

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Dec-25

System Name:		City of Canyonville		ID 41-00169		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	off	.029	.017	.017	.029
2	.017	.016	.018	.016	.019	off	.019
3	off	off	off	off	off	off	off
4	off	off	off	off	off	off	off
5	off	off	off	.026	.019	.018	.026
6	.017	.024	.019	off	off	.023	.024
7	.018	.017	.018	.019	.017	.019	.019
8	off	off	off	off	off	off	off
9	off	off	off	off	off	off	off
10	off	off	off	.022	.017	.019	.022
11	.016	.018	.017	.017	.019	.030	.030
12	off	off	off	.021	.016	.017	.021
13	.018	.021	off	off	off	off	.021
14	off	off	off	off	off	off	off
15	off	off	off	off	.021	.016	.021
16	.018	off	.027	.019	.019	.017	.027
17	.018	.020	.023	off	off	off	.023
18	off	off	off	off	off	off	off
19	off	off	off	off	.061	off	.061
20	off	off	off	off	.031	.025	.031
21	.023	.038	.038	off	off	off	.038
22	off	off	off	.027	.021	.022	.027
23	off	off	off	.023	.027	.021	.027
24	.027	.070	off	.030	.025	.019	.070
25	.024	.052	off	off	off	off	.052
26	off	off	off	.024	.021	.020	.024
27	.019	.020	off	off	off	off	.020
28	off	off	off	off	off	off	off
29	off	off	off	.031	.024	.022	.031
30	.025	.028	.042	.022	.025	.022	.042
31	off	off	off	.034	.020	.019	.034

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes/No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	Yes/No	Yes/No	Yes/No
All turbidity readings < IFE ² triggers	Yes/No		

Notes:	PRINTED NAME: <u>THOMAS C PAGE</u>	
	SIGNATURE: <u>[Signature]</u>	DATE: <u>1-5-26</u>
	PHONE #: <u>(541) 661-1745</u>	CERT #: <u>6358</u>

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	City of Canyonville	ID#: 41	00169	Month/Year:	Disinfection <i>Giardia</i> Log Inactive:	0.5
--------------	---------------------	---------	-------	-------------	--	-----

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1) 0932	1.76	21	37.0	9.1	7.19	33.0	YES	275
2) 0805	1.75	21	36.8	9.0	7.16	33.0	YES	275
3			plant	off				
4			plant	off				
5) 0825	1.65	21	34.7	9.5	7.19	32.0	YES	275
6) 0436	1.8	21	37.8	9.7	7.14	33.0	YES	275
7) 0926	1.81	21	38.0	9.9	7.13	33.0	YES	275
8			plant	off				
9			plant	off				
10) 0949	1.77	21	37.2	10.5	7.17	25.0	YES	275
11) 0843	1.67	21	35.1	10.6	7.10	25.0	YES	275
12) 0959	1.57	21	33.0	10.4	7.14	24.0	YES	275
13) 0630	1.73	21	36.3	7.9	7.12	33.0	YES	275
14			plant	off				
15) 1319	1.81	21	38.0	8.8	7.14	33.0	YES	275
16) 0826	1.73	21	36.3	9.3	7.07	33.0	YES	275
17) 0829	1.66	21	34.9	10.5	7.18	25.0	YES	275
18			plant	off			YES	
19) 1237	1.48	21	31.0	10.9	7.11	24.0	YES	275
20) 1250	1.79	21	37.6	11.1	6.89	20.0	YES	275
21) 0608	1.95	21	41.0	9.0	6.64	28.0	YES	275
22) 1001	1.63	21	34.2	9.4	6.93	27.0	YES	275
23) 1009	1.76	21	37.0	10.2	6.88	20.0	YES	275
24) 1101	1.6	21	34.0	9.2	7.00	26.0	YES	325
25) 0600	1.76	21	37.0	9.8	6.77	27.0	YES	275
26) 0954	1.67	21	35.0	9.9	6.85	27.0	YES	275
27) 0021	1.56	21	33.0	9.6	6.90	26.0	YES	275
28			plant	off			YES	
29) 1126	1.7	21	36.0	10.0	7.02	25.0	YES	325
30) 0816	1.68	21	35.0	7.9	7.11	33.0	YES	325
31) 0916	1.86	21	39.0	7.7	7.02	28.0	YES	275

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350