

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: Jan.-2026

| System Name: | City of Canyonville | | ID 41-00169 | | | | WTP: TP - A |
|--------------|---------------------|------------|-------------|------------|------------|------------|---|
| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the Day ¹ [NTU] |
| 1 | .017 | .018 | .019 | - | - | - | .019 |
| 2 | - | - | - | - | - | - | - |
| 3 | - | - | - | - | - | - | - |
| 4 | - | - | - | .026 | .022 | .018 | .018 .026 |
| 5 | .044 | .045 | - | .027 | .020 | .024 | .045 |
| 6 | .029 | - | - | .024 | .021 | .026 | .029 |
| 7 | .021 | - | - | - | .117 | .021 | .117 |
| 8 | .021 | .079 | .026 | .023 | - | - | .079 |
| 9 | - | - | - | - | - | - | - |
| 10 | - | - | - | - | - | - | - |
| 11 | - | - | - | - | .025 | .158 | .158 |
| 12 | - | - | - | .023 | .018 | .036 | .036 |
| 13 | - | - | - | - | .026 | .024 | .026 |
| 14 | .025 | .022 | .039 | .021 | - | .026 | .039 |
| 15 | .027 | .026 | .038 | .063 | .031 | - | .063 |
| 16 | - | - | - | - | - | - | - |
| 17 | - | - | - | - | - | - | - |
| 18 | - | - | .022 | .022 | .048 | - | .048 |
| 19 | - | - | - | .026 | - | .025 | .026 |
| 20 | .029 | .023 | - | - | - | - | .029 |
| 21 | - | - | - | - | - | - | - |
| 22 | - | - | - | - | - | - | - |
| 23 | - | - | - | .022 | .021 | .018 | .022 |
| 24 | .022 | .019 | .111 | - | - | - | .111 |
| 25 | - | - | - | .024 | .020 | .022 | .024 |
| 26 | .020 | - | - | - | - | - | .020 |
| 27 | - | - | - | - | - | - | - |
| 28 | - | - | - | - | - | .028 | .028 |
| 29 | .023 | .020 | .019 | .019 | - | .022 | .023 |
| 30 | .023 | .018 | - | - | - | - | .023 |
| 31 | - | - | - | - | - | - | - |

| Conventional or Direct Filtration | Monthly Summary (Answer Yes or No) | |
|--|---|---|
| 95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No | CT's met everyday? (see back) Yes / No | All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No |
| All 4-hour turbidity readings ≤ 1 NTU? Yes / No | | |
| All turbidity readings < IFE ² triggers Yes / No | | |

| | | |
|--------|-----------------------------------|---------------------|
| Notes: | PRINTED NAME: <u>RAYMOND PAGE</u> | DATE: <u>2-9-26</u> |
| | SIGNATURE: <u>[Signature]</u> | CERT #: <u>6358</u> |
| | PHONE #: <u>(541) 661-1745</u> | |

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP -: **A**

System Name: City of Canyonville ID#: 41 00169 Month/Year: **Jan. 2026** Disinfection *Giardia* Log Inactive: 0.5

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L] | Contact Time (T) [minutes] | Actual CT C X T | Temp [°C] | pH | Required CT formula | CT Met? ³ Yes / No | Peak Hourly Demand Flow [GPM] |
|-------------|--|-------------------------------|--------------------|--------------|------|------------------------|----------------------------------|----------------------------------|
| 1 0021 | 1.74 | 21 | 36 | 7.71 | 7.28 | 33 | Yes | 275 |
| 2 | | | | Plant off | | | | |
| 3 | | | | Plant off | | | | |
| 4 0615 | 1.82 | 21 | 38 | 9.36 | 7.32 | 33 | Yes | 275 |
| 5 0956 | 1.83 | 21 | 38 | 9.78 | 6.90 | 27 | Yes | 275 |
| 6 0946 | 1.64 | 21 | 34 | 9.92 | 6.79 | 27 | Yes | 275 |
| 7 0956 | 1.65 | 21 | 34 | 9.95 | 6.92 | 27 | Yes | 275 |
| 8 0410 | 1.65 | 21 | 34 | 8.89 | 7.04 | 27 | Yes | 275 |
| 9 | | | | Plant off | | | | |
| 10 | | | | Plant off | | | | |
| 11 1309 | 1.79 | 21 | 37 | 9.4 | 7.23 | 33 | Yes | 370 |
| 12 0844 | 1.72 | 21 | 36 | 8.14 | 7.09 | 27 | Yes | 275 |
| 13 0834 | 1.61 | 21 | 34 | 7.47 | 7.09 | 26 | Yes | 275 |
| 14 0800 | 1.67 | 21 | 35 | 6.45 | 7.2 | 33 | Yes | 275 |
| 15 0810 | 1.70 | 21 | 36 | 6.04 | 7.2 | 33 | Yes | 370 |
| 16 0820 | | | | Plant off | | | | |
| 17 | | | | Plant off | | | | |
| 18 0627 | 1.59 | 21 | 33, 39 | 7.36 | 7.23 | 32 | Yes | 370 |
| 19 0918 | 1.72 | 21 | 36 | 5.56 | 7.25 | 33 | Yes | 370 |
| 20 0630 | 2.01 | 21 | 42 | 5.24 | 7.27 | 33 | Yes | 370 |
| 21 | | | | Plant off | | | | |
| 22 | | | | Plant off | | | | |
| 23 0841 | 1.95 | 21 | 41 | 6.63 | 7.26 | 33 | Yes | 370 |
| 24 1230 | 1.84 | 21 | 38 | 5.19 | 7.24 | 33 | Yes | 370 |
| 25 0820 | 1.80 | 21 | 38 | 5.39 | 7.26 | 33 | Yes | 370 |
| 26 0021 | 3.14 | 21 | 66 | 4.08 | 7.36 | 53 | Yes | 370 |
| 27 | | | | Plant off | | | | |
| 28 1841 | 2.68 | 21 | 56 | 5.72 | 7.32 | 36 | Yes | 370 |
| 29 0831 | 2.04 | 21 | 42 | 7.5 | 7.23 | 33 | Yes | 370 |
| 30 0021 | 1.64 | 21 | 34 | 7.88 | 7.26 | 32 | Yes | 370 |
| 31 | | | | Plant off | | | | |

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350