

OHA - Drinking Water Services - Turbidity Monitoring Report Form

County: Douglas
 Month/Year: Feb. 2026

Conventional or Direct Filtration

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	-	-	-	-	-	.020	.020
2	.018	.021	.019	.027	.023	.019	.027
3	.021	.019	.018	-	-	-	.021
4	-	-	-	-	-	-	-
5	-	-	-	-	-	-	-
6	-	-	.026	.024	.020	.019	.026
7	.027	.021	.030	.020	.022	.022	.030
8	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-
10	-	-	-	-	-	.035	.035
11	.028	-	.051	.024	.023	.032	.032 .051
12	-	-	-	.027	.027	.031	.031
13	.062	-	.187	.036	.055	.052	.187
14	.022	.021	-	-	-	-	.022
15	-	-	-	-	-	-	-
16	-	-	.021	.026	.022	.024	.026
17	.022	.024	-	.028	.027	-	.028
18	-	-	-	-	-	-	-
19	-	-	-	-	-	-	-
20	-	-	-	.051	.067	.075	.075
21	.067	.058	-	.029	.026	.022	.067
22	.021	-	-	-	-	-	.021
23	-	-	-	-	-	-	-
24	-	-	-	.026	.022	.020	.026
25	.019	-	-	.031	.019	.020	.031
26	.018	.038	.018	.020	.019	-	.038
27	.023	.022	.022	.022	.020	.015	.023
28	-	.027	.022	-	-	-	.027
29							
30							
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes / No		
Notes:	PRINTED NAME: <u>Thomas C Page</u> SIGNATURE: <u>[Signature]</u> DATE: _____ PHONE #: <u>(541) 2661-1745</u> CERT #: <u>8358</u>	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter ETL (332-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: City of Canyonville	ID#: 41	00169	Month/Year: Feb. 2026	Disinfection Giardia Log Inactive: 0.5
----------------------------------	---------	-------	-----------------------	--

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp [°C]	pH	Required CT formule	CT Met? ² Yes / No	Peak Hourly Demand Flow [GPM]
12313	1.68	21	35	8.4	7.23	33	Yes	370
20829	1.71	21	36	7.8	7.31	33	yes	370
30805	1.70	21	35	7.1	7.3	33	Yes	370
4				Plant off				
5				Plant off				
6 0721	1.55	21	33	7.93	7.3	32	yes	370
7 0740	2.020	21	42.12	6.91	7.3	33	YES	370
8				Plant off				
9				Plant off				
10 1946	2.28	21	48	8.41	7.26	34	Yes	370
11 0927	1.67	21	35	8.52	7.00	27	Yes	370
12 0836	1.82	21	38	8.88	7.12	33	Yes	275
13 0712	1.68	21	35	9.06	7.12	33	Yes	370
14 0021	1.85	21	39	9.63	7.2	33	Yes	370
15				Plant off				
16 0753	1.72	21	36	9.68	7.23	33	yes	370
17 0638	1.66	21	35	7.93	7.23	33	Yes	370
18				Plant off				
19				Plant off				
20 0919	1.59	21	33	8.27	7.26	32	Yes	370
21 1018	1.70	21	36	7.43	7.23	32	yes	370
22 0021	1.75	21	37	8.69	7.22	33	Yes	370
23				Plant off				
24 0859	2.01	21	42	9.14	7.23	33	Yes	275
25 0021	1.74	21	36	10.7	6.67	20	Yes	275
26 0809	1.78	21	37	9.86	6.93	27	Yes	275
27	1.79	21	37.6	9.80	7.42	33	yes	275
28 0500	1.71	21	36	10.41	7.50	25	Yes	275
29								
30								
31								

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
dws.dmsa@oha.oregon.gov; 871-873-0884; or Drinking Water Services, PO Box 14380, Portland, OR 97283-0380