

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Douglas

Conventional or Direct Filtration

Month/Year: March 2026

System Name: City of Canyonville ID 41-00169 WTP : TP - A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	-	-	-	-	-	-	-
2	-	-	-	-	-	-	-
3	-	-	-	.019	.019	.017	.019
4	.014	-	-	-	-	.014	.014
5	.014	.015	.015	.012	.043	.026	.043
6	.026	.020	.022	.046	.082	-	.082
7	-	-	-	-	-	-	-
8	-	-	-	-	-	-	-
9	-	-	-	.014	.014	.015	.015
10	.014	.013	.011	.012	.046	.014	.046
11	.014	.014	.011	.012	.012	.011	.014
12	-	.016	-	-	-	-	.016
13	-	-	-	.018	.016	.014	.018
14	.014	-	-	-	-	-	.014
15	-	-	-	-	-	-	-
16	-	-	-	.012	.017	.015	.017
17	.016	.016	.015	.013	.013	.014	.016
18	.016	.015	-	-	-	-	.016
19	-	-	-	-	-	-	-
20	-	-	-	-	.023	.016	.023
21	.015	.016	.012	.015	.018	.016	.018
22	.013	-	-	-	-	-	.013
23	-	-	-	-	-	-	-
24	-	-	-	-	-	.016	.016
25	.015	.013	.014	.016	.016	.018	.018
26	.017	.016	-	-	-	-	.017
27	-	-	-	-	-	-	-
28	-	-	-	-	-	.063	.063
29	.014	.013	.013	.014	.015	.014	.015
30	.014	.017	-	-	-	-	.017
31	-	-	-	-	-	-	-

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No		
All turbidity readings < IFE ² triggers <input checked="" type="checkbox"/> Yes / No		

Notes:

PRINTED NAME: RAYMOND PAGE

SIGNATURE: [Signature] DATE: 4-6-26

PHONE #: (541) 861-1745 CERT #: 6358

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: City of Canyonville	ID#: 41	00169	Month/Year: March 2026	Disinfection Giardia Log Inactive: 0.5
----------------------------------	---------	-------	------------------------	--

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [°C]	pH	Required CT formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1								
2								
3 0858	1.67	21	35	10.3	7.48	25	yes	275
4 0838	1.63	21	34	11.56	7.53	25	yes	275
5 0826	1.89	21	39	10.03	7.13	25	yes	275
6 0800	1.97	21	41	9.86	7.24	33	yes	275
7	1.44	21						
8								
9 0911	1.44	21	30	11.13	7.3	24	yes	275
10 0818	1.65	21	35	9.71	7.26	33	yes	275
11 0827	1.66	21	35	9.38	7.23	33	yes	275
12 021	1.83	21	38	10.99	7.3	25	yes	275
13 0938	1.70	21	36	11.11	7.3	25	yes	370
14 0021	1.55	21	32	12.59	7.36	24	yes	370
15							yes	370
16 0842	1.25	21	26	12.4	7.38	23	yes	370
17 0815	1.6	21	34	11.7	7.36	24	yes	370
18 0600	1.5	21	31	12.68	7.34	24	yes	370
19								
20 1449	1.34	21	28	12.92	7.39	23	yes	370
21 0922	1.56	21	32	13.28	7.39	23	yes	370
22 0021	1.55	21	32	13.18	7.44	24	yes	370
23								
24 1850	1.33	21	28	13.26	7.43	23	yes	370
25 0822	1.50	21	31	12.76	7.40	24	yes	370
26 0021	1.34	21	28	12.79	7.47	23	yes	370
27								
28 0031	1.15	21	24	12.56	7.38	23	yes	370
29 0837	1.29	21	26	11.79	7.40	23	yes	370
30 0500	1.38	21	29	12.58	7.47	23	yes	370
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350