

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County:
Yamhill Conventional or Direct Filtration**

System Name: Carlton, City of ID #: 4100171 WTP-: A

Month/Year **January 2026**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.04	.03	OFF	.04	.03	.03	.24
2	/	.04	/	.06	.04	.03	.22
3	.05	/	.06	.03	.08	/	.26
4	.04	.04	/	.06	.07	.03	.43
5	/	/	.04	.03	.06	/	.42
6	.04	/	.04	.04	.03	/	.40
7	.06	.04	/	.04	.04	.09	.55
8	/	.07	/	.04	.04	.04	.39
9	/	.04	/	.05	.04	.05	.36
10	/	/	/	.05	.05	.04	.28
11	.04	/	.07	.04	.04	/	.20
12	.06	/	/	.06	.05	.05	.20
13	/	.06	/	.04	.05	.04	.13
14	/	.04	/	.05	.05	.06	.15
15	/	/	.06	.05	/	/	.13
16	.05	/	.07	.04	.04	/	.15
17	.05	/	/	.06	.04	.04	.18
18	/	/	/	.10	.07	.04	.19
19	.04	/	/	.05	/	.05	.13
20	/	.05	/	.06	/	.06	.20
21	.05	.05	/	.08	.05	/	.22
22	.05	/	.05	.05	.05	/	.18
23	.05	/	.05	.06	.05	/	.21
24	.08	/	/	.06	.06	.07	.25
25	/	/	/	.05	.07	.05	.25
26	.05	/	/	.06	.05	.05	.27
27	/	.05	/	.05	.05	.06	.24
28	/	/	.08	.05	.05	/	.20
29	.10	/	/	.08	.06	/	.24
30	.06	/	/	.08	.06	.06	.27
31	/	.08	/	.10	.06	.08	.31

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of the 4-hour turbidity readings ≤ 0.3 NTU? **Yes** / No
 All the 4-hour turbidity readings ≤ 1 NTU? **Yes** / No
 All turbidity readings < IFE triggers? **Yes** / No²

CT's met everyday?
 (see back)
Yes / No

All Cl₂ residuals at entry point ≥ 0.2 m
Yes / No

Notes:

PRINTED NAME: Bryan W. Burnham

SIGNATURE: *Bryan W. Burnham*

DATE: **2/3/2026**

PHONE #: (503) 852-3104

CERT #: 6201

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program – Surface Water Quality Data Form - *Giardia* Inactivation

System Name: Carlton, City of ID #: 4100171	WTP-: A	Month/Year: January 2026	Log Requirement (Circle One): 0.5/ 1.0
---	----------------	---------------------------------	--

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT/Met ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 /9:00	1.8	72	129	11	7.4	50	YES	233
2 /9:00	1.8	72	129	11	7.4	50	YES	266
3 /9:00	1.5	72	108	13	7.6	45	YES	242
4 /9:00	1.5	72	108	13	7.6	45	YES	260
5 /9:00	1.5	72	108	13	7.6	45	YES	2,565
6 /9:00	1.8	72	129	9	7.6	62	YES	269
7 /4:00	1.6	72	115	10	7.5	55	YES	249
8 /1:00	1.7	72	122	10	7.6	57	YES	264
9 /9:00	1.7	72	122	9	7.6	60	YES	222
10 /10:00	1.7	72	122	9	7.6	60	YES	223
11 /10:00	1.7	72	122	9	7.6	60	YES	238
12 /10:00	1.7	72	122	9	7.6	60	YES	220
13 /11:00	1.7	72	122	10	7.6	57	YES	239
14 /3:30	1.7	72	122	10	7.6	57	YES	226
15 /11:00	1.6	72	115	10	7.6	57	YES	217
16 /9:00	1.8	72	129	10	7.2	50	YES	229
17 /10:00	1.6	72	115	9	7.3	54	YES	225
18 /10:00	1.6	72	115	9	7.3	54	YES	233
19 /10:00	1.6	72	115	9	7.3	54	YES	232
20 /11:00	1.8	72	129	8	7.6	65	YES	255
21 /9:00	1.5	72	108	8	7.6	62	YES	233
22 /3:30	1.5	72	108	8	7.6	62	YES	233
23 /9:30	1.7	72	122	7	7.6	67	YES	227
24 /11:30	1.4	72	100	6	7.6	69	YES	203
25 /11:30	1.4	72	100	6	7.6	69	YES	218
26 /11:30	1.4	72	100	6	7.6	69	YES	968
27 /9:30	1.6	72	115	6	7.4	65	YES	233
28 /10:30	1.7	72	122	8	7.3	57	YES	232
29 /12:00	1.7	72	122	9	7.4	55	YES	236
30 /11:00	1.9	72	136	9	7.5	59	YES	249
31 /11:00	1.3	72	93	11	7.5	49	YES	215

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised January 2014