

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Clackamas
Conventional or Direct Filtration**

System Name: CLACKAMAS RIVER WATER - CLACKAMAS ID #: 4100187 WTP: A Month/Year: Feb-2026

DAY	2 AM [NTU]	6 AM [NTU]	10 AM [NTU]	2 PM [NTU]	6 PM [NTU]	10 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	off	0.02	0.02	0.02	0.02
2	off	off	off	0.03	0.03	0.03	0.03
3	off	off	off	off	0.03	0.03	0.03
4	off	off	0.03	0.03	0.03	0.03	0.03
5	off	off	off	0.03	0.03	0.03	0.03
6	off	off	0.03	0.02	0.02	0.02	0.03
7	off	off	off	0.02	0.02	0.02	0.02
8	off	off	off	0.02	0.02	0.02	0.02
9	off	off	off	0.03	0.03	0.03	0.03
10	off	off	0.03	0.03	0.03	0.03	0.03
11	off	off	0.03	0.03	off	off	0.03
12	off	off	off	0.04	0.04	off	0.04
13	off	off	0.03	0.05	0.03	0.03	0.05
14	off	off	off	0.02	0.02	0.02	0.02
15	off	off	off	0.02	0.02	0.02	0.02
16	off	off	0.03	0.03	off	off	0.03
17	off	off	off	0.03	0.03	0.03	0.03
18	off	off	0.03	0.03	0.03	0.03	0.03
19	off	off	off	0.03	0.03	0.03	0.03
20	off	off	0.03	0.03	off	off	0.03
21	off	off	off	0.02	0.02	0.02	0.02
22	off	off	off	0.02	0.02	0.03	0.03
23	off	off	off	0.03	0.03	0.03	0.03
24	off	off	0.03	0.03	0.03	0.03	0.03
25	off	off	off	0.03	0.03	0.04	0.04
26	off	off	0.03	0.03	0.03	off	0.03
27	off	off	0.03	0.05	0.03	0.03	0.05
28	off	off	off	0.02	0.03	0.03	0.03

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No All turbidity readings < IFF2 triggers? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl ₂ residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
Notes:	PRINTED NAME: Katelynn Niece	
	SIGNATURE: <i>Katelynn Niece</i>	DATE: 03/02/2026
	PHONE #: (971) 997-3305	CERT #: T08621

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Clackamas River Water-Clackamas ID#: 4100187 WTP: A Disinfection *Giardia* Log Inactiv: 1

Feb-2026

Date / Time	Pre-Chlorination Segment									Post-Chlorination Segment									Total		CT Met? ³ Yes / No	
	Minimum free chlorine residual after pre-chlorination (C) [ppm or mg/L]	Peak hourly demand flow (Pre) [GPM]	Contact time (Pre) (T) [minutes]	Actual CT (Pre) C X T	pH (Pre)	temp (Pre) [° C]	Required CT (Total) formula	Actual CT / Required CT (Pre)	Percent log inactivation achieved (Pre)	Minimum free chlorine residual after post-chlorination (C) ³ [ppm or mg/L]	Peak hourly demand flow (Post) [GPM]	Contact Time (Post) (T) [minutes]	Actual CT (Post) C X T	pH (Post)	temp (Post) [° C]	Required CT (Total) formula	Actual CT / Required CT (Post)	Percent log inactivation achieved (Post)	Actual CT / Required CT Sum of Pre and Post	Total percent of require log inactivation achieved		
1/ 22:00	0.71	8604	38.0	27.0	7.09	8.4	42.9	0.6	62.9	1.16	9624	74.1	86.0	7.66	11.8	44.0	2.0	195.5	2.59	258.4	Y	
2/ 14:00	0.27	4562	34.5	9.3	7.04	8.4	39.9	0.2	23.3	1.11	5319	138.7	154.0	7.50	9.9	46.9	3.3	328.4	3.52	351.7	Y	
3/ 19:00	1.03	7166	44.2	45.5	7.11	8.9	43.3	1.1	105.1	1.35	9090	75.8	102.3	8.54	11.4	63.4	1.6	161.4	2.66	266.4	Y	
4/ 09:00	0.80	7458	43.0	34.4	7.03	8.4	42.3	0.8	81.3	1.33	10944	63.7	84.7	7.86	11.8	48.0	1.8	176.5	2.58	257.8	Y	
5/ 13:00	0.31	7513	30.1	9.3	7.06	9.1	38.6	0.2	24.1	1.16	8249	87.4	101.4	7.66	10.0	49.5	2.0	204.8	2.29	228.9	Y	
6/ 21:00	0.71	4520	63.5	45.1	7.13	9.0	41.4	1.1	108.9	1.18	4243	162.8	192.1	7.66	12.1	43.3	4.4	443.6	5.55	552.6	Y	
7/ 22:00	0.77	4604	58.6	45.1	7.03	9.1	40.4	1.1	111.6	1.13	5236	137.0	154.8	7.54	11.8	42.2	3.7	366.8	4.79	478.5	Y	
8/ 20:00	0.74	9159	40.0	29.6	6.97	9.6	38.2	0.8	77.5	1.19	9715	71.4	85.0	7.54	12.4	40.5	2.1	209.9	2.87	287.4	Y	
9/ 16:00	0.79	7673	32.9	26.0	6.97	9.6	38.2	0.7	68.1	1.22	10748	68.1	83.1	7.84	12.4	45.4	1.8	183.0	2.51	251.1	Y	
10/ 17:00	0.65	7224	69.4	45.1	7.02	9.4	38.9	1.2	115.9	1.24	8868	76.1	94.4	7.72	11.5	46.3	2.0	203.9	3.20	319.8	Y	
11/ 10:00	0.61	4680	56.8	34.6	6.97	8.6	40.2	0.9	86.1	1.12	5340	135.8	152.1	7.76	11.1	47.4	3.2	320.9	4.07	407.0	Y	
12/ 15:00	0.54	7756	37.7	20.4	6.95	9.0	38.4	0.5	53.1	1.14	9854	70.4	80.2	7.63	11.1	45.4	1.8	176.7	2.30	229.8	Y	
13/ 22:00	0.85	11694	32.2	27.4	6.96	9.1	39.7	0.7	69.0	1.26	10805	67.8	85.5	7.60	12.4	41.8	2.0	204.5	2.73	273.6	Y	
14/ 16:00	0.80	8833	31.9	25.5	7.02	8.9	40.8	0.6	62.5	1.11	10791	65.9	73.2	7.63	12.0	42.7	1.7	171.4	2.34	233.9	Y	
15/ 17:00	0.77	8909	58.5	45.0	7.01	9.1	39.9	1.1	112.8	1.22	6520	106.9	130.4	7.64	12.0	43.4	3.0	300.5	4.13	413.2	Y	
16/ 13:00	0.54	4576	63.8	34.4	6.99	8.6	40.0	0.9	86.0	1.36	5305	136.9	186.1	7.65	11.4	46.0	4.0	404.6	4.91	490.6	Y	
17/ 18:00	0.62	8951	37.5	23.3	7.05	8.6	41.2	0.6	56.6	1.21	4845	71.3	86.2	7.62	11.6	44.2	2.0	195.0	2.52	251.6	Y	
18/ 12:00	0.67	7666	36.7	24.6	7.07	8.4	42.4	0.6	58.0	1.29	9881	70.5	91.0	7.40	9.7	46.7	1.9	194.9	2.53	252.9	Y	
19/ 13:00	0.15	9062	31.5	4.7	7.01	8.7	38.4	0.1	12.2	1.10	9861	71.3	78.5	7.31	9.3	45.5	1.7	172.5	1.85	184.8	Y	
20/ 10:00	0.66	9048	38.2	25.2	6.95	8.2	41.0	0.6	61.5	1.14	9694	74.3	84.6	7.73	10.5	49.1	1.7	172.3	2.34	233.8	Y	
21/ 20:00	0.94	11659	33.2	31.2	7.11	8.8	43.0	0.7	72.6	1.09	12069	56.7	61.8	7.73	10.8	47.7	1.3	129.6	2.02	202.1	Y	
22/ 18:00	0.84	11784	35.3	29.7	7.06	9.0	41.3	0.7	71.9	1.14	11013	62.0	70.6	7.66	10.9	46.4	1.5	152.2	2.24	224.1	Y	
23/ 17:00	0.83	4861	53.1	44.0	6.93	9.0	41.3	1.1	106.5	1.17	8118	92.3	108.0	7.81	10.6	50.4	2.1	214.3	3.26	320.8	Y	
24/ 10:00	0.92	7145	39.4	36.7	6.43	8.6	40.9	0.9	89.7	1.07	7374	93.8	110.6	7.90	10.2	53.5	2.1	206.7	3.17	296.5	Y	
25/ 21:00	0.66	7224	38.8	25.6	6.75	9.6	35.0	0.7	73.1	1.12	8048	87.6	98.1	7.80	12.0	45.3	2.2	216.6	2.90	289.7	Y	
26/ 10:00	0.58	4749	55.4	32.1	6.73	8.9	36.0	0.9	89.2	1.13	7388	101.5	114.7	7.93	10.7	51.8	2.2	221.4	3.11	310.6	Y	
27/15:00	0.56	7187	54.2	30.4	6.80	9.1	36.3	0.8	83.7	1.36	6972	97.9	133.1	7.72	10.8	49.2	2.7	270.5	3.55	354.3	Y	
28/16:00	0.77	11805	42.3	32.5	6.87	8.8	39.0	0.8	83.3	1.23	9048	75.0	92.2	7.70	10.7	48.2	1.9	191.3	2.75	274.6	Y	
29/																						
30/																						
31/																						

³ If Cl2 at entry point < 0.2 mg/l or CT not met, DWP to be notified by end of next business day.