

OHA - Drinking Water Program - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems


County: Tillamook

Month/Year: May-22

System Name: Beaver Water District ID#: 4100199

WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
5/1/2022		0.034	0.027	0.027			0.034
5/2/2022		0.025	0.027	0.030			0.030
5/3/2022		0.025	0.026	0.026	0.026		0.026
5/4/2022		0.029	0.026	0.026			0.029
5/5/2022		0.028	0.026	0.026			0.028
5/6/2022		0.028	0.026	0.050			0.050
5/7/2022		0.059	0.071	0.044			0.071
5/8/2022		0.050	0.033	0.030			0.050
5/9/2022		0.027	0.027	0.027			0.027
5/10/2022		0.026	0.026				0.026
5/11/2022		0.029	0.026	0.026			0.029
5/12/2022		0.028	0.026	0.027			0.028
5/13/2022		0.082	0.062	0.048	0.034		0.082
5/14/2022		0.029	0.055	0.046			0.055
5/15/2022		0.032	0.026	0.026			0.032
5/16/2022		0.028	0.026	0.027			0.028
5/17/2022		0.027	0.026	0.025	0.025		0.027
5/18/2022		0.082	0.035	0.031	0.030		0.082
5/19/2022		0.036	0.028	0.028			0.036
5/20/2022		0.036	0.026	0.027			0.036
5/21/2022		0.029	0.026				0.029
5/22/2022		0.026	0.026	0.026			0.026
5/23/2022		0.052	0.032	0.029	0.027		0.052
5/24/2022		0.029	0.026				0.029
5/25/2022		0.028	0.026	0.026			0.028
5/26/2022		0.027	0.026	0.027			0.027
5/27/2022		0.028	0.026	0.026	0.028		0.028
5/28/2022		0.026	0.026	0.027			0.027
12/29/2022		0.044	0.170	0.035			0.170
12/30/2022		0.029	0.028				0.029
12/31/2022		0.027	0.027	0.027			0.027

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No) Rev. 7-2-18 T.N.T	
95% of daily turbidity readings ≤ 1 NTU? ²	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:		PRINTED NAME: Troy N. Trute	
		SIGNATURE: 	DATE: 6-6-22
		PHONE #: (541)992-1655	CERT #: D-08123 T-08076

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not

correspond to continuous readings' maximum. ² Filtered systems only. Page 1 of 2

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP - : WTP-A

System Name: Beaver Water	ID#: 4100199	Month/Year: May-22	Disinfectio n Giardia	Log	1.0
District					

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.68	97	65.96	11.4	5.86	23.4	Yes	76
2	0.81	97	78.57	11.1	6.84	33.3	Yes	76
3	0.96	97	93.12	10.8	6.52	31.0	Yes	76
4	0.85	97	82.45	10.7	6.43	29.9	Yes	76
5	0.84	97	81.48	11.2	6.39	28.6	Yes	76
6	0.94	97	91.18	10.8	6.25	28.3	Yes	76
7	1.07	97	103.79	11	6.46	30.4	Yes	76
8	0.98	97	95.06	9.9	6.86	36.9	Yes	76
9	1.05	97	101.85	11.1	6.45	30.0	Yes	76
10	1.11	97	107.67	9.6	6.70	36.1	Yes	76
11	1.18	97	114.46	10.7	6.38	30.5	Yes	76
12	0.75	97	72.75	11	6.39	28.7	Yes	74
13	0.85	97	82.45	11	6.73	32.5	Yes	71
14	0.7	97	67.9	10.7	6.85	33.9	Yes	73
15	1.01	97	97.97	10.9	6.03	26.3	Yes	73
16	0.82	97	79.54	11.3	7.03	35.1	Yes	75
17	0.99	97	96.03	11.3	6.30	28.0	Yes	71
18	0.81	97	78.57	11.1	6.52	29.9	Yes	75
19	0.8	97	77.6	11	6.95	34.8	Yes	71
20	0.96	97	93.12	10.9	6.58	31.4	Yes	74
21	0.85	97	82.45	11.1	6.65	31.4	Yes	73
22	0.81	97	78.57	10.9	6.08	26.2	Yes	74
23	1.14	97	110.58	11.5	6.69	32.0	Yes	73
24	1.19	97	115.43	11.9	8.72	64.0	Yes	73
25	0.98	97	95.06	12.2	6.36	27.0	Yes	70
26	1.06	97	102.82	12	6.59	29.7	Yes	74
27	0.96	97	93.12	12.3	6.42	27.3	Yes	71
28	0.77	97	74.69	11.7	6.32	26.9	Yes	73
29	0.68	97	65.96	12.1	6.58	28.3	Yes	76
30	0.96	97	93.12	11.7	6.37	27.9	Yes	69
31	1.07	97	103.79	11.6	6.33	28.0	Yes	73

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

lwp.dmce@state.or.us 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350