


OHA - Drinking Water Program - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Tillamook**
 Month/Year: **Feb-24**

| System Name: Beaver Water District | | ID#: 4100199 | | WTP: TP - | | WTP- A | |
|---|-------------|---------------------|------------|------------------|------------|---------------|---|
| Day | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the day ¹ [NTU] |
| 2/1/2024 | | | | | | | Off |
| 2/2/2024 | | | 0.206 | | | | 0.206 |
| 2/3/2024 | | | | | | | Off |
| 2/4/2024 | | | | | | | Off |
| 2/5/2024 | | | 0.070 | | | | 0.070 |
| 2/6/2024 | | | 0.076 | 0.110 | | | 0.110 |
| 2/7/2024 | | | | | | | Off |
| 2/8/2024 | | | | | | | Off |
| 2/9/2024 | | | 0.059 | 0.161 | | | 0.161 |
| 2/10/2024 | | | | | | | Off |
| 2/11/2024 | | | | | | | Off |
| 2/12/2024 | | | 0.163 | | | | 0.163 |
| 2/13/2024 | | | 0.165 | 0.036 | | | 0.165 |
| 2/14/2024 | | | 0.066 | 0.034 | 0.035 | | 0.066 |
| 2/15/2024 | | | 0.166 | 0.040 | | | 0.166 |
| 2/16/2024 | | | 0.050 | | | | 0.050 |
| 2/17/2024 | | | | | | | Off |
| 2/18/2024 | | | | | | | Off |
| 2/19/2024 | | | 0.044 | 0.060 | 0.032 | | 0.060 |
| 2/20/2024 | | | 0.060 | | | | 0.060 |
| 2/21/2024 | | | 0.040 | | | | 0.040 |
| 2/22/2024 | | | | | | | Off |
| 2/23/2024 | | | 0.035 | 0.035 | | | 0.035 |
| 2/24/2024 | | | | | | | Off |
| 2/25/2024 | | | | | | | Off |
| 2/26/2024 | | | 0.036 | | | | 0.036 |
| 2/27/2024 | | | | | | | Off |
| 2/28/2024 | | | | | | | Off |
| 2/29/2024 | | | | | | | Off |
| 3/1/2024 | | | | | | | Off |
| 3/2/2024 | | | | | | | Off |

| | | | |
|---|---|--|---|
| Slow Sand/Membrane/DE Filtration/Unfiltered | | Monthly Summary (Answer Yes or No) Rev. 7-2-18 T.N.T | |
| 95% of daily turbidity readings ≤ 1 NTU? ² | <input checked="" type="radio"/> Yes / No | CT's met everyday? (see back) | All Cl2 residual at entry point ≥ 0.2 mg/l? |
| All daily turbidity readings ≤ 5 NTU? | <input checked="" type="radio"/> Yes / No | <input checked="" type="radio"/> Yes / No | <input checked="" type="radio"/> Yes / No |
| Notes: | | PRINTED NAME: Troy N. Trute | |
| | | SIGNATURE:  | DATE: 3-11-24 |
| | | PHONE #: (541)992-1655 | CERT #: D-08123 T-08076 |

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² Filtered systems only. Page 1 of 2

| | | | |
|--|--------------|-------------------------|--|
| System Name: Beaver Water District | ID#: 4100199 | Month/Year: February-24 | Disinfectio n <i>Giardia</i> Log 1.0 |
|--|--------------|-------------------------|--|

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand Flow |
|-------------|--|------------------------|-----------|-------|------|-------------|----------------------|----------------------------------|
| | [ppm or mg/l] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | off | 97 | Off | | | Off | Off | |
| 2 | 0.6 | 97 | 58.2 | 10.6 | 7.00 | 35.5 | Yes | 68.7 |
| 3 | off | 97 | Off | | | Off | Off | |
| 4 | off | 97 | Off | | | Off | Off | |
| 5 | 0.7 | 97 | 67.9 | 10.3 | 7.20 | 39.2 | Yes | 68.7 |
| 6 | 0.6 | 97 | 58.2 | 10.2 | 7.50 | 43.4 | Yes | 67.7 |
| 7 | off | 97 | Off | | | Off | Off | |
| 8 | off | 97 | Off | | | Off | Off | |
| 9 | 0.75 | 97 | 72.75 | 9.9 | 8.00 | 53.7 | Yes | 68.8 |
| 10 | off | 97 | Off | | | Off | Off | |
| 11 | off | 97 | Off | | | Off | Off | |
| 12 | 0.6 | 97 | 58.2 | 10 | 6.70 | 33.3 | Yes | 65.1 |
| 13 | 0.65 | 97 | 63.05 | 9 | 7.00 | 39.6 | Yes | 69.8 |
| 14 | 0.75 | 97 | 72.75 | 9.2 | 7.40 | 45.5 | Yes | 69.2 |
| 15 | 0.6 | 97 | 58.2 | 9 | 7.40 | 45.3 | Yes | 62.5 |
| 16 | 0.7 | 97 | 67.9 | 9.5 | 7.20 | 41.3 | Yes | 68.3 |
| 17 | off | 97 | Off | | | Off | Off | |
| 18 | off | 97 | Off | | | Off | Off | |
| 19 | 0.6 | 97 | 58.2 | 9.9 | 7.50 | 44.2 | Yes | 67.2 |
| 20 | 0.65 | 97 | 63.05 | 10.6 | 7.90 | 48.9 | Yes | 68.7 |
| 21 | 0.65 | 97 | 63.05 | 10.3 | 7.10 | 37.7 | Yes | 69.1 |
| 22 | off | 97 | Off | | | Off | Off | |
| 23 | 0.55 | 97 | 53.35 | 9.2 | 7.00 | 38.7 | Yes | 67.1 |
| 24 | off | 97 | Off | | | Off | Off | |
| 25 | off | 97 | Off | | | Off | Off | |
| 26 | 0.65 | 97 | 63.05 | 10.3 | 7.20 | 39.0 | Yes | 68.5 |
| 27 | off | 97 | Off | | | Off | Off | |
| 28 | off | 97 | Off | | | Off | Off | |
| 29 | off | 97 | Off | | | Off | Off | |
| 30 | off | 97 | Off | | | Off | Off | |
| 31 | off | 97 | Off | | | Off | Off | |

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

wp.dmce@state.or.us 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350