


**OHA - Drinking Water Program - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Tillamook**  
 Month/Year: **Jun-24**  
 WTP: TP - **WTP-A**

System Name:	Beaver Water District		ID#: 4100199				WTP: TP - WTP-A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]	
6/1/2024			0.086	0.044			0.086	
6/2/2024							Off	
6/3/2024							Off	
6/4/2024			0.050	0.037			0.050	
6/5/2024							Off	
6/6/2024				0.046			0.046	
6/7/2024				0.037	0.037		0.037	
6/8/2024							Off	
6/9/2024				0.037			0.037	
6/10/2024				0.050	0.035		0.050	
6/11/2024							Off	
6/12/2024			0.032	0.032	0.032		0.032	
6/13/2024				0.040	0.040		0.040	
6/14/2024				0.100			0.100	
6/15/2024							Off	
6/16/2024				0.088	0.032		0.088	
6/17/2024			0.035	0.031			0.035	
6/18/2024							Off	
6/19/2024				0.042	0.032		0.042	
6/20/2024				0.036	0.033		0.036	
6/21/2024				0.033			0.033	
6/22/2024							Off	
6/23/2024				0.066	0.036		0.066	
6/24/2024				0.036	0.030		0.036	
6/25/2024				0.035			0.035	
6/26/2024				0.033			0.033	
6/27/2024				0.034	0.038		0.038	
6/28/2024			0.033				0.033	
6/29/2024							Off	
6/30/2024			0.036	0.038			0.038	
7/1/2024							Off	

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>  95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <input checked="" type="radio"/> Yes / No  All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / No	<b>Monthly Summary (Answer Yes or No)</b> Rev. 7-3-24 L.J.C CT's met everyday?                      All Cl2 residual at entry point (see back)                                      ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No <input checked="" type="radio"/> Yes / No	
	<b>Notes:</b>	
<b>PRINTED NAME:</b> Larry J Chitwood		
<b>SIGNATURE:</b> 		
<b>PHONE #:</b> (503)801-3338		
<b>DATE:</b> 7-3-2024		
<b>CERT #:</b> 549298		

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.                      Page 1 of 2



OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name:  
Beaver Water  
District

ID#: 4100199

Month/Year: June-24

Disinfection  
Giardia Log  
Inactiv: 1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.8	97	77.6	13.9	8.00	41.5	Yes	68.7
2	off	97	Off			Off	Off	
3	off	97	Off			Off	Off	
4	0.6	97	58.2	12.4	7.00	31.7	Yes	69.6
5	off	97	Off			Off	Off	
6	0.6	97	58.2	14.2	6.90	26.4	Yes	71.3
7	0.6	97	58.2	14.8	6.80	24.5	Yes	67.9
8	off	97	Off			Off	Off	
9	0.8	97	77.6	16	6.90	24.0	Yes	70.1
10	0.5	97	48.5	14.8	6.80	24.2	Yes	67.3
11	off	97	Off			Off	Off	
12	0.6	97	58.2	12.9	7.00	29.9	Yes	70.1
13	0.65	97	63.05	12.9	7.80	40.5	Yes	71
14	0.6	97	58.2	14.7	7.20	28.6	Yes	71.4
15	off	97	Off			Off	Off	
16	0.6	97	58.2	14.2	7.40	31.8	Yes	67.2
17	0.65	97	63.05	11.3	8.20	51.9	Yes	69.6
18	off	97	Off			Off	Off	
19	0.5	97	48.5	14.3	7.40	31.3	Yes	67.7
20	0.7	97	67.9	15.2	8.00	37.6	Yes	68.4
21	0.8	97	77.6	14.6	7.70	35.4	Yes	66.7
22	off	97	Off			Off	Off	
23	0.7	97	67.9	15.9	7.20	26.7	Yes	70.5
24	0.5	97	48.5	16.6	8.30	37.4	Yes	69.2
25	0.7	97	67.9	15.8	6.90	24.0	Yes	67.7
26	0.65	97	63.05	16.4	7.90	33.3	Yes	68.7
27	0.5	97	48.5	15.8	7.50	29.4	Yes	66.4
28	0.6	97	58.2	15.8	7.70	32.0	Yes	70.2
29	off	97	Off			Off	Off	
30	0.7	97	67.9	18.2	8.20	33.2	Yes	66.3
31	off	97	Off			Off	Off	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

[lwpc.dmce.state.or.us](mailto:lwpc.dmce.state.or.us) 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350