


OHA - Drinking Water Program - Surface Water Quality Data Form
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: Tillamook

Month/Year: Apr-22

System Name: Beaver Water District ID#: 4100199 WTP: TP - WTP-A

Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
4/1/2022		0.027	0.025	0.025			0.027
4/2/2022		0.027	0.025	0.025	0.025		0.027
4/3/2022		0.025	0.025				0.025
4/4/2022		0.100	0.113	0.045			0.113
4/5/2022		0.049	0.057	0.029			0.057
4/6/2022		0.045	0.054	0.070			0.070
4/7/2022		0.032	0.025	0.025			0.032
4/8/2022		0.038	0.025	0.026			0.038
4/9/2022		0.025	0.025	0.025	0.025		0.025
4/10/2022		0.031	0.028				0.031
4/11/2022		0.025	0.025	0.155	0.029		0.155
4/12/2022		0.036	0.040				0.040
4/13/2022		0.183	0.058				0.183
4/14/2022		0.036	0.032	0.032			0.036
4/15/2022		0.031	0.028	0.028			0.031
4/16/2022		0.030	0.026	0.026			0.030
4/17/2022		0.026	0.026				0.026
4/18/2022		0.026	0.026	0.027			0.027
4/19/2022		0.027	0.027	0.027			0.027
4/20/2022		0.112	0.047	0.035			0.112
4/21/2022		0.059	0.029	0.029			0.059
4/22/2022		0.036	0.028	0.029			0.036
4/23/2022		0.035	0.035				0.035
4/24/2022		0.046	0.047	0.025			0.047
4/25/2022		0.025	0.026	0.027			0.027
4/26/2022		0.026	0.026	0.027			0.027
4/27/2022		0.025	0.027	0.029			0.029
4/28/2022		0.025	0.040	0.040			0.040
4/29/2022		0.053	0.043	0.047	0.040		0.053
4/30/2022		0.052	0.089	0.033	0.030		0.089

Slow Sand/Membrane/DE Filtration/Unfiltered 95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / No	Monthly Summary (Answer Yes or No) Rev. 7-2-18 T.N.T	
	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
Notes:	PRINTED NAME: Troy N. Trute SIGNATURE:  PHONE #: (541)992-1655	
	DATE: 5-9-22 CERT #: D-08123 T-08076	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name: Beaver Water District	ID#: 4100199	Month/Year: April-22	Disinfectio n <i>Giardia</i> Log	WTP-A 1.0
---------------------------------------	--------------	----------------------	--	--------------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.03	97	99.91	10.2	6.07	27.9	Yes	76
2	0.92	97	89.24	10.5	6.16	27.9	Yes	76
3	0.84	97	81.48	11.1	6.66	31.5	Yes	76
4	0.7	97	67.9	10.2	7.55	44.6	Yes	76
5	1.1	97	106.7	10.6	5.80	25.1	Yes	76
6	0.86	97	83.42	8.6	7.71	53.5	Yes	76
7	0.87	97	84.39	10.5	5.55	22.8	Yes	76
8	0.85	97	82.45	11	5.69	23.1	Yes	76
9	0.87	97	84.39	10.8	5.91	25.1	Yes	76
10	0.71	97	68.87	10.6	7.87	48.7	Yes	76
11	0.89	97	86.33	9.9	8.17	58.0	Yes	76
12	0.8	97	77.6	9.8	6.07	27.9	Yes	76
13	1.04	97	100.88	10.1	5.76	25.4	Yes	76
14	1.05	97	101.85	10.3	6.18	28.8	Yes	76
15	1.16	97	112.52	8.6	6.37	34.6	Yes	76
16	0.86	97	83.42	10.2	6.20	28.6	Yes	76
17	0.79	97	76.63	9.5	6.95	38.3	Yes	76
18	0.73	97	70.81	10.9	6.45	29.3	Yes	76
19	0.74	97	71.78	10.4	5.82	24.6	Yes	76
20	0.99	97	96.03	9.2	6.67	36.2	Yes	76
21	0.84	97	81.48	10.5	6.18	27.8	Yes	76
22	0.75	97	72.75	10.7	6.16	27.1	Yes	76
23	0.83	97	80.51	10.8	6.43	29.7	Yes	76
24	0.79	97	76.63	10.2	6.71	33.7	Yes	76
25	0.78	97	75.66	11.4	6.85	32.7	Yes	76
26	0.9	97	87.3	11.1	6.53	30.3	Yes	76
27	0.91	97	88.27	10.8	6.57	31.3	Yes	76
28	0.81	97	78.57	11	5.86	24.3	Yes	76
29	1.08	97	104.76	10.7	6.31	29.4	Yes	76
30	0.81	97	78.57	10.6	7.74	47.1	Yes	76

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

wp.dmce@state.or.us 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350