


OHA - Drinking Water Program - Surface Water Quality Data Form  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

County: **Tillamook**  
 Month/Year: **Jun-22**

System Name: <b>Beaver Water District</b>		ID#: <b>4100199</b>		WTP: <b>TP -</b>		WTP- <b>A</b>	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
6/1/2022		0.027	0.027	0.027			0.027
6/2/2022		0.027	0.026	0.026			0.027
6/3/2022		0.038	0.032	0.030			0.038
6/4/2022		0.035	0.027	0.027			0.035
6/5/2022		0.028	0.112	0.028			0.112
6/6/2022		0.038	0.044	0.029			0.044
6/7/2022		0.026	0.026	0.026			0.026
6/8/2022		0.029	0.026	0.026			0.029
6/9/2022		0.071	0.033	0.030			0.071
6/10/2022		0.029	0.190	0.029			0.190
6/11/2022		0.034	0.026	0.026			0.034
6/12/2022		0.029	0.073				0.073
6/13/2022		0.026	0.027	0.027			0.027
6/14/2022		0.026	0.027				0.027
6/15/2022		0.050	0.032	0.030	0.029		0.050
6/16/2022		0.050	0.028	0.028	0.027		0.050
6/17/2022		0.041	0.027	0.027			0.041
6/18/2022		0.038	0.026	0.027			0.038
6/19/2022		0.030	0.026				0.030
6/20/2022		0.028	0.026	0.026			0.028
6/21/2022		0.035	0.028				0.035
6/22/2022		0.035	0.027	0.027	0.028		0.035
6/23/2022		0.037	0.026	0.026	0.026		0.037
6/24/2022		0.029	0.026	0.027	0.026		0.029
6/25/2022		0.029	0.027	0.026	0.026		0.029
6/26/2022		0.028	0.026	0.060	0.052	0.042	0.060
6/27/2022		0.030	0.034	0.030			0.034
6/28/2022		0.034	0.030	0.029	0.029		0.034
6/29/2022		0.027	0.027	0.036			0.036
6/30/2022		0.028	0.029	0.028			0.029

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>  95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <input checked="" type="radio"/> Yes / No  All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / No	<b>Monthly Summary (Answer Yes or No)</b> <span style="float: right;">Rev. 7-2-18 T.N.T</span>	
	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
<b>Notes:</b>	PRINTED NAME: <b>Troy N. Trute</b> SIGNATURE:  PHONE #: <b>(541)992-1655</b>	
	DATE: <b>7-8-22</b> CERT #: <b>D-08123 T-08076</b>	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not

correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : WTP-A

System Name: Beaver Water	ID#: 4100199	Month/Year: June-22	Disinfectio n <i>Giardia</i> Log 1.0
District			

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.95	97	92.15	11.7	6.72	31.3	Yes	76
2	0.94	97	91.18	12.1	8.23	51.4	Yes	70.75
3	1.03	97	99.91	12.3	7.80	44.0	Yes	74
4	0.88	97	85.36	12.9	6.50	25.7	Yes	70
5	0.6	97	58.2	12.2	6.77	29.7	Yes	74
6	0.79	97	76.63	11.9	6.03	24.2	Yes	72
7	0.9	97	87.3	11.5	8.18	52.4	Yes	73
8	0.8	97	77.6	12.3	8.02	46.4	Yes	72.4
9	0.73	97	70.81	12	6.55	28.3	Yes	75
10	0.63	97	61.11	12.5	7.30	34.5	Yes	72
11	0.99	97	96.03	12.1	6.37	27.3	Yes	76
12	0.82	97	79.54	12.6	6.46	25.6	Yes	72.9
13	1	97	97	12.3	7.00	33.3	Yes	73.2
14	1.4	97	135.8	11.4	6.19	28.0	Yes	70.9
15	0.9	97	87.3	11.6	7.61	42.5	Yes	76
16	0.86	97	83.42	11.8	7.78	44.3	Yes	72
17	0.79	97	76.63	11.3	7.95	48.3	Yes	75
18	0.74	97	71.78	11.5	6.42	28.0	Yes	73
19	0.8	97	77.6	11.9	8.21	50.9	Yes	76
20	0.78	97	75.66	11.7	6.57	29.2	Yes	72.6
21	1.15	97	111.55	14.3	8.33	47.4	Yes	73.3
22	0.95	97	92.15	13.1	6.72	27.7	Yes	73
23	0.7	97	67.9	13.2	8.07	44.1	Yes	71
24	0.82	97	79.54	13.6	8.65	53.8	Yes	69
25	0.68	97	65.96	12.9	6.25	22.9	Yes	73
26	0.78	97	75.66	16.7	8.65	43.7	Yes	69.5
27	1.08	97	104.76	14.1	8.14	44.5	Yes	77.4
28	0.7	97	67.9	14.3	8.02	40.2	Yes	68
29	0.97	97	94.09	13.5	8.02	43.7	Yes	67.8
30	0.72	97	69.84	13	6.43	24.4	Yes	65.5

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

wp.dmce@state.or.us 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350