

Conventional or Direct Filtration

System Name: Colton Water District		ID#: 41 00202		WTP: TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	No Flow	No Flow	No Flow	0.10	0.12	0.11	0.12
2	No Flow	No Flow	0.10	0.10	0.12	0.13	0.13
3	No Flow	No Flow	0.12	0.11	0.11	0.10	0.12
4	No Flow	No Flow	0.16	0.11	0.11	0.10	0.16
5	No Flow	No Flow	0.10	0.10	0.12	0.13	0.13
6	No Flow	No Flow	No Flow	0.03	0.04	No Flow	0.04
7	No Flow	No Flow	0.18	No Flow	0.23	0.05	0.23
8	No Flow	No Flow	No Flow	0.07	0.06	0.08	0.08
9	No Flow	No Flow	No Flow	0.04	0.04	0.03	0.04
10	No Flow	No Flow	0.03	0.04	0.05	0.04	0.05
11	No Flow	No Flow	No Flow	0.09	0.06	0.05	0.09
12	No Flow	No Flow	No Flow	0.11	0.14	0.11	0.14
13	No Flow	No Flow	0.11	0.16	0.16	0.12	0.16
14	No Flow	No Flow	No Flow	0.24	0.10	0.12	0.24
15	No Flow	No Flow	No Flow	No Flow	No Flow	0.05	0.05
16	No Flow	No Flow	No Flow	No Flow	No Flow	0.24	0.24
17	0.16	No Flow	No Flow	No Flow	0.02	0.01	0.02
18	No Flow	No Flow	No Flow	0.03	0.03	0.02	0.03
19	No Flow	No Flow	0.04	0.02	0.03	0.03	0.04
20	No Flow	No Flow	0.08	0.08	0.10	No Flow	0.10
21	0.07	No Flow	No Flow	0.04	0.05	0.04	0.05
22	No Flow	No Flow	0.14	0.06	0.07	0.07	0.14
23	0.06	No Flow	No Flow	0.14	0.09	0.07	0.14
24	0.06	0.05	No Flow	0.04	0.05	0.04	0.06
25	0.04	0.07	No Flow	0.06	0.05	0.04	0.07
26	No Flow	No Flow	0.08	0.04	0.04	0.04	0.08
27	0.03	No Flow	0.03	0.03	0.04	0.03	0.04
28	0.07	No Flow	No Flow	0.02	0.03	0.02	0.07
29	0.02	No Flow	No Flow	0.03	0.03	0.03	0.03
30	0.02	No Flow	No Flow	0.02	0.02	0.02	0.02
31	No Flow	No Flow	0.02	0.06	0.05	0.03	0.06

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes / ☐ No	CT's met everyday? (see back)	All Cl2 residual at entry point $\geq$ 0.2 mg/l?
All 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes / ☐ No	☒ Yes / ☐ No	☒ Yes / ☐ No
All turbidity readings < IFE2 triggers	☒ Yes / ☐ No		

Notes:	PRINTED NAME: <i>Steve Apostol</i>	
	SIGNATURE: <i>[Signature]</i>	DATE: <i>8/28/25</i>
	PHONE #: <i>(503) 829-2500</i>	CERT #: <i>325</i>

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

A

System Name:

Colton Water District

ID#: 41 00202

Month/Year:

August 2025

Disinfection *Giardia*

Log Inactive:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) 3	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.09	50	54.5	13.0	6.80	29.2	YES	220
2	1.06	50	53.0	13.0	6.80	29.1	YES	246
3	1.05	50	52.5	13.0	6.80	29.1	YES	231
4	1.00	50	50.0	13.0	7.00	31.1	YES	232
5	1.03	50	51.5	13.0	7.00	31.2	YES	237
6	1.07	50	53.5	13.0	7.00	31.4	YES	185
7	0.93	50	46.5	13.0	7.00	30.9	YES	180
8	0.97	50	48.5	13.0	6.80	28.8	YES	243
9	1.08	50	54.0	13.0	6.80	29.2	YES	180
10	1.05	50	52.5	13.0	6.80	29.1	YES	251
11	1.08	50	54.0	13.0	6.80	29.2	YES	253
12	1.06	50	53.0	14.0	6.80	27.2	YES	299
13	1.00	50	50.0	14.0	6.80	27.0	YES	310
14	1.01	50	50.5	14.0	6.80	27.1	YES	210
15	1.04	50	52.0	13.0	6.80	29.0	YES	216
16	0.97	50	48.5	14.0	6.80	26.9	YES	169
17	0.77	50	38.5	14.0	7.40	32.9	YES	204
18	0.85	50	42.5	14.0	7.00	28.6	YES	210
19	1.02	50	51.0	13.0	7.00	31.2	YES	241
20	1.04	50	52.0	14.0	6.80	27.2	YES	237
21	1.05	50	52.5	12.0	6.80	31.9	YES	233
22	1.06	50	53.0	13.0	6.80	29.1	YES	255
23	1.10	50	55.0	13.0	7.00	31.5	YES	256
24	1.12	50	56.0	13.0	6.80	29.3	YES	290
25	1.21	50	60.5	14.0	7.00	29.8	YES	200
26	1.14	50	57.0	13.0	7.00	31.6	YES	235
27	1.18	50	59.0	14.0	7.00	29.7	YES	207
28	1.19	50	59.5	14.0	7.00	29.8	YES	231
29	1.21	50	60.5	14.0	7.00	29.8	YES	216
30	1.11	50	55.5	13.0	6.80	29.3	YES	235
31	1.20	50	60.0	13.0	7.00	31.8	YES	200

3 If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

PAGE 2 of 2