

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Clackamas**
 Month/Year: **Sept. 2025**

System Name:		Colton Water District		ID#: 41		00202		WTP : TP - A	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]		
1	0.03	No Flow	No Flow	0.03	0.03	0.03	0.03		
2	0.05	No Flow	No Flow	0.09	0.05	0.04	0.09		
3	0.03	No Flow	No Flow	0.03	0.06	0.04	0.06		
4	No Flow	No Flow	0.04	0.07	0.06	0.05	0.07		
5	No Flow	No Flow	0.04	0.05	0.03	0.03	0.05		
6	No Flow	No Flow	0.02	0.04	No Flow	No Flow	0.04		
7	0.03	0.02	No Flow	No Flow	0.07	0.06	0.07		
8	No Flow	No Flow	No Flow	0.08	0.04	0.05	0.08		
9	No Flow	No Flow	No Flow	0.05	No Flow	No Flow	0.05		
10	No Flow	No Flow	0.03	No Flow	No Flow	0.04	0.04		
11	0.02	No Flow	No Flow	0.22	0.04	No Flow	0.22		
12	No Flow	No Flow	No Flow	0.06	0.05	No Flow	0.06		
13	No Flow	0.04	0.03	No Flow	0.04	0.03	0.04		
14	No Flow	No Flow	No Flow	No Flow	No Flow	No Flow	No Flow		
15	No Flow	No Flow	0.14	0.15	0.10	0.05	0.15		
16	0.04	No Flow	No Flow	0.08	0.10	No Flow	0.10		
17	No Flow	No Flow	0.12	0.06	No Flow	No Flow	0.12		
18	0.04	No Flow	No Flow	No Flow	0.04	No Flow	0.04		
19	No Flow	No Flow	0.03	0.05	No Flow	No Flow	0.05		
20	No Flow	0.04	0.03	No Flow	No Flow	0.03	0.04		
21	No Flow	No Flow	No Flow	No Flow	No Flow	No Flow	No Flow		
22	No Flow	No Flow	No Flow	0.04	0.08	0.05	0.08		
23	No Flow	No Flow	No Flow	0.03	0.03	0.06	0.06		
24	0.11	No Flow	No Flow	No Flow	No Flow	0.04	0.11		
25	No Flow	No Flow	No Flow	No Flow	No Flow	0.02	0.02		
26	0.02	No Flow	No Flow	0.07	0.09	No Flow	0.09		
27	No Flow	No Flow	No Flow	0.04	0.05	No Flow	0.05		
28	No Flow	0.05	0.04	No Flow	No Flow	0.06	0.06		
29	0.05	No Flow	No Flow	0.10	No Flow	No Flow	0.10		
30	0.02	No Flow	No Flow	No Flow	0.02	No Flow	0.02		
31									

Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?		Yes / No	CT's met everyday? (see back)		All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?		Yes / no	Yes / No		Yes / No
All turbidity readings < IFE2 triggers		Yes / No			

Notes:	PRINTED NAME: <i>Peter Dostent</i>	
	SIGNATURE: <i>Peter Dostent</i>	DATE: <i>Oct 2</i>
	PHONE #: <i>(503) 824-2500</i>	CERT #: <i>6574</i>

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name:	Colton Water District	ID#: 41	00202	Month/Year:	September/2025	WTP - :A	Disinfection Giardia	1
---------------------	------------------------------	----------------	--------------	--------------------	-----------------------	-----------------	-----------------------------	----------

Date / Time	Minimum Cl2 [ppm or mg/L]	Contact Time [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT formula	CT Met? 3 Yes / No	Peak Hourly [GPM]
1	1.21	50	60.5	13.0	7.00	31.9	YES	233
2	1.23	50	61.5	13.0	7.00	32.0	YES	219
3	1.19	50	59.5	14.0	7.00	29.8	YES	227
4	1.22	50	61.0	14.0	7.00	29.9	YES	212
5	1.19	50	59.5	14.0	7.00	29.8	YES	210
6	1.14	50	57.0	13.0	7.00	31.6	YES	133
7	1.17	50	58.5	13.0	7.00	31.7	YES	166
8	1.02	50	51.0	14.0	6.90	28.1	YES	164
9	1.45	50	72.5	14.0	7.10	31.8	YES	152
10	0.98	50	49.0	13.0	7.00	31.1	YES	168
11	0.86	50	43.0	13.0	7.00	30.6	YES	141
12	0.98	50	49.0	13.0	7.00	31.1	YES	221
13	1.01	50	50.5	13.0	7.00	31.2	YES	198
14	0.91	50	45.5	13.0	7.00	30.8	YES	127
15	0.91	50	45.5	13.0	7.00	30.8	YES	260
16	0.81	50	40.5	13.0	7.00	30.5	YES	160
17	0.84	50	42.0	13.0	7.00	30.6	YES	201
18	0.92	50	46.0	13.0	7.00	30.8	YES	142
19	0.84	50	42.0	13.0	7.00	30.6	YES	221
20	0.98	50	49.0	13.0	7.20	33.4	YES	201
21	0.98	50	49.0	14.0	7.00	29.1	YES	119
22	0.92	50	46.0	13.0	7.20	33.2	YES	119
23	0.98	50	49.0	13.0	7.20	33.4	YES	250
24	0.95	50	47.5	13.0	7.00	31.0	YES	165
25	0.93	50	46.5	13.0	7.00	30.9	YES	145
26	0.96	50	48.0	12.0	7.00	33.8	YES	172
27	0.99	50	49.5	11.0	7.20	38.7	YES	155
28	1.04	50	52.0	12.0	7.20	36.5	YES	150
29	0.98	50	49.0	13.0	7.20	33.4	YES	120
30	0.97	50	48.5	12.0	7.20	36.2	YES	229
31								

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350