

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Clackamas**
 Month/Year: **Nov-25**

System Name:	Colton		ID#: 41	00202	WTP : TP - A		
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	No Flow	No Flow	No Flow	No Flow	No Flow	No Flow	No Flow
2	No Flow	No Flow	No Flow	No Flow	0.10	0.09	0.10
3	0.10	0.23	0.17	0.09	No Flow	No Flow	0.23
4	No Flow	No Flow	No Flow	0.21	0.12	No Flow	0.21
5	No Flow	No Flow	No Flow	0.12	0.12	No Flow	0.12
6	No Flow	No Flow	0.12	0.13	No Flow	No Flow	0.13
7	No Flow	No Flow	No Flow	No Flow	0.14	0.14	0.14
8	No Flow	No Flow	No Flow	0.14	0.15	No Flow	0.15
9	No Flow	No Flow	No Flow	0.14	0.14	No Flow	0.14
10	No Flow	No Flow	0.14	0.14	No Flow	No Flow	0.14
11	No Flow	No Flow	0.17	0.15	No Flow	No Flow	0.17
12	No Flow	No Flow	0.15	No Flow	No Flow	No Flow	0.15
13	0.15	No Flow	No Flow	No Flow	0.17	No Flow	0.17
14	No Flow	No Flow	No Flow	0.18	No Flow	No Flow	0.18
15	No Flow	No Flow	No Flow	0.21	0.18	No Flow	0.21
16	No Flow	No Flow	No Flow	0.18	0.24	No Flow	0.24
17	No Flow	No Flow	No Flow	No Flow	No Flow	0.25	0.25
18	0.25	No Flow	No Flow	No Flow	No Flow	0.25	0.25
19	0.32	No Flow	No Flow	No Flow	0.24	0.24	0.32
20	No Flow	No Flow	No Flow	0.25	0.24	No Flow	0.25
21	No Flow	No Flow	No Flow	0.25	0.24	No Flow	0.25
22	No Flow	No Flow	No Flow	0.24	0.24	No Flow	0.24
23	No Flow	No Flow	No Flow	0.24	0.38	No Flow	0.38
24	No Flow	No Flow	No Flow	No Flow	0.27	0.26	0.27
25	No Flow	No Flow	No Flow	No Flow	0.26	0.33	0.33
26	No Flow	No Flow	No Flow	No Flow	0.27	0.27	0.27
27	No Flow	No Flow	No Flow	No Flow	0.26	0.26	0.26
28	0.29	No Flow	No Flow	No Flow	0.26	0.26	0.26
29	0.26	No Flow	No Flow	No Flow	0.26	0.26	0.26
30	No Flow	No Flow	No Flow	No Flow	0.26	0.27	0.27
31							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / No	<input checked="" type="radio"/> Yes / No	<input checked="" type="radio"/> Yes / No
All turbidity readings < IFE2 triggers	<input checked="" type="radio"/> Yes / No		
Notes:	PRINTED NAME: <i>Peterj Dostent</i>		
	SIGNATURE: <i>Peterj Dostent</i>		DATE: <i>12-4-2025</i>
	PHONE #: <i>(503) 824-2500</i>		CERT #: <i>6574</i>

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - : A

System Name:	Colton	ID#: 41	00202	Month/Year:	Nov-25	Disinfection	Giardia	1
--------------	--------	---------	-------	-------------	--------	--------------	---------	---

Date / Time	Minimum Cl2 Residual at 1st	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.17	50	58.5	10.0	7.20	42.2	YES	120
2	1.11	50	55.5	10.0	7.40	44.9	YES	250
3	1.17	50	58.5	9.0	7.20	45.0	YES	120
4	1.11	50	55.5	10.0	7.00	39.1	YES	250
5	1.09	50	54.5	11.0	7.00	36.5	YES	125
6	1.12	50	56.0	11.0	7.00	36.7	YES	132
7	1.02	50	51.0	10.0	7.00	38.7	YES	250
8	1.06	50	53.0	10.0	7.20	41.7	YES	165
9	0.95	50	47.5	10.0	7.00	38.4	YES	207
10	1.13	50	56.5	10.0	7.00	39.2	YES	155
11	1.14	50	57.0	10.0	7.00	39.2	YES	116
12	1.14	50	57.0	10.0	7.00	39.2	YES	114
13	1.19	50	59.5	10.0	7.20	42.3	YES	110
14	1.08	50	54.0	11.0	7.00	36.5	YES	250
15	1.11	50	55.5	11.0	7.20	39.2	YES	110
16	1.08	50	54.0	11.0	7.00	36.5	YES	91
17	1.31	50	65.5	11.0	7.20	40.1	YES	93
18	1.13	50	56.5	9.0	7.20	44.8	YES	250
19	1.23	50	61.5	8.0	7.00	45.2	YES	122
20	1.07	50	53.5	8.0	7.20	47.6	YES	260
21	1.27	50	63.5	7.0	7.40	55.9	YES	149
22	1.27	50	63.5	8.0	7.20	48.7	YES	193
23	1.27	50	63.5	8.0	7.20	48.7	YES	193
24	1.21	50	60.5	8.0	7.20	48.4	YES	108
25	1.29	50	64.5	8.0	7.20	48.8	YES	110
26	1.3	50	65.0	9.0	7.20	45.7	YES	102
27	1.54	50	77.0	9.0	7.00	43.8	YES	200
28	1.57	50	78.5	10.0	7.00	41.1	YES	198
29	1.46	50	73.0	9.0	7.00	43.4	YES	176
30	1.57	50	78.5	9.0	7.20	47.1	YES	92
31		50						

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:
dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350