

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clackamas  
 Month/Year: Dec-25

Conventional or Direct Filtration

| System Name: | Colton      |            |            | ID#: 41    | 00202      | WTP : TP - A |                                    |
|--------------|-------------|------------|------------|------------|------------|--------------|------------------------------------|
| Day          | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU]   | Highest Reading of the Day 1 [NTU] |
| 1            | No Flow     | No Flow    | No Flow    | 0.27       | 0.27       | No Flow      | 0.27                               |
| 2            | No Flow     | No Flow    | No Flow    | 0.27       | 0.27       | No Flow      | 0.27                               |
| 3            | No Flow     | No Flow    | No Flow    | 0.27       | 0.27       | No Flow      | 0.27                               |
| 4            | No Flow     | No Flow    | 0.27       | 0.27       | No Flow    | No Flow      | 0.27                               |
| 5            | No Flow     | 0.27       | No Flow    | No Flow    | No Flow    | No Flow      | 0.27                               |
| 6            | 0.29        | No Flow    | No Flow    | 0.29       | 0.32       | 0.31         | 0.32                               |
| 7            | 0.31        | No Flow      | 0.31                               |
| 8            | No Flow     | No Flow    | No Flow    | No Flow    | No Flow    | No Flow      | No Flow                            |
| 9            | No Flow     | No Flow    | No Flow    | No Flow    | No Flow    | No Flow      | No Flow                            |
| 10           | No Flow     | No Flow    | No Flow    | No Flow    | 0.89       | 0.65         | 0.89                               |
| 11           | 0.75        | 0.64       | No Flow    | 0.80       | 0.62       | 0.62         | 0.80                               |
| 12           | No Flow     | No Flow    | No Flow    | 0.64       | 0.64       | 0.64         | 0.64                               |
| 13           | No Flow     | 0.64       | 0.64       | 0.69       | 0.66       | 0.66         | 0.66                               |
| 14           | 0.66        | 0.66       | 0.66       | 0.66       | 0.66       | 0.66         | 0.66                               |
| 15           | 0.66        | 0.66       | 0.68       | 0.66       | 0.66       | 0.66         | 0.68                               |
| 16           | No Flow     | No Flow    | No Flow    | No Flow    | 0.66       | 0.67         | 0.67                               |
| 17           | 0.67        | No Flow    | No Flow    | No Flow    | 0.67       | 0.67         | 0.67                               |
| 18           | 0.67        | 0.67       | No Flow    | No Flow    | No Flow    | No Flow      | 0.67                               |
| 19           | No Flow     | No Flow    | No Flow    | No Flow    | No Flow    | No Flow      | No Flow                            |
| 20           | No Flow     | No Flow    | No Flow    | No Flow    | No Flow    | No Flow      | No Flow                            |
| 21           | No Flow     | No Flow    | No Flow    | No Flow    | 0.78       | 0.78         | 0.78                               |
| 22           | 0.78        | 0.77       | No Flow    | 0.83       | 0.83       | 0.83         | 0.83                               |
| 23           | No Flow     | No Flow    | No Flow    | 0.83       | 0.85       | 0.84         | 0.85                               |
| 24           | 0.84        | 0.84       | 0.84       | 0.84       | 0.87       | No Flow      | 0.87                               |
| 25           | No Flow     | No Flow    | No Flow    | No Flow    | No Flow    | No Flow      | No Flow                            |
| 26           | No Flow     | No Flow    | No Flow    | 0.87       | 0.86       | No Flow      | 0.87                               |
| 27           | No Flow     | 0.86       | 0.86       | 0.86       | 0.87       | 0.87         | 0.87                               |
| 28           | No Flow     | No Flow    | No Flow    | No Flow    | 0.87       | 0.87         | 0.87                               |
| 29           | No Flow     | No Flow    | No Flow    | 0.88       | 0.87       | 0.87         | 0.88                               |
| 30           | No Flow     | No Flow    | No Flow    | 0.87       | 0.87       | No Flow      | 0.87                               |
| 31           | No Flow     | No Flow    | No Flow    | 0.88       | 0.88       | 0.87         | 0.88                               |

| Conventional or Direct Filtration   | Monthly Summary (Answer Yes or No)  |   |
|---|---|---|
| 95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No   | CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No | All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No |
| All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No  |   |   |
| All turbidity readings < IFE2 triggers <input checked="" type="radio"/> Yes <input type="radio"/> No  |   |   |
| Notes: 12-10-25 effluent turbidity analyzer sample vial dirty. Turbidty results from 12-10-25 on through end of month are not accurate. They are 0.5 to 0.6 ntu high approximately. Jackson Creek was flooding from 12-19-25 to 12-21-25. | PRINTED NAME: Peter Postcard  |   |
|   | SIGNATURE: <i>Peter Postcard</i>  | DATE: 1/8/26  |
|   | PHONE #: (507) 824-2500   | CERT #: 6579  |

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

**OHA - Drinking Water Program - Surface Water Quality Data Form**

WTP - :

A

|                            |                |       |                           |                             |   |
|----------------------------|----------------|-------|---------------------------|-----------------------------|---|
| System Name: <b>Colton</b> | ID#: <b>41</b> | 00202 | Month/Year: <b>Dec-25</b> | Disinfection <i>Giardia</i> | 1 |
|----------------------------|----------------|-------|---------------------------|-----------------------------|---|

| Date / Time | Minimum Cl2 Residual at 1st | Contact Time (T) | Actual CT    | Temp  | pH   | Required CT | CT Met? 3 | Peak Hourly Demand Flow |
|-------------|-----------------------------|------------------|--------------|-------|------|-------------|-----------|-------------------------|
|             | [ppm or mg/L]               | [minutes]        | <b>C X T</b> | [° C] |      | formula     | Yes / No  | [GPM]                   |
| 1           | 1.48                        | 50               | 74.0         | 9.0   | 7.40 | 50.1        | YES       | 155                     |
| 2           | 1.47                        | 50               | 73.5         | 8.0   | 7.00 | 46.4        | YES       | 116                     |
| 3           | 1.4                         | 50               | 70.0         | 9.0   | 7.20 | 46.2        | YES       | 192                     |
| 4           | 1.41                        | 50               | 70.5         | 8.0   | 7.20 | 49.5        | YES       | 116                     |
| 5           | 1.49                        | 50               | 74.5         | 10.0  | 7.20 | 43.7        | YES       | 130                     |
| 6           | 1.41                        | 50               | 70.5         | 10.0  | 7.00 | 40.4        | YES       | 235                     |
| 7           | 1.55                        | 50               | 77.5         | 10.0  | 7.00 | 41.0        | YES       | 175                     |
| 8           | 1.53                        | 50               | 76.5         | 10.0  | 6.80 | 38.2        | YES       | 43                      |
| 9           | 1.57                        | 50               | 78.5         | 10.5  | 7.00 | 39.8        | YES       | 42                      |
| 10          | 2.01                        | 50               | 100.5        | 11.0  | 7.00 | 40.5        | YES       | 130                     |
| 11          | 1.77                        | 50               | 88.5         | 11.0  | 6.80 | 36.8        | YES       | 250                     |
| 12          | 1.96                        | 50               | 98.0         | 11.0  | 7.00 | 40.2        | YES       | 160                     |
| 13          | 2.03                        | 50               | 101.5        | 10.0  | 7.00 | 43.3        | YES       | 250                     |
| 14          | 2.17                        | 50               | 108.5        | 9.0   | 7.00 | 47.0        | YES       | 200                     |
| 15          | 2.12                        | 50               | 106.0        | 10.0  | 7.00 | 43.8        | YES       | 180                     |
| 16          | 1.94                        | 50               | 97.0         | 11.0  | 7.00 | 40.2        | YES       | 134                     |
| 17          | 1.74                        | 50               | 87.0         | 11.0  | 7.00 | 39.3        | YES       | 117                     |
| 18          | 3.9                         | 50               | 195.0        | 9.0   | 7.00 | 57.3        | YES       | 149                     |
| 19          | 1.8                         | 50               | 90.0         | 10.0  | 7.20 | 45.3        | YES       | 22                      |
| 20          | 1.79                        | 50               | 89.5         | 10.0  | 7.20 | 45.2        | YES       | 44                      |
| 21          | 1.79                        | 50               | 89.5         | 10.0  | 7.20 | 45.2        | YES       | 54                      |
| 22          | 1.7                         | 50               | 85.0         | 9.0   | 7.00 | 44.6        | YES       | 180                     |
| 23          | 1.56                        | 50               | 78.0         | 9.0   | 7.00 | 43.9        | YES       | 189                     |
| 24          | 1.44                        | 50               | 72.0         | 9.0   | 7.20 | 46.4        | YES       | 180                     |
| 25          | 1.44                        | 50               | 72.0         | 9.0   | 7.20 | 46.4        | YES       | 35                      |
| 26          | 1.2                         | 50               | 60.0         | 9.0   | 7.20 | 45.2        | YES       | 170                     |
| 27          | 1.2                         | 50               | 60.0         | 8.0   | 7.20 | 48.3        | YES       | 236                     |
| 28          | 1.29                        | 50               | 64.5         | 8.0   | 7.20 | 48.8        | YES       | 109                     |
| 29          | 1.35                        | 50               | 67.5         | 8.0   | 7.20 | 49.1        | YES       | 96                      |
| 30          | 1.27                        | 50               | 63.5         | 8.0   | 7.20 | 48.7        | YES       | 135                     |
| 31          | 1.31                        | 50               | 65.5         | 8.0   | 7.20 | 48.9        | YES       | 95                      |

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

**Return by 10th of following month by email, fax, or mail to:**

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350