

OHA - Drinking Water Services -Turbidity Monitoring Report Form

County: Clackamas

Conventional or Direct Filtration

Month/Year: Mar-26

System Name:	Colton	ID#: 41	00202	WTP : TP - A			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day 1 [NTU]
1	0.06	No Flow	No Flow	No Flow	0.06	0.07	0.07
2	0.07	No Flow	No Flow	No Flow	0.10	0.07	0.10
3	0.07	0.07	No Flow	No Flow	No Flow	0.07	0.07
4	0.07	0.07	No Flow	No Flow	0.09	0.07	0.09
5	0.07	No Flow	No Flow	No Flow	No Flow	0.07	0.07
6	0.07	No Flow	No Flow	No Flow	0.07	0.07	0.07
7	0.07	No Flow	No Flow	No Flow	0.07	0.07	0.07
8	0.07	No Flow	No Flow	No Flow	0.07	0.07	0.07
9	0.07	No Flow	No Flow	No Flow	0.07	0.07	0.07
10	0.07	No Flow	No Flow	No Flow	0.07	0.07	0.07
11	0.07	No Flow	No Flow	No Flow	0.07	0.07	0.07
12	0.07	No Flow	No Flow	No Flow	No Flow	No Flow	No Flow
13	No Flow	No Flow	No Flow	No Flow	No Flow	No Flow	No Flow
14	No Flow	No Flow	No Flow	No Flow	No Flow	No Flow	No Flow
15	No Flow	No Flow	No Flow	No Flow	0.09	0.09	0.09
16	0.09	0.08	0.09	0.09	0.09	0.08	0.09
17	0.08	0.08	0.08	0.08	No Flow	No Flow	0.08
18	No Flow	0.08	0.08	No Flow	0.09	0.09	0.09
19	No Flow	No Flow	No Flow	0.09	0.09	0.09	0.09
20	No Flow	No Flow	No Flow	0.09	0.09	0.09	0.09
21	No Flow	No Flow	No Flow	No Flow	0.09	0.09	0.09
22	0.09	No Flow	No Flow	No Flow	0.09	0.09	0.09
23	0.09	No Flow	No Flow	No Flow	0.09	0.09	0.09
24	No Flow	No Flow	No Flow	No Flow	0.09	0.09	0.09
25	0.09	No Flow	No Flow	No Flow	0.02	0.02	0.02
26	No Flow	No Flow	No Flow	No Flow	0.01	0.01	0.01
27	No Flow	No Flow	No Flow	0.01	0.01	0.01	0.01
28	No Flow	No Flow	No Flow	0.01	0.01	No Flow	0.01
29	No Flow	No Flow	0.02	0.01	0.01	No Flow	0.02
30	No Flow	No Flow	0.01	0.02	No Flow	No Flow	0.02
31	No Flow	0.02	0.02	No Flow	No Flow	No Flow	0.02

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE2 triggers	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: <i>Roger Postel</i>		DATE: <i>4/7/26</i>
	SIGNATURE: <i>Roger Postel</i>		CERT #: <i>6574</i>
	PHONE #: <i>(503) 824-2500</i>		

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. 2 IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

**OHA - Drinking Water Program - Surface Water Quality Data Form**

<b>System Name:</b>	<b>Colton</b>	<b>ID#:</b> 41	<b>00202</b>	<b>Month/Year:</b>	<b>March-26</b>	<b>WTP - :</b>	<b>A</b>
						<b>Disinfection</b> <i>Giardia</i>	<b>1</b>

Date / Time	Minimum Cl2 Residual at 1st	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? 3	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	1.29	50	64.5	8.0	7.40	52.4	YES	77
2	1.21	50	60.5	9.0	7.20	45.2	YES	144
3	1.26	50	63.0	8.0	7.40	52.2	YES	115
4	1.23	50	61.5	9.0	7.20	45.3	YES	102
5	1.24	50	62.0	8.0	7.20	48.5	YES	127
6	1.24	50	62.0	8.0	7.20	48.5	YES	101
7	1.18	50	59.0	9.0	7.40	48.4	YES	112
8	1.24	50	62.0	9.0	7.20	45.4	YES	136
9	1.21	50	60.5	8.0	7.20	48.4	YES	114
10	1.24	50	62.0	8.0	7.40	52.1	YES	132
11	1.24	50	62.0	8.0	7.20	48.5	YES	111
12	1.21	50	60.5	9.0	7.20	45.2	YES	143
13	1.21	50	60.5	9.0	7.20	45.2	YES	36
14	1.24	50	62.0	9.0	7.20	45.4	YES	25
15	1.24	50	62.0	9.0	7.40	48.7	YES	150
16	1.23	50	61.5	9.0	7.20	45.3	YES	167
17	1.23	50	61.5	9.0	7.20	45.3	YES	180
18	1.21	50	60.5	9.0	7.20	45.2	YES	148
19	1.21	50	60.5	10.0	7.20	42.4	YES	114
20	1.24	50	62.0	10.0	7.40	45.6	YES	91
21	1.24	50	62.0	10.0	7.40	45.6	YES	81
22	1.31	50	65.5	8.0	7.40	52.5	YES	107
23	1.29	50	64.5	8.0	7.40	52.4	YES	117
24	1.29	50	64.5	9.0	7.40	49.0	YES	115
25	1.34	50	67.0	9.0	7.40	49.3	YES	111
26	1.25	50	62.5	8.0	7.40	52.2	YES	98
27	1.23	50	61.5	9.0	7.40	48.7	YES	113
28	1.18	50	59.0	9.0	7.40	48.4	YES	93
29	1.02	50	51.0	9.0	7.40	47.5	YES	99
30	1.25	50	62.5	9.0	7.40	48.8	YES	133
31	1.36	50	68.0	8.0	7.60	56.8	YES	185

3 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

**Return by 10th of following month by email, fax, or mail to:**

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350