


OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Coos
Conventional or Direct Filtration

System Name: COOS BAY-NORTH BEND WTR BRD ID# : OR4100205 WTP-: WTP-A Month/Year: Jun-25

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	shutdown	shutdown	0.03	0.03	0.03	shutdown	0.03
2	shutdown	shutdown	0.04	0.03	shutdown	shutdown	0.04
3	shutdown	shutdown	0.03	0.03	0.03	shutdown	0.03
4	shutdown	shutdown	0.03	0.03	0.03	shutdown	0.03
5	shutdown	shutdown	0.04	0.03	0.03	shutdown	0.04
6	shutdown	shutdown	0.04	0.03	0.03	shutdown	0.04
7	shutdown	shutdown	0.04	0.03	shutdown	shutdown	0.04
8	shutdown	shutdown	0.04	0.03	0.04	shutdown	0.04
9	shutdown	shutdown	0.04	0.03	shutdown	shutdown	0.04
10	shutdown	shutdown	0.04	0.03	shutdown	shutdown	0.04
11	shutdown	shutdown	0.04	0.03	0.03	shutdown	0.04
12	shutdown	shutdown	0.03	0.03	0.03	shutdown	0.03
13	shutdown	shutdown	0.04	0.03	0.03	shutdown	0.04
14	shutdown	shutdown	0.04	0.03	0.03	shutdown	0.04
15	shutdown	shutdown	0.03	0.03	0.03	shutdown	0.03
16	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
17	shutdown	shutdown	0.03	0.03	0.03	shutdown	0.03
18	shutdown	shutdown	0.03	0.03	0.03	shutdown	0.03
19	shutdown	shutdown	shutdown	0.03	0.03	shutdown	0.03
20	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
21	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
22	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
23	shutdown	shutdown	0.04	0.03	shutdown	shutdown	0.04
24	shutdown	shutdown	0.04	0.03	shutdown	shutdown	0.04
25	shutdown	shutdown	0.03	0.03	0.04	0.03	0.04
26	shutdown	shutdown	0.03	0.03	0.03	shutdown	0.03
27	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
28	shutdown	shutdown	0.04	0.03	0.03	shutdown	0.04
29	shutdown	shutdown	0.03	0.03	0.03	shutdown	0.03
30	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU?	☒ Yes / No	CT's met everyday? (see back)	All Cl2 residuals at entry point $\geq$ 0.2 mg/l?
All the 4-hour turbidity readings $\leq$ 1 NTU?	☒ Yes / No	☒ Yes / No	
All turbidity readings < IFE ² triggers?	☒ Yes / No ²		☒ Yes / No
Notes:		PRINTED NAME: Jeff Miller, Water Treatment Supervisor	
		SIGNATURE: 	DATE: July 1, 2025
		PHONE #: (541) 267-3128 ext.250	CERT#: T-6686 FE

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through

"8 PM" may not correspond to continuous readings' maximum.

² IFE + Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form - Giardia Inactivation

System Name: COOS BAY-NORTH BEND WTR BRD ID#: OR4100205 WTP: WTP-A Month/Year: Jun-25

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes/No	[GPM]
1/ 1126	3.33	561	1869	16.9	8.7	225.3	Yes	4514
2/ 1043	3.27	597	1952	17.1	8.0	222.7	Yes	4236
3/ 1110	3.25	493	1601	17.4	8.8	218.8	Yes	5278
4/ 2032	3.32	472	1566	18.0	8.5	211.0	Yes	5278
5/ 1035	3.30	552	1823	18.2	8.6	208.4	Yes	4583
6/ 1130	3.29	572	1883	17.9	8.6	212.3	Yes	4444
7/ 1142	3.25	584	1898	18.3	8.6	207.1	Yes	4375
8/ 1219	3.19	558	1780	18.1	8.4	209.7	Yes	4583
9/ 801	3.13	587	1838	18.5	8.0	204.5	Yes	4306
10/ 1930	3.11	520	1617	18.2	8.4	208.4	Yes	5069
11/ 1910	3.15	490	1544	18.5	8.1	204.5	Yes	4792
12/ 1107	3.12	514	1602	18.6	8.3	203.2	Yes	4861
13/ 911	3.12	488	1524	18.3	8.5	207.1	Yes	5347
14/ 1123	3.09	544	1682	18.3	8.5	207.1	Yes	4653
15/ 1836	3.10	553	1713	18.2	8.2	208.4	Yes	4583
16/ 946	3.06	566	1733	18.2	8.4	208.4	Yes	4514
17/ 1820	3.06	484	1481	18.4	8.6	205.8	Yes	5347
18/ 1914	3.11	505	1572	18.5	8.6	204.5	Yes	4792
19/ 1935	3.06	600	1836	18.9	8.5	199.3	Yes	4236
20/ 1942	3.06	602	1841	18.9	8.7	199.3	Yes	4306
21/ 2020	3.12	590	1842	18.7	8.5	201.9	Yes	4306
22/ 1144	3.17	595	1886	18.4	8.1	205.8	Yes	4375
23/ 1047	3.15	613	1930	18.4	8.2	205.8	Yes	4167
24/ 828	3.05	505	1539	18.5	8.0	204.5	Yes	5000
25/ 1830	3.12	448	1398	18.1	8.0	209.7	Yes	5139
26/ 1104	3.07	555	1703	18.2	8.3	208.4	Yes	4653
27/ 1946	3.13	567	1773	18.7	8.3	201.9	Yes	4444
28/ 1911	3.20	506	1619	18.8	8.3	200.6	Yes	4861
29/ 1721	3.23	534	1725	18.6	8.1	203.2	Yes	4792
30/ 1825	3.22	537	1728	19.8	8.3	187.6	Yes	4792

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.Oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct..pdf