

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Coos
Conventional or Direct Filtration

System Name: COOS BAY-NORTH BEND WTR BRD ID# : OR4100205 WTP-: WTP-A Month/Year: Nov-25

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	shutdown	shutdown	0.03	0.04	shutdown	shutdown	0.04
2	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
3	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
4	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
5	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
6	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
7	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
8	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
9	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
10	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
11	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
12	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
13	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
14	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
15	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
16	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
17	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
18	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
19	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
20	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
21	shutdown	shutdown	0.03	0.04	0.04	shutdown	0.04
22	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
23	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
24	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
25	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
26	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
27	shutdown	shutdown	0.03	0.04	shutdown	shutdown	0.04
28	shutdown	shutdown	0.03	0.04	shutdown	shutdown	0.04
29	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
30	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03

Conventional or Direct Filtration 95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? (Yes/ No) All the 4-hour turbidity readings $\leq$ 1 NTU? (Yes/ No) All turbidity readings < IFE ² triggers? (Yes/ No²)		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) (Yes/ No) All Cl2 residuals at entry point $\geq$ 0.2 mg/l? (Yes/ No)	
Notes: 		PRINTED NAME: Jeff Miller, Water Treatment Supervisor	
		SIGNATURE: 	DATE: 12-2-25
		PHONE #: (541) 267-3128 ext.250	CERT#: T-6686 FE

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE + Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form - Giardia Inactivation

System Name: COOS BAY-NORTH BEND WTR BRD ID#: OR4100205 WTP--: WTP-A Month/Year: Nov-25

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes/No	[GPM]
1/ 1201	3.29	955	3143	16.5	8.5	230.5	Yes	2722
2/ 1441	3.27	827	2705	15.4	8.0	244.8	Yes	3187
3/ 1348	3.25	1019	3311	15.0	8.0	250.0	Yes	2569
4/ 1200	3.24	1057	3424	15.3	8.1	246.1	Yes	2500
5/ 1832	3.20	985	3153	15.5	8.6	243.5	Yes	2639
6/ 1640	3.21	848	2722	15.6	8.6	242.2	Yes	3056
7/ 1408	3.19	928	2959	15.8	8.5	239.6	Yes	2778
8/ 1157	3.18	916	2912	15.6	8.5	242.2	Yes	2847
9/ 1509	3.19	931	2969	14.9	8.0	251.2	Yes	2847
10/ 1648	3.17	1148	3639	17.6	8.0	216.2	Yes	2292
11/ 1143	3.13	991	3101	14.7	7.7	253.5	Yes	2639
12/ 1325	3.13	970	3036	14.4	8.2	256.9	Yes	2708
13/ 1420	3.13	755	2362	15.0	8.4	250.0	Yes	3472
14/ 1430	3.14	740	2325	14.6	8.5	254.6	Yes	3472
15/ 1818	3.15	916	2885	14.8	8.2	252.3	Yes	2847
16/ 1534	3.13	925	2895	14.6	8.1	254.6	Yes	2778
17/ 1156	3.09	878	2713	14.1	8.4	260.4	Yes	2986
18/ 1458	3.09	848	2620	14.4	8.1	256.9	Yes	3056
19/ 642	3.45	1085	3743	13.7	8.6	265.0	Yes	2431
20/ 1447	3.00	835	2505	14.1	8.6	260.4	Yes	3194
21/ 1512	3.13	420	1315	13.1	8.5	271.9	Yes	6146
22/ 1930	3.11	686	2135	13.0	8.3	273.0	Yes	3889
23/ 1131	3.12	692	2159	12.6	8.3	277.6	Yes	3750
24/ 1434	3.13	760	2380	12.5	8.1	278.8	Yes	3472
25/ 2048	3.12	814	2539	12.2	8.0	282.2	Yes	3264
26/ 1428	3.12	585	1826	12.4	8.5	279.9	Yes	4514
27/ 1400	3.13	661	2069	12.7	8.1	276.5	Yes	3819
28/ 1544	3.16	500	1579	13.0	8.7	273.0	Yes	5278
29/ 1416	3.14	670	2104	14.1	8.5	260.4	Yes	3958
30/ 2034	3.14	676	2123	12.2	8.6	282.2	Yes	3889

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.Oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct..pdf