


OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Coos
Conventional or Direct Filtration

System Name: COOS BAY-NORTH BEND WTR BRD ID# : OR4100205 WTP-: WTP-A Month/Year: Dec-25

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
2	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
3	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
4	shutdown	shutdown	0.03	0.04	shutdown	shutdown	0.04
5	shutdown	shutdown	0.03	0.04	shutdown	shutdown	0.04
6	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
7	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
8	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
9	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
10	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
11	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
12	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
13	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
14	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
15	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
16	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
17	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
18	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
19	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
20	shutdown	shutdown	0.03	0.04	shutdown	shutdown	0.04
21	shutdown	shutdown	0.03	0.06	shutdown	shutdown	0.06
22	shutdown	shutdown	0.03	0.04	shutdown	shutdown	0.04
23	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
24	shutdown	shutdown	0.03	0.03	0.05	shutdown	0.05
25	shutdown	shutdown	0.04	0.03	shutdown	shutdown	0.04
26	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
27	shutdown	shutdown	0.04	0.03	shutdown	shutdown	0.04
28	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
29	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
30	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
31	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03

Conventional or Direct Filtration 95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? <u>Yes</u> / No All the 4-hour turbidity readings $\leq$ 1 NTU? <u>Yes</u> / No All turbidity readings < IFE ² triggers? <u>Yes</u> / No²		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <u>Yes</u> / No All Cl2 residuals at entry point $\geq$ 0.2 mg/l? <u>Yes</u> / No	
Notes: 		PRINTED NAME: Jeff Miller, Water Treatment Supervisor	
		SIGNATURE: 	
		DATE: 1-5-2026	
		PHONE #: (541) 267-3128 ext.250	CERT#: T-6686 FE

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through

"8 PM" may not correspond to continuous readings' maximum.

² IFE + Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form - Giardia Inactivation

System Name: COOS BAY-NORTH BEND WTR BRD ID#: OR4100205 WTP:-WTP-A Month/Year: Dec-25

Required Log
Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes/No	[GPM]
1/ 1152	3.13	640	2005	11.7	8.0	288.0	Yes	4028
2/ 1626	3.17	676	2144	13.0	8.0	273.0	Yes	3889
3/ 1956	3.14	764	2398	12.4	8.0	279.9	Yes	3472
4/ 1521	3.11	740	2302	12.0	8.6	284.5	Yes	3542
5/ 808	3.11	636	1979	13.9	8.5	262.7	Yes	4167
6/ 1326	3.11	651	2026	14.3	8.6	258.1	Yes	3958
7/ 1535	3.16	679	2147	12.9	8.9	274.2	Yes	3819
8/ 1903	3.16	717	2265	12.7	8.9	276.5	Yes	3611
9/ 1021	3.14	776	2437	13.4	8.9	268.4	Yes	3403
10/ 1504	3.14	681	2140	13.7	8.8	265.0	Yes	3889
11/ 1838	3.17	658	2087	14.1	8.5	260.4	Yes	4028
12/ 1027	3.17	555	1760	13.3	8.4	269.6	Yes	4583
13/ 1334	3.17	598	1896	13.0	8.9	273.0	Yes	4375
14/ 1132	3.15	722	2276	13.2	8.4	270.7	Yes	3611
15/ 1200	3.14	793	2491	14.0	8.6	261.5	Yes	3264
16/ 1354	3.12	764	2384	13.6	8.4	266.1	Yes	3472
17/ 918	3.10	788	2443	14.5	8.4	255.8	Yes	3403
18/ 1426	3.10	586	1816	13.9	8.5	262.7	Yes	4444
19/ 1457	3.10	607	1881	14.3	8.7	258.1	Yes	4167
20/ 1118	3.10	658	2039	13.9	8.5	262.7	Yes	3958
21/ 1551	3.18	657	2090	13.1	8.7	271.9	Yes	3889
22/ 1538	3.22	742	2388	12.9	8.5	274.2	Yes	3472
23/ 2048	3.25	663	2156	12.3	8.3	281.1	Yes	3958
24/ 1258	3.25	584	1898	12.1	8.5	283.4	Yes	4375
25/ 1717	3.22	752	2422	12.6	8.5	277.6	Yes	3542
26/ 1419	3.22	642	2067	11.8	8.1	286.7	Yes	4097
27/ 1606	3.19	666	2124	11.7	8.1	288.0	Yes	3889
28/ 1330	3.16	673	2127	11.2	8.2	293.7	Yes	3819
29/ 1258	3.19	643	2051	10.8	8.2	298.3	Yes	3958
30/ 1922	3.15	595	1875	11.0	8.0	296.0	Yes	4514
31/ 1411	3.15	548	1726	10.6	7.8	300.6	Yes	4514

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.Oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct..pdf