

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Coos
Conventional or Direct Filtration**

System Name: COOS BAY-NORTH BEND WTR BRD ID# : OR4100205 WTP-: WTP-A Month/Year: Feb-26

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	shutdown	shutdown	0.02	0.02	shutdown	shutdown	0.02
2	shutdown	shutdown	0.02	0.02	shutdown	shutdown	0.02
3	shutdown	shutdown	0.02	0.02	shutdown	shutdown	0.02
4	shutdown	shutdown	0.02	0.02	shutdown	shutdown	0.02
5	shutdown	shutdown	0.02	0.02	shutdown	shutdown	0.02
6	shutdown	shutdown	0.02	0.02	shutdown	shutdown	0.02
7	shutdown	shutdown	0.02	0.02	shutdown	shutdown	0.02
8	shutdown	shutdown	0.02	0.02	shutdown	shutdown	0.02
9	shutdown	shutdown	0.02	0.02	shutdown	shutdown	0.02
10	shutdown	shutdown	0.03	0.02	shutdown	shutdown	0.03
11	shutdown	shutdown	0.02	0.02	shutdown	shutdown	0.02
12	shutdown	shutdown	0.02	0.02	shutdown	shutdown	0.02
13	shutdown	shutdown	0.02	0.02	shutdown	shutdown	0.02
14	shutdown	shutdown	0.03	0.03	0.03	shutdown	0.03
15	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
16	shutdown	shutdown	0.02	0.02	shutdown	shutdown	0.02
17	shutdown	shutdown	0.02	0.02	shutdown	shutdown	0.02
18	shutdown	shutdown	0.03	0.02	shutdown	shutdown	0.03
19	shutdown	shutdown	shutdown	0.02	shutdown	shutdown	0.02
20	shutdown	shutdown	0.02	0.02	shutdown	shutdown	0.02
21	shutdown	shutdown	0.02	0.03	0.03	shutdown	0.03
22	shutdown	shutdown	0.03	0.03	shutdown	shutdown	0.03
23	shutdown	shutdown	0.03	0.02	shutdown	shutdown	0.03
24	shutdown	shutdown	0.02	0.03	shutdown	shutdown	0.03
25	shutdown	shutdown	0.03	shutdown	shutdown	shutdown	0.03
26	shutdown	shutdown	0.02	0.03	shutdown	shutdown	0.03
27	shutdown	shutdown	0.02	0.03	shutdown	shutdown	0.03
28	shutdown	shutdown	0.03	0.02	shutdown	shutdown	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All the 4-hour turbidity readings \leq 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		All Cl2 residuals at entry point \geq 0.2 mg/l?
All turbidity readings $<$ IFE ² triggers?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: Jeff Miller, Water Treatment Supervisor		
	SIGNATURE: 		DATE: 3-2-2026
	PHONE #: (541) 267-3128 ext. 250		CERT#: T-6686 FE

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE + Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form - Giardia Inactivation

System Name: COOS BAY-NORTH BEND WTR BRD ID#: OR4100205 WTP:-WTP-A Month/Year: Feb-26 Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[° C]		Use tables	Yes/No	[GPM]
1/ 1433	3.21	695	2230	9.9	8.3	308.7	Yes	3750
2/ 1329	3.17	784	2487	9.8	8.9	309.9	Yes	3403
3/ 1553	3.20	643	2057	9.5	8.3	313.5	Yes	4028
4/ 722	3.16	730	2306	9.7	8.2	311.1	Yes	3611
5/ 1151	3.21	558	1790	10.0	7.9	310.0	Yes	4722
6/ 1438	3.22	637	2052	10.4	8.2	302.9	Yes	4028
7/ 1011	3.16	757	2392	10.9	8.7	297.2	Yes	3472
8/ 1257	3.18	693	2205	11.7	8.8	288.0	Yes	3750
9/ 1514	3.16	714	2256	11.0	8.1	296.0	Yes	3681
10/ 1657	3.16	750	2369	11.5	7.9	290.3	Yes	3472
11/ 1204	3.11	755	2347	10.3	8.0	304.1	Yes	3542
12/ 1446	3.11	632	1966	10.7	8.2	299.5	Yes	4028
13/ 1544	3.08	681	2097	10.9	8.2	297.2	Yes	3819
14/ 1130	3.06	695	2125	11.3	8.4	292.6	Yes	3750
15/ 1201	3.15	661	2083	10.4	8.1	302.9	Yes	3958
16/ 1426	3.19	651	2075	10.5	8.7	301.8	Yes	4097
17/ 943	3.18	789	2510	10.6	8.9	300.6	Yes	3333
18/ 1231	3.26	814	2654	10.3	8.9	304.1	Yes	3264
19/ 1546	3.35	742	2485	10.2	8.3	305.2	Yes	3542
20/ 1828	3.14	740	2324	10.3	8.5	304.1	Yes	3611
21/ 1031	3.23	721	2329	9.7	8.1	311.1	Yes	3611
22/ 1432	3.29	724	2382	11.5	8.9	290.3	Yes	3681
23/ 1848	3.33	634	2112	10.7	8.4	299.5	Yes	4236
24/ 1134	3.30	519	1714	11.1	8.4	294.9	Yes	4931
25/ 1457	3.27	716	2342	11.0	8.5	296.0	Yes	3750
26/ 1900	3.25	679	2207	10.7	7.9	299.5	Yes	3819
27/ 1241	3.22	598	1926	11.0	7.9	296.0	Yes	4375
28/ 1247	3.20	610	1951	10.6	8.3	300.6	Yes	4236

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.