

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: COQUILLE, CITY OF ID:OR4100213 WTP:-WTP-A Month/Year: Apr-21

| DAY | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the Day ¹ [NTU] |
|-----|-------------|------------|------------|------------|------------|------------|---|
| 1 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 2 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 3 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 4 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 5 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 6 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 7 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 8 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 9 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 10 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 11 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 12 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 13 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 14 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 15 | NR | NR | NR | 0.02 | 0.02 | NR | 0.02 |
| 16 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 17 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 18 | NR | NR | NR | NR | 0.02 | NR | 0.02 |
| 19 | NR | NR | NR | 0.02 | NR | NR | 0.02 |
| 20 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 21 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 22 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 23 | NR | NR | 0.03 | 0.02 | NR | NR | 0.03 |
| 24 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 25 | NR | NR | NR | 0.02 | NR | NR | 0.02 |
| 26 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 27 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 28 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 29 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 30 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| | | | | | | | 0.03 |

| Conventional or Direct Filtration | Monthly Summary (Answer Yes or No) | |
|--|---|---|
| 95% of the 4 hour turbidity readings ≤ 0.3 NTU? <i>Yes / No</i> | CT's met everyday? (see back) <i>Yes / No</i> | All Cl ₂ residual at entry point ≥ 0.2 mg/l? <i>Yes / No</i> |
| All the 4 hour turbidity readings ≤ 1 NTU? <i>Yes / No</i> | | |
| All turbidity readings < IFE ² triggers? <i>Yes / No²</i> | | |
| Notes: <div style="text-align: center; font-size: 2em; color: blue; opacity: 0.5;">RECEIVED</div> <div style="text-align: center; color: red; font-weight: bold;">MAY 10 2021</div> | PRINTED NAME: <i>Raymond S. Doan</i> | DATE: 5/3/2021 |
| | SIGNATURE: <i>[Signature]</i> | CERT #: T-2651 <i>fe</i> |
| | PHONE #: (541) 396-4614 | |

¹Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

COQUILLE, CITY OF ID #: OR4100213 WTP-: WTP-A

Month/Year: Apr-21

Required Log Inactivation: 0.5

| Date / Time | Residual At 1 st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand Flow |
|-------------|---|------------------|-----------|-------|------|-------------|----------------------|-------------------------|
| | [ppm or mg/l] | [minutes] | C x T | [° C] | S.U. | Formula | Yes / No | [GPM] |
| 1 / 8:45 | 1.1 | 48 | 53 | 10.0 | 7.0 | 20 | Yes | 950 |
| 2 / 8:30 | 1.1 | 48 | 53 | 10.0 | 7.0 | 20 | Yes | 915 |
| 3 / 9:40 | 1.0 | 48 | 48 | 11.0 | 7.0 | 18 | Yes | 920 |
| 4 / 9:35 | 0.8 | 48 | 38 | 12.0 | 7.1 | 17 | Yes | 925 |
| 5 / 8:15 | 0.8 | 48 | 38 | 11.0 | 7.0 | 18 | Yes | 950 |
| 6 / 8:30 | 1.0 | 48 | 48 | 10.0 | 7.0 | 19 | Yes | 910 |
| 7 / 8:25 | 0.9 | 48 | 29 | 11.0 | 7.0 | 8 | Yes | 925 |
| 8 / 8:40 | 1.0 | 48 | 48 | 11.0 | 7.0 | 18 | Yes | 950 |
| 9 / 8:40 | 1.0 | 48 | 48 | 10.0 | 7.0 | 19 | Yes | 920 |
| 10 / 9:40 | 1.0 | 48 | 48 | 12.0 | 7.0 | 17 | Yes | 925 |
| 11 / 9:30 | 1.0 | 48 | 48 | 11.0 | 7.0 | 18 | Yes | 950 |
| 12 / 8:30 | 1.0 | 48 | 48 | 11.0 | 7.0 | 18 | Yes | 975 |
| 13 / 8:30 | 0.9 | 48 | 43 | 11.0 | 7.0 | 18 | Yes | 915 |
| 14 / 8:25 | 1.0 | 48 | 48 | 11.0 | 7.0 | 18 | Yes | 925 |
| 15 / 8:30 | 1.0 | 48 | 48 | 11.0 | 7.1 | 19 | Yes | 930 |
| 16 / 8:35 | 0.9 | 48 | 43 | 11.0 | 7.0 | 18 | Yes | 930 |
| 17 / 9:30 | 0.8 | 48 | 38 | 12.0 | 7.0 | 17 | Yes | 1050 |
| 18 / 9:40 | 0.8 | 48 | 38 | 12.0 | 7.0 | 17 | Yes | 1140 |
| 19 / 8:30 | 0.9 | 48 | 43 | 12.0 | 7.0 | 17 | Yes | 1140 |
| 20 / 12:00 | 0.9 | 48 | 43 | 13.0 | 7.0 | 15 | Yes | 1140 |
| 21 / 8:30 | 1.0 | 48 | 48 | 12.0 | 7.0 | 17 | Yes | 1130 |
| 22 / 8:45 | 1.1 | 48 | 53 | 12.0 | 7.0 | 17 | Yes | 1130 |
| 23 / 8:30 | 1.1 | 48 | 53 | 12.0 | 6.9 | 17 | Yes | 1100 |
| 24 / 9:35 | 1.2 | 48 | 58 | 13.0 | 7.0 | 16 | Yes | 1050 |
| 25 / 9:45 | 1.0 | 48 | 48 | 13.0 | 7.0 | 16 | Yes | 1050 |
| 26 / 8:45 | 1.2 | 48 | 58 | 13.0 | 7.0 | 16 | Yes | 1025 |
| 27 / 8:30 | 1.4 | 48 | 67 | 13.0 | 7.0 | 16 | Yes | 1025 |
| 28 / 8:35 | 1.3 | 48 | 62 | 13.0 | 7.0 | 16 | Yes | 1025 |
| 29 / 8:50 | 1.1 | 48 | 53 | 13.0 | 7.0 | 16 | Yes | 1020 |
| 30 / 8:35 | 1.1 | 48 | 53 | 13.0 | 7.0 | 16 | Yes | 1020 |
| | | | | | | | | |

³If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

RECEIVED

MAY 10 2021

Monthly Fluoridation Report

City of Coquille, Oregon

Month / Year : Apr-21

| I Date | II Finished Water Produced X 1000 Gallons | III Pounds of Fluoride Used | IX Finished Water Fluoride MG/L |
|-----------|---|-----------------------------------|---------------------------------------|
| 1 | 450 | 2.44 | 0.65 |
| 2 | 423 | 2.47 | 0.70 |
| 3 | 331 | 2.18 | 0.79 |
| 4 | 555 | 3.15 | 0.68 |
| 5 | 342 | 2.08 | 0.73 |
| 6 | 415 | 2.49 | 0.72 |
| 7 | 544 | 3.04 | 0.67 |
| 8 | 388 | 2.17 | 0.67 |
| 9 | 563 | 3.15 | 0.67 |
| 10 | 389 | 2.21 | 0.68 |
| 11 | 251 | 1.53 | 0.73 |
| 12 | 404 | 2.56 | 0.76 |
| 13 | 472 | 3.03 | 0.77 |
| 14 | 339 | 2.09 | 0.74 |
| 15 | 636 | 3.77 | 0.71 |
| 16 | 614 | 3.69 | 0.72 |
| 17 | 290 | 1.79 | 0.74 |
| 18 | 821 | 4.38 | 0.64 |
| 19 | 404 | 2.16 | 0.64 |
| 20 | 458 | 2.14 | 0.56 |
| 21 | 515 | 1.98 | 0.46 |
| 22 | 556 | 2.55 | 0.55 |
| 23 | 502 | 2.14 | 0.51 |
| 24 | 460 | 2.38 | 0.62 |
| 25 | 447 | 2.35 | 0.63 |
| 26 | 363 | 2.00 | 0.66 |
| 27 | 486 | 2.63 | 0.65 |
| 28 | 578 | 3.09 | 0.64 |
| 29 | 453 | 2.34 | 0.62 |
| 30 | 532 | 2.66 | 0.60 |
| | | | |

RECEIVED

MAY 10 2021

Data Mgmt & Compliance
Drinking Water Program

Month / Year : Apr-21

City of Coquille Daily Chlorine and pH Report

| Day | Chlorine | | | | | pH | | | | | Hours of Operation | | | CL17 Analyzer Reading | Alkalinity |
|-----|----------|-----|-----|-----|-----|-----|-----|-----|---------|-----------|--------------------|-------|------|-----------------------|------------|
| | 2 | 3 | 4 | 5 | 2 | 3 | 4 | 5 | Reading | Plant Hrs | R.C. | River | | | |
| 1 | 1.1 | 0.9 | 0.8 | 0.4 | 7.0 | 7.0 | 7.0 | 7.1 | 740.1 | 7.9 | X | | 1.23 | | |
| 2 | 1.1 | 1.0 | 0.8 | 0.4 | 7.0 | 7.0 | 7.0 | 7.1 | 748.0 | 7.7 | X | | 1.19 | | |
| 3 | 1.0 | 0.9 | 1.0 | 0.5 | 7.0 | 7.1 | 7.1 | 7.1 | 755.7 | 6.0 | X | | 1.14 | | |
| 4 | 0.8 | 0.9 | 0.8 | 0.5 | 7.1 | 7.1 | 7.1 | 7.2 | 761.7 | 10.0 | X | | 1.12 | | |
| 5 | 0.8 | 0.9 | 0.9 | 0.4 | 7.0 | 7.0 | 7.1 | 7.1 | 771.7 | 6.0 | X | | 1.18 | 20.0 | |
| 6 | 1.0 | 0.8 | 0.8 | 0.5 | 7.0 | 7.0 | 7.0 | 7.1 | 777.7 | 7.6 | X | | 1.16 | | |
| 7 | 0.9 | 0.8 | 0.7 | 0.4 | 7.0 | 7.0 | 7.1 | 7.1 | 785.3 | 9.8 | X | | 1.15 | | |
| 8 | 1.0 | 0.8 | 0.8 | 0.4 | 7.0 | 7.0 | 7.0 | 7.1 | 795.1 | 6.8 | X | | 1.18 | | |
| 9 | 1.0 | 0.8 | 0.8 | 0.4 | 7.0 | 7.0 | 7.0 | 7.0 | 801.9 | 10.2 | X | | 1.15 | | |
| 10 | 1.0 | 0.8 | 0.8 | 0.5 | 7.0 | 7.0 | 7.1 | 7.1 | 812.1 | 7.0 | X | | 1.18 | | |
| 11 | 1.0 | 0.9 | 0.8 | 0.5 | 7.0 | 7.0 | 7.0 | 7.1 | 819.1 | 4.4 | X | | 1.15 | | |
| 12 | 1.0 | 0.8 | 0.7 | 0.4 | 7.0 | 7.0 | 7.0 | 7.0 | 823.5 | 6.9 | X | | 1.15 | 15.0 | |
| 13 | 0.9 | 0.8 | 0.7 | 0.4 | 7.0 | 7.1 | 7.1 | 7.1 | 830.4 | 8.6 | X | | 1.20 | | |
| 14 | 1.0 | 0.8 | 0.4 | 0.4 | 7.0 | 7.1 | 7.1 | 7.1 | 839.0 | 6.1 | X | | 1.19 | | |
| 15 | 1.0 | 0.8 | 0.6 | 0.4 | 7.1 | 7.0 | 7.0 | 7.0 | 845.1 | 11.4 | X | | 1.12 | | |
| 16 | 0.9 | 0.9 | 0.7 | 0.4 | 7.0 | 7.0 | 7.0 | 7.0 | 856.5 | 11.0 | X | | 1.09 | | |
| 17 | 0.8 | 0.8 | 0.8 | 0.6 | 7.0 | 7.0 | 7.0 | 7.0 | 867.5 | 4.6 | X | | 1.23 | | |
| 18 | 0.8 | 0.8 | 0.8 | 0.7 | 7.0 | 7.0 | 7.0 | 7.1 | 872.1 | 12.0 | X | | 1.00 | | |
| 19 | 0.9 | 0.6 | 0.7 | 0.5 | 7.0 | 7.0 | 7.0 | 7.0 | 884.1 | 5.9 | X | | 0.98 | 15.0 | |
| 20 | 0.9 | 0.5 | 0.7 | 0.4 | 7.0 | 7.0 | 7.0 | 7.0 | 890.0 | 6.7 | X | | 1.39 | | |
| 21 | 1.0 | 0.8 | 0.6 | 0.4 | 7.0 | 7.0 | 7.0 | 7.0 | 896.7 | 7.6 | X | | 1.57 | | |
| 22 | 1.1 | 0.9 | 0.8 | 0.4 | 7.0 | 7.0 | 7.0 | 7.0 | 904.3 | 8.2 | X | | 1.47 | | |
| 23 | 1.1 | 1.0 | 0.7 | 0.4 | 6.9 | 7.0 | 7.0 | 7.0 | 912.5 | 7.6 | X | | 1.31 | | |
| 24 | 1.2 | 0.9 | 0.8 | 0.6 | 7.0 | 7.0 | 7.0 | 7.1 | 920.1 | 7.3 | X | | 1.48 | | |
| 25 | 1.0 | 1.0 | 0.8 | 0.5 | 7.0 | 7.0 | 7.0 | 7.0 | 927.4 | 7.1 | X | | 1.38 | | |
| 26 | 1.2 | 0.8 | 0.5 | 0.4 | 7.0 | 7.0 | 7.0 | 7.0 | 934.5 | 5.9 | X | | 1.40 | 15.0 | |
| 27 | 1.4 | 1.0 | 0.8 | 0.5 | 7.0 | 7.0 | 7.0 | 7.0 | 940.4 | 7.9 | X | | 1.37 | | |
| 28 | 1.3 | 1.0 | 0.9 | 0.5 | 7.0 | 7.0 | 7.0 | 7.0 | 948.3 | 9.4 | X | | 1.41 | | |
| 29 | 1.1 | 1.0 | 0.9 | 0.5 | 7.0 | 7.0 | 7.0 | 7.0 | 957.7 | 7.4 | X | | 1.29 | | |
| 30 | 1.1 | 0.9 | 0.8 | 0.5 | 7.0 | 7.0 | 7.0 | 7.0 | 965.1 | 8.7 | X | | 1.19 | | |

Sample Points

Final Water Tap
 MGRES
 Sewage Plant

233.7

16,087 Million Gallons

n/a Pounds

n/a Pounds

n/a Pounds

100 Pounds

2,936 Million Pounds



Data Mgmt & Compliance
 Drinking Water Program

Daily Fluoride, Production & Chlorination Report

Water System: City of Coquille

Number of Services: 1,806 Population Served: 3866

Chlorine Product Used: NaOCL Strength: 0.80%

Make & Type of Chlorinator: W & T OSC

Month / Year : Apr-21

Source of Water: Rink Creek

Free Chlorine Residual Tests
 Test Method: DPD
 2. Knowlton Heights
 3. WWTP, Sink Tap
 4. Steel Tank
 5. Random Point - Oerding Hts

| Day of Month | Reading Gallons | Daily Water Production Gall X 1,000 | Finished Water Fluoride MG/L | SP #2 | SP #3 | SP #4 | SP #5 | ReMayks |
|--------------|-----------------|-------------------------------------|------------------------------|-------|-------|-------|-------|---------|
| | | | | PPM | PPM | PPM | PPM | |
| 1 | Calculated | 450 | 0.65 | 1.1 | 0.9 | 0.8 | 0.4 | |
| 2 | " " | 423 | 0.70 | 1.1 | 1.0 | 0.8 | 0.4 | |
| 3 | " " | 331 | 0.79 | 1.0 | 0.9 | 1.0 | 0.5 | |
| 4 | " " | 555 | 0.68 | 0.8 | 0.9 | 0.8 | 0.5 | |
| 5 | " " | 342 | 0.73 | 0.8 | 0.9 | 0.9 | 0.4 | |
| 6 | " " | 415 | 0.72 | 1.0 | 0.8 | 0.8 | 0.5 | |
| 7 | " " | 544 | 0.67 | 0.9 | 0.8 | 0.7 | 0.4 | |
| 8 | " " | 388 | 0.67 | 1.0 | 0.8 | 0.8 | 0.4 | |
| 9 | " " | 563 | 0.67 | 1.0 | 0.8 | 0.8 | 0.4 | |
| 10 | " " | 389 | 0.68 | 1.0 | 0.8 | 0.8 | 0.5 | |
| 11 | " " | 251 | 0.73 | 1.0 | 0.9 | 0.8 | 0.5 | |
| 12 | " " | 404 | 0.76 | 1.0 | 0.8 | 0.7 | 0.4 | |
| 13 | " " | 472 | 0.77 | 0.9 | 0.8 | 0.7 | 0.4 | |
| 14 | " " | 339 | 0.74 | 1.0 | 0.8 | 0.4 | 0.4 | |
| 15 | " " | 636 | 0.71 | 1.0 | 0.8 | 0.6 | 0.4 | |
| 16 | " " | 614 | 0.72 | 0.9 | 0.9 | 0.7 | 0.4 | |
| 17 | " " | 290 | 0.74 | 0.8 | 0.8 | 0.8 | 0.6 | |
| 18 | " " | 821 | 0.64 | 0.8 | 0.8 | 0.8 | 0.7 | |
| 19 | " " | 404 | 0.64 | 0.9 | 0.6 | 0.7 | 0.5 | |
| 20 | " " | 458 | 0.56 | 0.9 | 0.5 | 0.7 | 0.4 | |
| 21 | " " | 515 | 0.46 | 1.0 | 0.8 | 0.6 | 0.4 | |
| 22 | " " | 556 | 0.55 | 1.1 | 0.9 | 0.8 | 0.4 | |
| 23 | " " | 502 | 0.51 | 1.1 | 1.0 | 0.7 | 0.4 | |
| 24 | " " | 460 | 0.62 | 1.2 | 0.9 | 0.8 | 0.6 | |
| 25 | " " | 447 | 0.63 | 1.0 | 1.0 | 0.8 | 0.5 | |
| 26 | " " | 363 | 0.66 | 1.2 | 0.8 | 0.5 | 0.4 | |
| 27 | " " | 486 | 0.65 | 1.4 | 1.0 | 0.8 | 0.5 | |
| 28 | " " | 578 | 0.64 | 1.3 | 1.0 | 0.9 | 0.5 | |
| 29 | | 453 | 0.62 | 1.1 | 1.0 | 0.9 | 0.5 | |
| 30 | | 532 | 0.60 | 1.1 | 0.9 | 0.8 | 0.5 | |

RECEIVED

MAY 10 2021

Data Mgmt & Compliance
 Drinking Water Program

City of Coquille Water Plant Report

44287

| RAW WATER | River MGD | Rink Creek MGD | Post | | Bags Used | RAW | Final | Raw Water | ISOPAC 806 | FLOURIDE | SODA ASH | Temperature °C | Settled Water Turbidity | Soda Ash Tank Inches | Highest Turbidity of the Day | | | |
|-----------|-----------|----------------|---------------|--------------------|-----------|-----|-------|-----------|------------|----------|----------|----------------|-------------------------|----------------------|------------------------------|------|--------|------|
| | | | Scale Reading | Feed Rate mL / Min | | | | | | | | | | | | | | |
| 1 | | 0.450 | 50/55 | | 1 | 6.4 | 7.0 | 1.3 | 40 | SCM | 41/41 | 0 | 53 | 51/45 | 10.0 | 0.40 | 17 | 0.02 |
| 2 | | 0.423 | 50/55 | | 1 | 6.4 | 7.0 | 1.5 | | SCM | 41/41 | 0 | | 51/45 | 10.0 | 0.30 | 15 1/2 | 0.02 |
| 3 | | 0.331 | 50/55 | | 0 | 6.7 | 7.0 | 2.3 | | SCM | 41/41 | 0 | | 51/45 | 10.0 | 0.30 | 20 | 0.02 |
| 4 | | 0.555 | 50/55 | | 1 | 6.8 | 7.1 | 2.4 | | SCM | 41/41 | 0 | | 51/45 | 11.0 | 0.50 | 18 1/2 | 0.02 |
| 5 | | 0.342 | 50/55 | | 1 | 6.8 | 7.0 | 2.3 | | SCM | 41/41 | 0 | | 51/45 | 10.0 | 0.50 | 16 3/4 | 0.02 |
| 6 | | 0.415 | 50/55 | | 1 | 6.7 | 7.0 | 2.0 | | SCM | 41/41 | 0 | | 51/45 | 10.0 | 0.30 | 15 1/2 | 0.02 |
| 7 | | 0.544 | 50/55 | | 1 | 6.4 | 7.0 | 2.3 | | SCM | 41/41 | 0 | | 51/45 | 10.0 | 0.40 | 14 3/4 | 0.02 |
| 8 | | 0.388 | 50/55 | | 1 | 6.4 | 7.0 | 2.8 | | SCM | 41/41 | 1 | | 51/45 | 10.0 | 0.50 | 12 1/2 | 0.02 |
| 9 | | 0.563 | 50/55 | | 1 | 6.6 | 7.0 | 0.9 | | SCM | 41/41 | 0 | | 51/45 | 10.0 | 0.40 | 17 3/4 | 0.02 |
| 10 | | 0.389 | 50/55 | | 1 | 6.8 | 7.0 | 1.2 | | SCM | 41/41 | 0 | | 51/45 | 11.0 | 0.50 | 15 1/2 | 0.02 |
| 11 | | 0.251 | 50/55 | | 0 | 6.7 | 7.0 | 1.1 | | SCM | 41/41 | 0 | | 51/45 | 11.0 | 0.50 | 14 | 0.02 |
| 12 | | 0.404 | 50/55 | | 1 | 6.8 | 7.0 | 0.9 | | SCM | 41/41 | 0 | | 51/45 | 10.0 | 0.40 | 13 | 0.02 |
| 13 | | 0.472 | 50/55 | | 9 | 6.7 | 7.0 | 1.2 | | SCM | 41/41 | 0 | | 51/45 | 10.0 | 0.50 | 17 3/4 | 0.02 |
| 14 | | 0.339 | 50/55 | | 0 | 6.5 | 7.0 | 1.2 | | SCM | 41/41 | 0 | | 51/45 | 10.0 | 0.70 | 16 | 0.02 |
| 15 | | 0.636 | 50/55 | | 0 | 6.5 | 7.1 | 0.9 | | SCM | 41/41 | 0 | | 51/45 | 10.0 | 0.60 | 15 | 0.02 |
| 16 | | 0.614 | 50/55 | | 1 | 6.5 | 7.0 | 1.3 | | SCM | 41/41 | 0 | | 51/45 | 10.5 | 0.60 | 13 | 0.02 |
| 17 | | 0.290 | 50/55 | | 1 | 6.6 | 7.0 | 1.4 | | SCM | 41/41 | 0 | | 51/45 | 11.0 | 0.70 | 17 | 0.02 |
| 18 | | 0.821 | 50/55 | | 0 | 6.5 | 7.0 | 2.2 | | SCM | 41/41 | 0 | | 51/45 | 11.0 | 0.80 | 15 1/2 | 0.02 |
| 19 | | 0.404 | 50/55 | | 0 | 6.8 | 7.0 | 0.8 | | SCM | 41/41 | 0 | | 51/45 | 11.0 | 0.60 | 14 | 0.02 |
| 20 | | 0.458 | 50/55 | | 1 | 6.5 | 7.0 | 1.1 | | SCM | 41/41 | 1 | | 51/45 | 12.0 | 0.80 | 12 3/4 | 0.02 |
| 21 | | 0.515 | 50/55 | | 0 | 6.5 | 7.0 | 1.0 | | SCM | 41/41 | 0 | | 51/45 | 11.0 | 0.70 | 11 1/4 | 0.02 |
| 22 | | 0.556 | 50/55 | | 1 | 6.6 | 7.0 | 1.0 | | SCM | 41/41 | 0 | | 51/45 | 11.0 | 0.40 | 21 1/2 | 0.02 |
| 23 | | 0.502 | 50/55 | | 1 | 6.5 | 6.9 | 1.2 | | SCM | 41/41 | 0 | | 51/45 | 11.0 | 0.40 | 19 1/2 | 0.03 |
| 24 | | 0.460 | 50/55 | | 1 | 6.6 | 7.0 | 1.5 | | SCM | 41/41 | 0 | | 51/45 | 12.0 | 0.40 | 17 3/4 | 0.02 |
| 25 | | 0.447 | 50/55 | | 0 | 6.5 | 7.0 | 1.2 | | SCM | 41/41 | 0 | | 51/45 | 12.0 | 0.50 | 16 | 0.02 |
| 26 | | 0.363 | 50/55 | | 1 | 6.5 | 7.0 | 1.3 | | SCM | 41/41 | 0 | | 51/45 | 11.0 | 0.50 | 14 | 0.02 |
| 27 | | 0.486 | 50/55 | | 0 | 6.5 | 7.0 | 4.4 | | SCM | 41/41 | 0 | | 51/45 | 12.0 | 0.30 | 18 1/2 | 0.02 |
| 28 | | 0.578 | 50/55 | | 1 | 6.4 | 7.0 | 2.0 | | SCM | 41/41 | 0 | | 51/45 | 11.0 | 0.30 | 16 1/2 | 0.02 |
| 29 | | 0.453 | 50/55 | | 1 | 6.5 | 7.0 | 2.1 | | SCM | 41/41 | 0 | | 51/45 | 12.0 | 0.30 | 14 | 0.02 |
| 30 | | 0.532 | 50/55 | | 0 | 6.5 | 7.0 | 2.4 | | SCM | 41/41 | 0 | | 51/45 | 12.0 | 0.30 | 12 1/4 | 0.02 |

Date Maint & Compliance
Drinking Water Program