


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS  
Conventional or Direct Filtration**

**System Name: COQUILLE, CITY OF ID:OR4100213 WTP:-WTP-A      Month/Year: Dec-21**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	NR	NR	0.02	0.02	NR	NR	0.02
2	NR	NR	0.02	0.04	0.02	NR	0.04
3	NR	NR	NR	0.02	NR	NR	0.02
4	NR	NR	0.03	0.02	NR	NR	0.03
5	NR	NR	0.02	0.02	NR	NR	0.02
6	NR	NR	NR	0.03	0.02	NR	0.03
7	NR	NR	0.02	0.02	NR	NR	0.02
8	NR	NR	NR	0.02	NR	NR	0.02
9	NR	NR	NR	0.02	0.02	NR	0.02
10	NR	NR	0.02	0.02	NR	NR	0.02
11	NR	NR	0.03	0.02	0.02	NR	0.04
12	NR	NR	0.02	0.02	NR	NR	0.02
13	NR	NR	0.04	0.02	0.02	NR	0.04
14	NR	NR	0.03	0.02	0.02	NR	0.03
15	NR	NR	0.02	0.02	0.02	NR	0.02
16	NR	NR	0.03	0.02	0.02	NR	0.03
17	NR	NR	0.03	0.02	0.02	NR	0.03
18	NR	NR	0.03	0.02	NR	NR	0.03
19	NR	NR	0.02	0.02	NR	NR	0.02
20	NR	NR	0.03	0.02	0.02	NR	0.03
21	NR	NR	0.03	0.02	NR	NR	0.03
22	NR	NR	0.03	0.02	0.03	NR	0.03
23	NR	NR	0.03	0.02	0.02	NR	0.03
24	NR	NR	0.04	0.02	NR	NR	0.04
25	NR	NR	0.04	0.02	0.02	NR	0.04
26	NR	NR	0.03	0.02	0.02	NR	0.03
27	NR	NR	0.03	0.02	0.02	NR	0.03
28	NR	NR	NR	0.02	0.02	NR	0.02
29	NR	NR	0.03	0.02	NR	NR	0.03
30	NR	NR	0.02	0.02	0.02	NR	0.02
31	NR	NR	0.03	0.02	NR	NR	0.03
<b>0.03</b>							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
All the 4 hour turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No		
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No <sup>2</sup>		
Notes:	PRINTED NAME: <i>Raymond S. Doan</i>	DATE: <i>1/3/22</i>
	SIGNATURE: <i>[Signature]</i>	CERT #: <i>T-2651 FE</i>
	PHONE #: <i>(541) 396-4614</i>	

  
 JAN 07 2021  
 Data Mgmt & Compliance  
 Drinking Water Program

<sup>1</sup>Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup>IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

## OHA - Drinking Water Program - Surface Water Quality Data Form

COQUILLE, CITY OF ID #: OR4100213 WTP-: WTP-A

Month/Year: Dec-21

Required Log Inactivation: 0.5

Date / Time	Residual At 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 8:45	0.9	48	43	12.0	7.0	8	Yes	980
2 / 8:45	0.9	48	43	12.0	7.0	17	Yes	1000
3 / 8:30	1.0	48	48	12.0	7.0	17	Yes	985
4 / 9:45	0.8	48	38	13.0	7.1	16	Yes	1000
5 / 9:30	0.8	48	38	13.0	7.0	15	Yes	1000
6 / 8:45	0.8	48	38	12.0	7.0	17	Yes	1000
7 / 12:00	0.9	48	43	12.0	7.1	8	Yes	990
8 / 8:30	1.2	48	58	12.0	7.0	17	Yes	1000
9 / 9:00	1.0	48	48	12.0	7.0	17	Yes	1000
10 / 8:30	1.0	48	48	11.0	7.1	19	Yes	910
11 / 9:40	1.1	48	53	12.0	7.1	18	Yes	1000
12 / 9:05	1.0	48	48	12.0	7.1	18	Yes	960
13 / 8:55	1.0	48	48	11.0	7.0	18	Yes	920
14 / 8:35	1.1	48	53	10.5	7.0	19	Yes	925
15 / 8:45	1.1	48	53	12.0	7.1	18	Yes	920
16 / 8:55	1.0	48	48	11.0	7.2	19	Yes	905
17 / 8:40	1.0	48	48	12.0	7.1	18	Yes	920
18 / 9:00	0.8	48	38	12.0	7.0	17	Yes	910
19 / 9:40	1.0	48	48	13.0	7.1	16	Yes	905
20 / 8:30	1.0	48	48	12.0	7.0	17	Yes	910
21 / 11:30	1.0	48	48	11.0	7.0	18	Yes	905
22 / 8:50	0.9	48	43	11.0	7.0	18	Yes	910
23 / 9:45	1.2	48	58	11.0	7.1	19	Yes	910
24 / 10:50	1.0	48	48	11.0	7.1	19	Yes	915
25 / 9:40	1.3	48	62	11.0	7.2	20	Yes	910
26 / 9:45	1.3	48	62	11.0	7.1	19	Yes	910
27 / 8:40	1.5	48	72	10.0	7.0	20	Yes	920
28 / 8:30	1.6	48	77	10.0	7.0	21	Yes	930
29 / 8:30	1.9	48	91	10.0	7.0	16	Yes	925
30 / 8:50	1.7	48	82	9.0	7.1	23	Yes	915
31 / 10:00	1.3	48	62	10.0	7.1	21	Yes	900

RECEIVED

JAN 07 2021

# Daily Fluoride, Production & Chlorination Report

Water System: City of Coquille


Number of Services: 1,806      Population Served: 3866  
 Chlorine Product Used: NaOCL      Strength: 0.80%  
 Make & Type of Chlorinator: W & T OSC

Month / Year : Dec-21

Source of Water: Rink Creek

Free Chlorine Residual Tests  
 Test Method: DPD  
 2. Knowlton Heights  
 3. WWTP, Sink Tap  
 4. Steel Tank  
 5. Random Point - Oerding Hts

Day of Month	Reading Gallons	Daily Water Production Gall X 1,000	Finished Water Fluoride MG/L	SP #2	SP #3	SP #4	SP #5	Remarks
				PPM	PPM	PPM	PPM	
1	Calculated	388	0.64	0.9	0.7	0.6	0.4	
2	" "	546	0.65	0.9	0.7	0.6	0.3	
3	" "	473	0.80	1.0	0.8	0.5	0.2	
4	" "	402	0.79	0.8	0.8	0.6	0.2	
5	" "	396	0.72	0.8	0.7	0.6	0.4	
6	" "	504	0.47	0.8	0.7	0.5	0.2	
7	" "	404	0.59	0.9	0.6	0.5	0.2	
8	" "	468	0.70	1.2	0.7	0.3	0.1	
9	" "	588	0.71	1.0	0.6	0.6	0.1	
10	" "	360	0.88	1.0	0.8	0.5	0.2	
11	" "	468	0.87	1.1	0.8	0.5	0.2	
12	" "	426	0.92	1.0	0.9	0.6	0.2	
13	" "	469	0.80	1.0	0.9	0.5	0.2	
14	" "	533	0.74	1.1	0.9	0.5	0.2	
15	" "	541	0.82	1.1	0.9	0.7	0.1	
16	" "	472	0.72	1.0	1.1	0.7	0.5	
17	" "	508	0.76	1.0	1.0	0.7	0.2	
18	" "	366	0.70	0.8	0.7	0.6	0.1	
19	" "	293	0.72	1.0	1.1	1.0	0.2	
20	" "	846	0.69	1.0	0.4	0.8	0.3	
21	" "	174	0.67	1.0	1.1	0.6	1.0	
22	" "	486	0.53	0.9	1.2	1.0	0.9	
23	" "	650	0.55	1.2	1.4	1.1	0.4	
24	" "	373	0.76	1.0	1.1	1.0	0.3	
25	" "	475	0.88	1.3	1.3	1.0	0.3	
26	" "	459	0.62	1.3	1.3	1.2	0.4	
27	" "	436	0.43	1.5	1.3	1.3	0.3	
28	" "	564	0.52	1.6	1.4	1.1	0.5	
29	" "	494	0.70	1.9	1.3	1.1	0.6	
30	" "	708	0.81	1.7	1.4	1.3	0.4	
31	" "	291	0.80	1.3	1.4	1.3	0.6	

  
 JAN 07 2021  
 Data Mgmt & Compliance  
 Drinking Water Program

**City of Coquille Water Plant Report**

44331

RAW WATER			Post		PH		TURBIDITY		ISOPAC 806		FLOURIDE		SODA ASH		Temperature °C		Settled Water Turbidity		Soda Ash Tank Inches		Highest Turbidity of the Day	
Date	River MGD	Rink Creek MGD	Scale Reading	Feed Rate mL / Min	Bags Used	RAW	Final	Raw Water	mL / Min	Machine Setting	Speed / Stroke	Bags Used	mL / Min	Machine Setting	Temperature °C	Settled Water Turbidity	Soda Ash Tank Inches	Highest Turbidity of the Day				
1		0.388	50/55		0	6.7	7.0	1.6	40	SCM	41/41	0	53	51/45	11.0	0.20	15	0.02				
2		0.546	50/55		1	6.7	7.0	2.1		SCM	41/41	0		51/45	11.0	0.20	13 3/4	0.04				
3		0.473	50/55		1	6.8	7.0	2.0		SCM	41/41	0		51/45	12.0	0.30	19 1/2	0.02				
4		0.402	50/55		1	6.8	7.1	1.9		SCM	41/41	0		51/45	12.0	0.40	18 1/2	0.03				
5		0.396	50/55		1	6.8	7.0	1.9		SCM	41/41	0		51/45	12.0	0.30	17 1/2	0.02				
6		0.504	50/55		1	6.8	7.0	2.1		SCM	41/41	1		51/45	12.0	0.80	16 3/4	0.03				
7		0.404	50/55		1	6.7	7.1	1.5		SCM	41/41	0		51/45	11.0	0.90	15 1/2	0.02				
8		0.468	50/55		0	6.8	7.0	1.6		SCM	41/41	0		51/45	11.0	0.50	14	0.02				
9		0.588	50/55		1	6.8	7.0	1.5		SCM	41/41	0		51/45	12.0	0.10	12 3/4	0.02				
10		0.360	50/55		1	6.8	7.1	2.1		SCM	41/41	0		51/45	11.0	0.10	11	0.02				
11		0.468	50/55		0	6.8	7.1	2.2		SCM	41/41	0		51/45	11.0	0.10	16 1/2	0.04				
12		0.426	50/55		1	6.8	7.1	1.9		SCM	41/41	0		51/45	11.0	0.20	14 1/2	0.02				
13		0.469	50/55		1	6.8	7.0	1.8		SCM	41/41	0		51/45	11.0	0.20	12 1/2	0.04				
14		0.533	50/55		0	6.8	7.0	1.6		SCM	41/41	0		51/45	11.0	0.50	10 1/2	0.03				
15		0.541	50/55		1	6.8	7.1	2.4		SCM	41/41	0		51/45	11.0	0.60	16	0.02				
16		0.472	50/55		1	6.9	7.2	2.3		SCM	41/41	0		51/45	11.0	0.60	14	0.03				
17		0.508	50/55		1	6.9	7.1	2.1		SCM	41/41	0		51/45	11.0	0.80	29 1/2	0.03				
18		0.366	50/55		0	6.9	7.0	2.9		SCM	41/41	0		51/45	11.0	1.00	28 1/2	0.03				
19		0.293	50/55		1	6.8	7.1	4.5		SCM	41/41	0		51/45	11.0	0.90	28	0.02				
20		0.846	50/55		1	6.8	7.0	4.7		SCM	41/41	0		51/45	12.0	0.80	27	0.03				
21		0.174	50/55		1	6.8	7.0	6.1		SCM	41/41	0		51/45	11.0	0.80	24 1/2	0.03				
22		0.486	50/55		1	6.8	7.0	1.8		SCM	41/41	1		51/45	11.0	0.70	23 1/2	0.03				
23		0.650	50/55		1	6.9	7.1	1.9		SCM	41/41	0		51/45	11.0	0.80	21 3/4	0.03				
24		0.373	50/55		1	6.9	7.1	1.3		SCM	41/41	0		51/45	10.0	0.40	19 1/2	0.04				
25		0.475	50/55		0	6.9	7.2	2.0		SCM	41/41	0		51/45	11.0	0.20	18	0.04				
26		0.459	50/55		1	6.9	7.1	2.1		SCM	41/41	0		51/45	10.0	0.30	16 1/2	0.03				
27		0.436	50/55		1	6.7	7.0	3.3		SCM	41/41	1		51/45	9.0	0.30	14 3/4	0.03				
28		0.564	50/55		1	6.7	7.0	3.6		SCM	41/41	0		51/45	10.0	0.40	13 1/4	0.02				
29		0.494	50/55		1	6.9	7.0	4.3		SCM	41/41	0		51/45	9.0	0.50	18 3/4	0.03				
30		0.708	50/55		0	6.8	7.1	5.5		SCM	41/41	0		51/45	9.0	0.60	17 3/4	0.02				
31		0.291	50/55		1	6.8	7.1	1.6		SCM	41/41	0		51/45	9.0	0.80	21 1/2	0.03				

Month / Year : Dec-21

### City of Coquille Daily Chlorine and pH Report

Day	Chlorine					pH					Hours of Operation			River	CL17 Analyzer Reading	Alkalinity
	2	3	4	5	6	2	3	4	5	6	Reading	Plant Hrs	R.C.			
1	0.9	0.7	0.6	0.4	0.4	7.0	7.0	7.0	7.0	7.0	968.9	6.6	X	1.41		
2	0.9	0.7	0.6	0.3	0.3	7.0	7.1	7.0	7.0	7.0	975.5	9.1	X	1.34		
3	1.0	0.8	0.5	0.2	0.2	7.0	7.0	7.0	7.1	7.1	984.6	8.0	X	1.00		
4	0.8	0.8	0.6	0.2	0.2	7.1	7.0	7.0	7.0	7.0	992.6	6.7	X	1.15		
5	0.8	0.7	0.6	0.4	0.4	7.0	7.0	7.0	7.1	7.1	999.3	6.6	X	1.17		
6	0.8	0.7	0.5	0.2	0.2	7.0	7.0	7.0	7.1	7.1	5.9	8.4	X	0.98	20.0	
7	0.9	0.6	0.5	0.2	0.2	7.1	7.0	7.0	7.1	7.1	14.3	6.8	X	1.30		
8	1.2	0.7	0.3	0.1	0.1	7.0	7.0	7.0	7.1	7.1	21.1	7.8	X	1.39		
9	1.0	0.6	0.6	0.1	0.1	7.0	7.1	7.0	7.1	7.1	28.9	9.8	X	1.18		
10	1.0	0.8	0.5	0.2	0.2	7.1	7.0	7.0	7.1	7.1	38.7	6.6	X	1.38		
11	1.1	0.8	0.5	0.2	0.2	7.1	7.0	7.0	7.1	7.1	45.3	8.1	X	1.26		
12	1.0	0.9	0.6	0.2	0.2	7.1	7.0	7.0	7.1	7.1	53.4	7.4	X	1.43		
13	1.0	0.9	0.5	0.2	0.2	7.0	7.0	7.0	7.0	7.0	60.8	8.5	X	1.48	20.0	
14	1.1	0.9	0.5	0.2	0.2	7.0	7.0	7.0	7.1	7.1	69.3	9.6	X	1.40		
15	1.1	0.9	0.7	0.1	0.1	7.1	7.0	7.1	7.0	7.0	75.9	9.8	X	1.34		
16	1.0	1.1	0.7	0.5	0.5	7.2	7.1	7.0	7.0	7.0	88.7	8.7	X	1.46		
17	1.0	1.0	0.7	0.2	0.2	7.1	7.0	7.0	7.1	7.0	97.4	9.2	X	1.39		
18	0.8	0.7	0.6	0.1	0.1	7.0	7.0	7.0	7.0	7.0	106.6	6.7	X	1.59		
19	1.0	1.1	1.0	0.2	0.2	7.1	7.0	7.0	7.0	7.0	113.3	5.4	X	1.61		
20	1.0	0.4	0.8	0.3	0.3	7.0	7.0	7.0	7.1	7.0	118.7	15.5	X	1.21	30.0	
21	1.0	1.1	0.6	1.0	1.0	7.0	7.0	7.0	7.0	7.0	134.2	3.2	X	1.81		
22	0.9	1.2	1.0	0.9	0.9	7.0	7.0	7.0	7.0	7.0	137.4	8.9	X	1.69		
23	1.2	1.4	1.1	0.4	0.4	7.1	7.1	7.1	7.0	7.0	146.3	11.9	X	1.77		
24	1.0	1.1	1.0	0.3	0.3	7.1	7.0	7.0	7.0	7.0	158.2	6.8	X	1.83		
25	1.3	1.3	1.0	0.3	0.3	7.2	7.1	7.1	7.1	7.1	165.0	8.7	X	1.82		
26	1.3	1.3	1.2	0.4	0.4	7.1	7.1	7.1	7.1	7.1	173.7	8.4	X	2.10		
27	1.5	1.3	1.3	0.3	0.3	7.0	7.0	7.0	7.0	7.0	182.1	7.9	X	1.81	20.0	
28	1.6	1.4	1.1	0.5	0.5	7.0	7.0	7.0	7.0	7.0	190.0	10.1	X	1.06		
29	1.9	1.3	1.1	0.6	0.6	7.0	7.0	7.0	7.0	7.0	200.1	8.9	X	1.80		
30	1.7	1.4	1.3	0.4	0.4	7.1	7.0	7.0	7.0	7.0	209.0	12.9	X	1.80		
31	1.3	1.4	1.3	0.6	0.6	7.1	7.0	7.0	7.0	7.0	221.9	5.4	X	1.78		

Sample Points  
 Final Water Tap \_\_\_\_\_  
 MGRES \_\_\_\_\_  
 Sewage Plant \_\_\_\_\_

258.4 Million Gallons  
 16,087 Pounds  
 n/a Pounds  
 n/a Pounds  
 n/a Pounds  
 100 Pounds  
 2,936 Million Pounds

9.8

**RECEIVED**  
 JAN 07 2021

Data Mgmt & Compliance  
 Drinking Water Program