


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS
Conventional or Direct Filtration**

System Name: COQUILLE, CITY OF ID:OR4100213 WTP-:WTP-A Month/Year: Jul-22

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	NR	NR	0.02	0.02	NR	NR	0.02
2	NR	NR	0.02	0.02	NR	NR	0.02
3	NR	NR	0.02	0.02	NR	NR	0.02
4	NR	NR	0.02	0.02	NR	NR	0.02
5	NR	NR	0.02	0.02	NR	NR	0.02
6	NR	NR	NR	0.02	0.02	NR	0.02
7	NR	NR	0.02	0.02	0.02	NR	0.02
8	NR	NR	0.02	0.02	0.02	NR	0.02
9	NR	NR	0.02	0.02	NR	NR	0.02
10	NR	NR	0.02	0.02	0.02	NR	0.02
11	NR	NR	0.02	0.02	NR	NR	0.03
12	NR	NR	0.02	0.02	NR	NR	0.02
13	NR	NR	NR	0.02	0.02	0.02	0.02
14	NR	NR	0.02	0.02	NR	NR	0.02
15	NR	NR	0.02	0.02	0.02	NR	0.02
16	NR	NR	0.02	0.02	NR	NR	0.02
17	NR	0.02	0.02	NR	0.02	NR	0.02
18	NR	NR	0.02	0.02	0.02	NR	0.02
19	NR	NR	0.02	0.02	NR	NR	0.02
20	0.02	0.02	NR	0.02	NR	NR	0.02
21	NR	NR	0.02	0.03	NR	NR	0.03
22	NR	NR	0.02	0.02	0.02	NR	0.02
23	NR	NR	0.02	0.02	NR	NR	0.02
24	NR	0.02	0.02	0.03	0.02	NR	0.03
25	NR	0.03	0.02	0.03	NR	NR	0.03
26	NR	0.02	0.02	NR	NR	0.02	0.02
27	0.02	0.02	0.02	NR	NR	NR	0.02
28	0.03	0.02	NR	0.03	0.02	NR	0.03
29	NR	0.03	0.02	0.03	NR	NR	0.03
30	NR	0.03	0.02	0.03	NR	NR	0.03
31	NR	0.02	0.03	NR	0.03	NR	0.03
0.03							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <i>Yes</i> / No		CT's met everyday? <i>Yes</i> / No <i>(see back)</i>	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <i>Yes</i> / No
All the 4 hour turbidity readings ≤ 1 NTU? <i>Yes</i> / No			
All turbidity readings < IFE ² triggers? <i>Yes</i> / No ²			
Notes:	PRINTED NAME: <i>Raymond S. Doan</i>	SIGNATURE: <i>[Signature]</i> DATE: <i>8/1/22</i>	
Data Mgmt & Compliance Drinking Water Program	PHONE #: <i>(541) 396-4614</i>	CERT #: <i>T-2651 FE</i>	

¹Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))
PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

COQUILLE, CITY OF ID #: OR4100213 WTP-: WTP-A

Month/Year:

Jul-22

Required Log
Inactivation:

0.5

Date / Time	Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 8:15	1.1	48	53	16.0	7.0	8	Yes	1090
2 / 10:05	0.9	48	43	16.0	7.0	13	Yes	1090
3 / 10:00	0.8	48	38	16.0	7.1	13	Yes	1095
4 / 9:50	0.8	48	38	17.0	7.0	12	Yes	1090
5 / 8:20	0.9	48	43	16.0	7.0	13	Yes	1100
6 / 8:20	1.1	48	53	16.0	7.0	13	Yes	1095
7 / 8:40	1.0	48	48	16.0	7.0	8	Yes	1100
8 / 8:25	0.9	48	43	16.0	7.0	13	Yes	1095
9 / 10:05	0.8	48	38	17.0	7.0	12	Yes	1060
10 / 9:55	1.0	48	48	17.0	7.0	12	Yes	1090
11 / 8:20	1.0	48	48	17.0	7.0	12	Yes	1095
12 / 9:15	1.2	48	58	17.0	7.0	12	Yes	1090
13 / 8:15	1.3	48	62	17.0	7.0	12	Yes	1090
14 / 8:45	1.3	48	62	17.0	7.0	12	Yes	1100
15 / 8:35	1.3	48	62	18.0	7.0	12	Yes	1140
16 / 9:55	0.9	48	43	21.0	7.0	9	Yes	1140
17 / 10:00	0.8	48	38	22.0	7.0	8	Yes	1150
18 / 8:20	0.8	48	38	21.0	7.0	9	Yes	1140
19 / 9:40	0.8	48	38	22.0	7.0	8	Yes	1150
20 / 8:15	0.9	48	43	21.0	7.0	9	Yes	1140
21 / 8:40	0.8	48	38	21.0	7.0	9	Yes	1150
22 / 8:20	0.9	48	43	22.0	7.0	8	Yes	1140
23 / 9:50	0.9	48	43	22.0	7.1	9	Yes	1150
24 / 10:00	0.9	48	43	22.0	7.1	9	Yes	1150
25 / 8:15	0.9	48	48	22.0	7.0	8	Yes	1140
26 / 10:30	0.9	48	43	22.0	7.0	8	Yes	1160
27 / 8:15	1.0	48	48	22.0	7.0	8	Yes	1160
28 / 8:25	0.9	48	43	22.0	7.0	8	Yes	1150
29 / 8:15	0.9	48	43	22.0	6.9	8	Yes	1150
30 / 9:55	0.8	48	38	23.0	7.4	9	Yes	1150
31 / 9:30	0.8	48	38	24.0	7.2	8	Yes	1150

City of Coquille Water Plant Report

44743

RAW WATER				PH		TURBIDITY		ISOPAC 806		FLOURIDE		SODA ASH						
Date	River MGD	Rink Creek MGD	Scale Reading	Feed Rate mL / Min	Bags Used	RAW	Final	Raw Water	mL / Min	Machine Setting	Speed / Stroke	Bags Used	mL / Min	Machine Setting	Temperature °C	Settled Water Turbidity	Soda Ash Tank Inches	Highest Turbidity of the Day
1		0.523	50/55		1	6.9	7.0	1.5	40	SCM	41/41	0	53	51/45	14.0	0.30	16 1/2	0.02
2		0.549	50/55		0	6.7	7.0	2.2		SCM	41/41	0		51/45	15.0	0.30	21 1/2	0.02
3		0.526	50/55		1	6.8	7.1	3.1		SCM	41/41	0		51/45	15.0	0.30	19 1/2	0.02
4		0.549	50/55		0	6.8	7.0	3.8		SCM	41/41	0		51/45	15.0	0.30	18	0.02
5		0.422	50/55		1	6.9	7.0	1.4		SCM	41/41	0		51/45	15.0	0.30	15 3/4	0.02
6		0.650	50/55		1	6.8	7.0	2.0		SCM	41/41	0		51/45	16.0	0.30	14 1/4	0.02
7		0.713	50/55		0	6.9	7.0	2.8		SCM	41/41	0		51/45	15.0	0.40	19 1/2	0.02
8		0.690	50/55		1	6.8	7.0	1.2		SCM	41/41	1		51/45	15.0	0.40	17 1/4	0.02
9		0.518	50/55		1	6.8	7.0	1.5		SCM	41/41	0		51/45	16.0	0.30	22	0.02
10		0.654	50/55		0	6.8	7.0	2.0		SCM	41/41	0		51/45	16.0	0.50	20 1/2	0.02
11		0.775	50/55		1	6.8	7.0	1.4		SCM	41/41	1		51/45	15.0	0.50	18 3/4	0.02
12		0.445	50/55		1	6.8	7.0	1.2		SCM	41/41	0		51/45	16.0	0.50	16 1/2	0.02
13		1.138	50/55		1	6.8	7.0	2.8		SCM	41/41	0		51/45	17.0	0.50	14 3/4	0.02
14		0.429	50/55		1	6.8	7.0	2.0		SCM	41/41	0		51/45	17.0	0.50	11 1/4	0.02
15		0.657	50/55		1	6.9	7.0	3.0		SCM	41/41	0		51/45	22.0	0.60	16 3/4	0.02
16		0.848	50/55		0	6.9	7.0	4.7		SCM	41/41	0		51/45	23.0	0.60	22 1/2	0.02
17		0.380	50/55		1	6.9	7.0	5.0		SCM	41/41	0		51/45	23.0	0.60	19 1/2	0.02
18		0.896	50/55		1	6.8	7.0	3.8		SCM	41/41	1		51/45	23.0	0.60	18	0.02
19		0.698	50/55		0	6.8	7.0	3.7		SCM	41/41	0		51/45	22.0	0.60	15 1/2	0.02
20		0.492	50/55		1	6.8	7.0	3.9		SCM	41/41	0		51/45	22.0	0.60	12 3/4	0.02
21		0.580	50/55		0	6.9	7.0	6.2		SCM	41/41	0		51/45	22.0	0.50	18	0.03
22		1.128	50/55		1	6.8	7.0	1.8		SCM	41/41	0		51/45	22.0	0.50	16 1/4	0.02
23		0.422	50/55		1	6.8	7.1	1.6		SCM	41/41	0		51/45	23.0	0.50	20 1/2	0.02
24		0.745	50/55		1	6.9	7.1	2.3		SCM	41/41	0		51/45	22.0	0.50	18 1/2	0.03
25		0.814	50/55		1	6.8	7.0	2.3		SCM	41/41	1		51/45	22.0	0.40	16 1/4	0.03
26		0.786	50/55		1	6.8	7.0	2.3		SCM	41/41	0		51/45	23.0	0.40	13 3/4	0.02
27		0.668	50/55		0	6.9	7.0	3.9		SCM	41/41	0		51/45	23.0	0.40	18	0.02
28		1.007	50/55		1	6.8	7.0	2.4		SCM	41/41	0		51/45	23.0	0.40	15 1/2	0.03
29		0.608	50/55		1	6.8	7.0	3.5		SCM	41/41	0		51/45	24.0	0.30	19 1/2	0.03
30		0.605	50/55		1	7.0	7.4	3.4		SCM	41/41	0		51/45	24.0	0.40	18 1/2	0.03
31		0.449	50/55		0	6.9	7.2	4.6		SCM	41/41	0		51/45	24.0	0.30	14	0.03

Month / Year : Jul-22

City of Coquille Daily Chlorine and pH Report

Day	Chlorine					pH					Hours of Operation			CL17 Analyzer Reading	Alkalinity	
	2	3	4	5	6	2	3	4	5	6	Reading	Plant Hrs	R.C.			River
1	1.1	0.9	0.7	0.6	0.6	7.0	7.0	7.1	7.1	7.1	622.5	8.0	X		1.13	
2	0.9	0.8	0.7	0.7	0.7	7.0	7.1	7.0	7.0	7.0	630.5	8.4	X		1.15	
3	0.8	0.8	0.7	0.5	0.5	7.1	7.0	7.0	7.0	7.0	638.9	8.0	X		1.14	
4	0.8	0.8	0.5	0.3	0.3	7.0	7.0	7.1	7.0	7.0	646.9	8.4	X		1.13	
5	0.9	0.7	0.6	0.4	0.4	7.0	7.0	7.0	7.0	7.0	655.3	6.4	X		1.14	15.0
6	1.1	0.8	0.7	0.4	0.4	7.0	7.0	7.0	7.0	7.0	661.7	9.9	X		0.95	
7	1.0	0.5	0.5	0.6	0.6	7.0	7.0	7.0	7.0	7.1	671.6	10.8	X		1.15	
8	0.9	0.8	0.7	0.5	0.5	7.0	7.0	7.1	7.0	7.0	682.4	10.5	X		1.14	
9	0.8	0.9	0.8	0.5	0.5	7.0	7.0	7.0	7.0	7.0	692.9	8.1	X		1.18	
10	1.0	0.9	0.6	0.4	0.4	7.0	7.0	7.0	7.0	7.0	701.0	10.0	X		1.15	
11	1.0	0.8	0.4	0.6	0.6	7.0	7.1	7.1	7.0	7.0	711.0	11.8	X		1.15	15.0
12	1.2	0.8	0.7	0.6	0.6	7.0	7.0	7.0	7.0	7.0	722.8	6.8	X		1.15	
13	1.3	0.8	0.6	0.6	0.6	7.0	7.0	7.0	7.0	7.0	729.6	17.4	X		1.00	
14	1.3	0.9	0.6	0.7	0.7	7.0	7.0	7.0	7.1	7.1	747.0	6.5	X		1.17	
15	1.3	0.7	0.6	0.3	0.3	7.0	7.1	7.0	7.0	7.0	753.5	9.6	X		1.10	
16	0.9	0.7	0.6	0.2	0.2	7.0	7.0	7.1	7.1	7.1	763.1	12.4	X		1.14	
17	0.8	0.7	0.5	0.6	0.6	7.0	7.0	7.0	7.0	7.0	775.5	5.5	X		1.21	
18	0.8	0.6	0.5	0.3	0.3	7.0	7.0	7.0	7.0	7.0	781.0	13.1	X		1.21	25.0
19	0.8	0.4	0.5	0.1	0.1	7.0	7.0	7.0	7.0	7.0	794.1	10.2	X		1.26	
20	0.9	0.5	0.6	0.7	0.7	7.0	7.0	7.0	7.1	7.1	804.3	7.2	X		1.14	
21	0.8	0.9	0.5	0.3	0.3	7.0	7.0	7.0	7.0	7.0	811.5	8.4	X		1.29	
22	0.9	0.7	0.4	0.2	0.2	7.0	7.0	7.0	7.0	7.0	819.9	17.8	X		1.39	
23	0.9	0.9	0.7	0.7	0.7	7.1	7.2	7.2	7.2	7.2	833.7	6.7	X		1.34	
24	0.9	0.9	0.6	0.7	0.7	7.1	7.2	7.2	7.3	7.3	844.4	10.8	X		1.35	
25	0.9	0.8	0.7	0.1	0.1	7.0	7.0	7.0	7.1	7.1	856.2	11.9	X		1.33	30.0
26	0.9	0.8	0.3	0.7	0.7	7.0	7.0	7.0	7.0	7.0	862.1	11.3	X		1.18	
27	1.0	0.9	0.6	0.5	0.5	7.0	7.0	7.0	7.0	7.0	878.4	9.6	X		1.34	
28	0.9	0.8	0.5	0.8	0.8	7.0	7.0	7.0	7.0	7.0	888.0	14.6	X		1.20	
29	0.9	0.9	0.7	0.7	0.7	7.0	7.0	7.0	7.0	7.0	902.6	10.8	X		1.35	
30	0.8	0.7	0.6	0.1	0.1	7.4	7.4	7.3	7.4	7.4	913.4	9.6	X		1.34	
31	0.8	0.5	0.7	0.7	0.7	7.2	7.2	7.2	7.3	7.3	923.0	6.5	X		1.22	

Sample Points _____
 Final Water Tap _____
 MGRES _____
 Sewage Plant _____

307
 16,087 Million Gallons
 n/a Pounds
 n/a Pounds
 n/a Pounds
 100 Pounds
 2,936 Million Pounds