

OHA - Drinking Water Program - Surface Water Quality Data Form

COQUILLE, CITY OF ID #: OR4100213 WTP-: WTP-A Month/Year: Feb-23

Certification
 Required Log
 Drinking Water Services
 Inactivation: 0.5

Date / Time	Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 8:25	1.1	48	53	9.0	7.0	8	Yes	820
2 / 8:50	1.2	48	58	8.0	7.0	22	Yes	825
3 / 8:15	1.4	48	67	9.0	7.0	22	Yes	830
4 / 9:35	1.1	48	53	11.0	7.0	18	Yes	865
5 / 10:05	1.1	48	53	10.0	7.0	20	Yes	840
6 / 8:10	1.0	48	48	8.0	7.0	22	Yes	835
7 / 7:50	1.2	48	58	9.0	7.0	8	Yes	820
8 / 8:30	1.1	48	53	9.0	7.0	21	Yes	825
9 / 11:00	1.2	48	58	9.0	7.0	21	Yes	825
10 / 8:15	1.3	48	62	8.0	7.0	23	Yes	845
11 / 9:55	0.9	48	43	10.0	7.1	20	Yes	855
12 / 8:45	0.9	48	43	11.0	7.1	19	Yes	850
13 / 8:25	1.1	48	53	10.0	7.0	20	Yes	860
14 / 8:20	1.3	48	62	9.0	7.0	21	Yes	850
15 / 8:15	1.8	48	86	8.0	7.0	24	Yes	845
16 / 8:30	1.5	48	72	8.0	7.0	23	Yes	850
17 / 8:20	1.8	48	86	8.0	7.0	24	Yes	860
18 / 9:45	0.9	48	43	11.0	7.1	19	Yes	840
19 / 10:05	0.8	48	38	10.0	7.1	20	Yes	850
20 / 10:00	0.9	48	43	10.0	7.0	19	Yes	840
21 / 8:15	1.1	48	53	10.0	7.0	20	Yes	845
22 / 8:15	1.2	48	58	8.0	7.0	22	Yes	855
23 / 8:35	1.2	48	58	8.0	7.0	22	Yes	870
24 / 8:30	0.8	48	38	9.0	7.0	20	Yes	870
25 / 10:00	0.8	48	48	9.0	7.1	21	Yes	840
26 / 9:55	0.9	48	43	10.0	7.1	20	Yes	850
27 / 8:30	1.3	48	62	8.0	7.1	24	Yes	850
28 / 8:10	1.4	48	67	8.0	7.0	23	Yes	860

