


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS
Conventional or Direct Filtration**

System Name: COQUILLE, CITY OF ID:OR4100213 WTP-:WTP-A Month/Year: Jun-23

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	NR	NR	0.02	0.02	NR	NR	0.02
2	NR	NR	0.02	0.02	0.02	NR	0.02
3	NR	NR	0.02	0.02	0.02	NR	0.02
4	NR	NR	0.02	0.02	0.02	NR	0.02
5	NR	NR	0.02	0.02	NR	NR	0.02
6	NR	NR	0.02	0.02	NR	NR	0.02
7	NR	NR	0.02	0.02	NR	NR	0.02
8	NR	NR	0.02	0.03	NR	NR	0.03
9	NR	NR	0.02	0.02	0.02	NR	0.02
10	NR	NR	0.02	0.02	0.02	NR	0.02
11	NR	NR	0.02	0.02	NR	NR	0.02
12	NR	NR	0.02	0.02	0.02	0.02	0.02
13	NR	NR	0.02	0.02	NR	NR	0.02
14	NR	NR	0.02	0.02	0.02	NR	0.02
15	NR	NR	0.02	0.02	0.02	NR	0.02
16	NR	NR	NR	0.02	0.02	NR	0.02
17	NR	NR	0.02	0.02	NR	NR	0.02
18	NR	NR	0.02	0.02	NR	NR	0.02
19	NR	NR	0.02	0.02	NR	NR	0.02
20	NR	NR	0.02	0.02	NR	NR	0.02
21	NR	NR	0.02	0.02	NR	NR	0.02
22	NR	NR	0.02	0.03	0.02	NR	0.03
23	NR	NR	0.02	0.02	NR	NR	0.02
24	NR	NR	0.02	0.02	NR	NR	0.02
25	NR	NR	0.02	0.02	0.02	NR	0.02
26	NR	NR	NR	0.02	0.02	NR	0.02
27	NR	NR	0.02	0.02	0.02	NR	0.02
28	NR	NR	0.02	0.02	NR	NR	0.02
29	NR	NR	0.02	0.04	0.02	NR	0.04
30	NR	NR	NR	0.03	0.04	NR	0.05
0.04							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <i>Yes</i> / No	CT's met everyday? <i>(see back) Yes</i> / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <i>Yes</i> /No	
All the 4 hour turbidity readings ≤ 1 NTU? <i>Yes</i> / No			
All turbidity readings ≤ IFE ² triggers? <i>Yes</i> / No ²			
		0.04 <i>Raymond S. Doan</i>	
		0.04 <i>[Signature]</i>	DATE: <i>7/3/23</i>
		PHONE #: (541) 396-4614	CERT #: T-2651 <i>FE.</i>

Data Mgmt & Compliance
Drinking Water Program

OHA - Drinking Water Program - Surface Water Quality Data Form

COQUILLE, CITY OF ID #: OR4100213 WTP-: WTP-A

Month/Year:

Jun-23

Required Log

Inactivation:

0.5

Date / Time	Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 8:20	1.0	48	48	13.0	7.0	8	Yes	940
2 / 8:30	1.0	48	48	13.0	7.0	16	Yes	940
3 / 9:40	0.8	48	38	14.0	7.0	14	Yes	1080
4 / 9:45	0.9	48	43	14.0	7.0	14	Yes	1070
5 / 8:15	1.0	48	48	13.0	7.0	16	Yes	1070
6 / 8:20	1.0	48	48	13.0	7.0	16	Yes	1065
7 / 10:30	0.9	48	43	14.0	7.0	8	Yes	1060
8 / 8:30	1.0	48	48	14.0	7.0	15	Yes	1070
9 / 8:15	1.0	48	48	14.0	7.1	15	Yes	1070
10 / 9:00	0.8	48	38	15.0	7.0	13	Yes	1065
11 / 9:35	0.8	48	38	15.0	7.0	13	Yes	1060
12 / 8:20	1.0	48	48	14.0	7.0	15	Yes	1055
13 / 8:20	0.9	48	43	15.0	7.0	13	Yes	1060
14 / 8:15	0.8	48	38	14.0	7.0	14	Yes	1020
15 / 8:30	1.0	48	48	14.0	7.0	15	Yes	1050
16 / 8:30	1.1	48	53	15.0	7.0	14	Yes	1065
17 / 10:00	0.8	48	38	16.0	7.0	12	Yes	1040
18 / 9:45	0.8	48	38	16.0	7.0	12	Yes	1050
19 / 9:50	0.9	48	43	16.0	7.0	13	Yes	1050
20 / 8:15	0.8	48	38	15.0	7.0	13	Yes	1020
21 / 9:15	0.8	48	38	15.0	7.0	13	Yes	1050
22 / 8:20	0.8	48	38	15.0	7.0	13	Yes	1030
23 / 8:15	1.0	48	48	15.0	7.0	14	Yes	1040
24 / 9:40	1.0	48	48	17.0	7.0	12	Yes	1025
25 / 9:45	0.8	48	48	16.0	7.1	13	Yes	1040
26 / 9:30	1.1	48	53	16.0	7.0	13	Yes	1050
27 / 8:25	0.8	48	38	16.0	7.0	12	Yes	1070
28 / 8:20	0.8	48	38	18.0	7.0	11	Yes	1070
29 / 8:30	0.8	48	38	19.0	7.0	10	Yes	1080
30 / 8:15	0.8	48	38	20.0	7.0	10	Yes	1080

RECEIVED

JUL 11 2023

Month / Year : Jun-23

City of Coquille Daily Chlorine and pH Report

Day	Chlorine					pH					Hours of Operation			CL17 Analyzer Reading	Alkalinity
	2	3	4	5	2	3	4	5	Reading	Plant Hrs	R.C.	River			
1	1.0	0.8	0.7	0.6	7.0	7.0	7.1	7.0	969.8	9.8	X		1.10		
2	1.0	0.5	0.8	0.7	7.0	7.1	7.0	7.0	979.6	10.9	X		1.18		
3	0.8	0.8	0.8	0.7	7.0	7.0	7.0	7.0	990.5	9.5	X		1.20		
4	0.9	0.9	0.8	0.8	7.0	7.0	7.0	7.0	0.0	9.1	X		1.22		
5	1.0	1.0	0.7	0.6	7.0	7.0	7.0	7.0	9.1	8.5	X		1.22		
6	1.0	0.8	0.7	0.9	7.0	7.1	7.0	7.0	17.6	12.5	X		1.23		
7	0.9	0.9	0.8	0.6	7.0	7.0	7.0	7.0	30.1	7.1	X		1.29		
8	1.0	0.8	0.9	0.5	7.0	7.0	7.0	7.0	37.2	6.3	X		1.22		
9	1.0	0.9	0.7	0.6	7.1	7.0	7.0	7.1	43.5	11.4	X		1.20		
10	0.8	0.9	0.8	0.9	7.0	7.0	7.0	7.0	54.9	10.7	X		1.21		
11	0.8	0.9	0.9	0.8	7.0	7.0	7.0	7.0	65.6	7.2	X		1.20		
12	1.0	0.7	0.8	0.6	7.0	7.0	7.0	7.0	72.8	14.4	X		1.19		
13	0.9	1.0	0.8	1.0	7.0	7.0	7.0	7.1	87.2	6.8	X		1.22		
14	0.8	0.9	0.7	0.7	7.0	7.0	7.0	7.0	94.0	6.3	X		1.21		
15	1.0	0.3	0.8	0.6	7.0	7.0	7.0	7.0	104.3	8.4	X		1.21		
16	1.1	0.9	0.4	0.7	7.0	7.0	7.0	7.0	112.7	13.5	X		1.04		
17	0.8	1.0	0.7	0.7	7.0	7.0	7.0	7.0	126.2	7.4	X		1.21		
18	0.8	0.7	0.6	0.6	7.0	7.0	7.1	7.0	133.6	8.4	X		1.14		
19	0.9	0.9	0.8	0.7	7.0	7.0	7.0	7.0	142.0	5.8	X		1.17		
20	0.8	0.8	0.8	0.7	7.0	7.0	7.0	7.0	147.8	10.0	X		1.02		
21	0.8	0.4	0.7	0.7	7.0	7.0	7.0	7.0	157.8	6.2	X		1.18		
22	0.8	0.8	0.6	0.6	7.0	7.0	7.1	7.0	164.0	11.6	X		1.08		
23	1.0	0.8	0.6	0.7	7.0	7.0	7.0	7.1	175.6	9.9	X		1.28		
24	1.0	1.0	0.7	0.6	7.0	7.0	7.0	7.0	185.5	7.7	X		1.27		
25	0.8	0.9	0.8	0.6	7.1	7.0	7.1	7.0	193.2	8.1	X		1.21		
26	1.1	0.5	0.5	0.6	7.0	7.0	7.0	7.0	201.3	9.1	X		1.41		
27	0.8	0.8	0.8	0.7	7.0	7.0	7.0	7.0	210.4	9.0	X		1.18		
28	0.8	0.8	0.4	0.8	7.0	7.0	7.0	7.0	219.4	8.0	X		1.02		
29	0.8	0.7	0.8	0.8	7.0	7.0	7.0	7.0	227.4	9.6	X		1.06		
30	0.8	0.8	1	0.8	7.0	7.0	7.0	7.0	237.0	11.3	X		1.05		

Sample Points _____
 Final Water Tap _____
 MGRES _____
 Sewage Plant _____

274.5 Million Gallons
 16.087 Million Gallons
 n/a Pounds
 n/a Pounds
 n/a Pounds
 100 Pounds
 2.936 Million Pounds

9.8

Data Mgmt & Compliance
 Drinking Water Program

RECEIVED
 JUL 11 2023

Daily Fluoride, Production & Chlorination Report

Water System: City of Coquille

Number of Services: 1,806 Population Served: 3866

Chlorine Product Used: NaOCL Strength: 0.80%

Make & Type of Chlorinator: W & T OSC

Month / Year : Jun-23

Source of Water: Rink Creek/Coquille River

Free Chlorine Residual Tests
 Test Method: DPD
 2. Knowlton Heights
 3. WWTP, Sink Tap
 4. Steel Tank
 5. Random Point - Oerding Hts

Day of Month	Reading Gallons	Daily Water Production	Finished Water Fluoride MG/L	SP #2	SP #3	SP #4	SP #5	Remarks
				PPM	PPM	PPM	PPM	
1	Calculated	553	0.69	1.0	0.8	0.7	0.6	
2	" "	615	0.69	1.0	0.5	0.8	0.7	
3		616	0.77	0.8	0.8	0.8	0.7	
4		584	0.75	0.9	0.9	0.8	0.8	
5		546	0.66	1.0	1.0	0.7	0.6	
6		799	0.65	1.0	0.8	0.7	0.9	
7	" "	452	0.64	0.9	0.9	0.8	0.6	
8		404	0.64	1.0	0.8	0.9	0.5	
9		732	0.59	1.0	0.9	0.7	0.6	
10	" "	684	0.60	0.8	0.9	0.8	0.9	
11	" "	458	0.67	0.8	0.9	0.9	0.8	
12	" "	912	0.57	1.0	0.7	0.8	0.6	
13	" "	432	0.65	0.9	1.0	0.8	1.0	
14	" "	630	0.66	0.8	0.9	0.7	0.7	
15	" "	529	0.64	1.0	0.3	0.8	0.6	
16	" "	863	0.66	1.1	0.9	0.4	0.7	
17	" "	462	0.67	0.8	1.0	0.7	0.7	
18	" "	529	0.60	0.8	0.7	0.6	0.6	
19	" "	365	0.64	0.9	0.9	0.8	0.7	
20	" "	612	0.64	0.8	0.8	0.8	0.7	
21	" "	391	0.63	0.8	0.4	0.7	0.7	
22	" "	717	0.78	0.8	0.8	0.6	0.6	
23	" "	618	0.68	1.0	0.8	0.6	0.7	
24	" "	474	0.65	1.0	1.0	0.7	0.6	
25	" "	505	0.58	0.8	0.9	0.8	0.6	
26	" "	573	0.50	1.1	0.5	0.5	0.6	
27	" "	578	0.64	0.8	0.8	0.8	0.7	
28	" "	514	0.54	0.1	0.8	0.4	0.8	
29		622	0.61	0.8	0.7	0.8	0.8	
30		732	0.65	0.8	0.8	1.0	0.8	

RECEIVED

JUL 11 2023

Data Mgmt & Compliance
 Drinking Water Program

City of Coquille Water Plant Report

45078

RAW WATER	PH	TURBIDITY	ISOPAC 835	FLOURIDE	SODA ASH	Post		RAW	Final	Raw Water	mL / Min	Machine Setting	Speed / Stroke	Bags Used	mL / Min	Machine Setting	Temperature °C	Settled Water Turbidity	0.88	Soda Ash Tank Inches	Highest Turbidity of the Day
						Scale Reading	Feed Rate mL / Min														
1								6.9	7.0	1.1		SCM	41/41	1		51/45	13.0	0.10		18 1/2	0.02
2								6.9	7.0	1.9	40	SCM	41/41	0	53	51/45	12.0	0.30		16 1/2	0.02
3								6.8	7.0	1.5		SCM	41/41	0		51/45	12.0	0.40		14 1/4	0.02
4								6.7	7.0	2.2		SCM	41/41	0		51/45	13.0	0.50		12 1/2	0.02
5								6.9	7.0	1.9		SCM	41/41	0		51/45	12.0	0.30		11	0.02
6								6.9	7.0	2.6		SCM	41/41	0		51/45	12.0	0.50		16 1/4	0.02
7								6.9	7.0	2.3		SCM	41/41	0		51/45	13.0	0.80		14 1/4	0.02
8								6.8	7.0	0.5		SCM	41/41	0		51/45	12.0	0.50		13 1/4	0.03
9								6.9	7.1	1.8		SCM	41/41	1		51/45	13.0	0.60		12 1/4	0.02
10								6.8	7.0	1.4		SCM	41/41	0		51/45	13.0	0.50		17 1/2	0.02
11								6.9	7.0	1.1		SCM	41/41	0		51/45	14.0	0.50		16	0.02
12								6.9	7.0	1.2		SCM	41/41	0		51/45	13.0	0.50		15	0.02
13								6.9	7.0	0.9		SCM	41/41	0		51/45	13.0	0.50		12 1/2	0.02
14								6.9	7.0	1.4		SCM	41/41	0		51/45	13.0	0.50		18 1/2	0.02
15								6.9	7.0	1.2		SCM	41/41	0		51/45	13.0	0.40		16 3/4	0.02
16								6.9	7.0	1.5		SCM	41/41	1		51/45	14.0	0.40		15 1/2	0.02
17								6.8	7.0	3.0		SCM	41/41	0		51/45	15.0	0.60		19 1/4	0.02
18								6.8	7.0	4.6		SCM	41/41	0		51/45	15.0	0.60		17 1/4	0.02
19								6.7	7.0	7.3		SCM	41/41	0		51/45	15.0	0.70		15	0.02
20								6.9	7.0	0.4		SCM	41/41	0		51/45	14.0	0.30		13 1/2	0.02
21								6.9	7.0	0.4		SCM	41/41	0		51/45	14.0	0.70		11	0.02
22								6.9	7.0	1.2		SCM	41/41	0		51/45	14.0	0.70		16 1/4	0.03
23								6.9	7.0	1.5		SCM	41/41	0		51/45	14.0	0.60		13 3/4	0.02
24								6.7	7.0	1.1		SCM	41/41	0		51/45	15.0	0.70		18 1/2	0.02
25								6.7	7.1	1.6		SCM	41/41	0		51/45	15.0	0.80		17	0.02
26								6.7	7.0	7.0		SCM	41/41	1		51/45	20.0	0.90		15 1/2	0.02
27								6.8	7.0	3.5		SCM	41/41	0		51/45	20.0	0.90		14	0.02
28								6.8	7.0	3.7		SCM	41/41	0		51/45	21.0	0.10		119 1 1/2	0.02
29								6.8	7.0	3.3		SCM	41/41	0		51/45	22.0	0.20		17 3/4	0.02
30								6.9	7.0	3.9		SCM	41/41	0		51/45	20.0	0.20		18	0.02

Data Meters
Drinking Water Program

DE
11/20/02