

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS
Conventional or Direct Filtration**

System Name: COQUILLE, CITY OF ID:OR4100213 WTP-:WTP-A **Month/Year:** Jun-24

| DAY | 12 AM [NTU] | 4 AM [NTU] | 8 AM [NTU] | NOON [NTU] | 4 PM [NTU] | 8 PM [NTU] | Highest Reading of the Day ¹ [NTU] |
|-----|-------------|------------|------------|------------|------------|------------|-----------------------------------------------|
| 1 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 2 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 3 | NR | NR | 0.02 | 0.02 | 0.03 | NR | 0.03 |
| 4 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 5 | NR | NR | 0.02 | 0.02 | 0.03 | NR | 0.03 |
| 6 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 7 | NR | NR | 0.02 | 0.02 | 0.02 | 0.02 | 0.02 |
| 8 | NR | NR | 0.03 | 0.03 | 0.02 | NR | 0.02 |
| 9 | NR | NR | 0.03 | 0.03 | 0.03 | NR | 0.03 |
| 10 | NR | NR | 0.03 | 0.04 | 0.04 | 0.04 | 0.04 |
| 11 | NR | NR | 0.04 | 0.05 | 0.05 | NR | 0.05 |
| 12 | NR | NR | 0.05 | 0.02 | 0.02 | NR | 0.05 |
| 13 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 14 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 15 | NR | NR | 0.02 | 0.03 | NR | NR | 0.03 |
| 16 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 17 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 18 | NR | NR | 0.02 | 0.03 | 0.02 | NR | 0.03 |
| 19 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 20 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 21 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 22 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 23 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 24 | NR | NR | NR | 0.02 | 0.02 | 0.02 | 0.02 |
| 25 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 26 | NR | NR | 0.02 | 0.02 | NR | NR | 0.02 |
| 27 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 28 | NR | NR | 0.03 | 0.02 | 0.02 | NR | 0.02 |
| 29 | NR | NR | 0.02 | 0.02 | 0.02 | NR | 0.02 |
| 30 | NR | NR | 0.02 | 0.02 | 0.02 | 0.02 | 0.02 |

| Conventional or Direct Filtration | Monthly Summary (Answer Yes or No) | |
|----------------------------------------------------------------------------------|-----------------------------------------------|-------------------------------------------------------------------------|
| 95% of the 4 hour turbidity readings ≤ 0.3 NTU? <i>Yes</i> / No | CT's met everyday? (see back) <i>Yes</i> / No | All Cl ₂ residual at entry point ≥ 0.2 mg/l? <i>Yes</i> / No |
| All the 4 hour turbidity readings ≤ 1 NTU? <i>Yes</i> / No | | |
| All turbidity readings ≤ IFE ² triggers? <i>Yes</i> / No ² | | |
| | <i>Gary Dagitt</i> | |
| | <i>Gary Dagitt</i> | DATE: <i>7/2/24</i> |
| | PHONE #: <i>(541) 396-4614</i> | CERT #: <i>09435</i> |

OHA - Drinking Water Program - Surface Water Quality Data Form

COQUILLE, CITY OF ID #: OR4100213 WTP-: WTP-A Month/Year: Jun-24 Required Log Inactivation: 0.5

| Date / Time | Residual At 1 st User (C) ³ | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ³ | Peak Hourly Demand Flow |
|-------------|---------------------------------------------------|------------------|-----------|-------|------|-------------|----------------------|-------------------------|
| | [ppm or mg/l] | [minutes] | C x T | [° C] | S.U. | Formula | Yes / No | [GPM] |
| 1/ 9:25 | 1.2 | 48 | 48 | 15.0 | 7.1 | 14 | Yes | 960 |
| 2/ 9:45 | 0.9 | 48 | 43 | 15.0 | 7.0 | 13 | Yes | 990 |
| 3/ 8:15 | 1.0 | 48 | 48 | 14.0 | 7.0 | 15 | Yes | 970 |
| 4/ 8:30 | 1.0 | 48 | 48 | 14.0 | 7.0 | 15 | Yes | 970 |
| 5/ 8:20 | 0.9 | 48 | 43 | 15.0 | 7.0 | 13 | Yes | 1000 |
| 6/ 8:30 | 1.1 | 48 | 53 | 15.0 | 7.0 | 14 | Yes | 1000 |
| 7/ 8:30 | 1.0 | 48 | 48 | 15.0 | 7.0 | 14 | Yes | 980 |
| 8/ 9:30 | 1.6 | 48 | 77 | 14.0 | 7.0 | 16 | Yes | 970 |
| 9/ 9:10 | 1.5 | 48 | 72 | 15.0 | 7.0 | 14 | Yes | 990 |
| 10/ 8:30 | 1.9 | 48 | 91 | 15.0 | 7.0 | 15 | Yes | 1020 |
| 11/ 8:20 | 1.2 | 48 | 58 | 15.0 | 7.0 | 14 | Yes | 1100 |
| 12/ 8:00 | 1.2 | 48 | 58 | 17.0 | 7.0 | 12 | Yes | 1100 |
| 13/ 9:30 | 2.5 | 48 | 120 | 18.0 | 7.0 | 13 | Yes | 1090 |
| 14/ 11:00 | 1.1 | 48 | 53 | 19.0 | 7.0 | 11 | Yes | 1090 |
| 15/ 9:30 | 2.2 | 48 | 106 | 19.0 | 7.0 | 12 | Yes | 1090 |
| 16/ 9:00 | 2.1 | 48 | 101 | 19.0 | 7.0 | 12 | Yes | 1100 |
| 17/ 8:15 | 0.8 | 48 | 38 | 19.0 | 7.0 | 10 | Yes | 1100 |
| 18/ 8:30 | 0.9 | 48 | 43 | 19.0 | 7.0 | 10 | Yes | 1090 |
| 19/ 7:15 | 0.4 | 48 | 19 | 19.0 | 7.0 | 10 | Yes | 1090 |
| 20/ 8:30 | 0.9 | 48 | 43 | 18.0 | 7.0 | 11 | Yes | 1090 |
| 21/ 8:20 | 0.9 | 48 | 43 | 19.0 | 7.0 | 10 | Yes | 1090 |
| 22/ 9:30 | 2.2 | 48 | 106 | 19.0 | 7.0 | 12 | Yes | 1100 |
| 23/ 9:00 | 1.5 | 48 | 72 | 19.0 | 7.1 | 11 | Yes | 1100 |
| 24/ 9:00 | 0.9 | 48 | 43 | 19.0 | 7.0 | 10 | Yes | 1105 |
| 25/ 8:15 | 1.0 | 48 | 48 | 20.0 | 7.0 | 10 | Yes | 1120 |
| 26/ 8:15 | 0.9 | 48 | 43 | 21.0 | 7.0 | 9 | Yes | 1120 |
| 27/ 8:25 | 0.9 | 48 | 43 | 21.0 | 7.0 | 9 | Yes | 1100 |
| 28/ 8:30 | 1.6 | 48 | 77 | 21.0 | 7.0 | 10 | Yes | 1110 |
| 29/ 9:15 | 1.1 | 48 | 53 | 21.0 | 7.0 | 9 | Yes | 1110 |
| 30/ 10:00 | 2.1 | 48 | 101 | 22.0 | 7.0 | 10 | Yes | 1125 |
| | | | | | | | | |

Month / Year : Jun-24

City of Coquille Daily Chlorine and pH Report

| Day | CL 2 | | | | | | pH | | | | | Hours of Operation | | | | CL17 Analyzer Reading | Alkalinity | | | | |
|-----|------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------------|-----|-----|-----|-----------------------|------------|-----------|------|-------|------|
| | 2 | 3 | 4 | 5 | 6 | 7 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | | | Plant Hrs | R.C. | River | |
| | | | | | | | | | | | | | | | | | | | | | |
| 1 | 1.2 | 1.1 | 0.9 | 0.9 | 0.9 | 0.9 | 7.1 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 690.5 | 9.0 | x | | 1.23 | |
| 2 | 0.9 | 1.0 | 1.0 | 0.9 | 0.9 | 0.9 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 699.5 | 9.1 | x | | 1.19 | |
| 3 | 1.0 | 0.5 | 0.9 | 1.1 | 1.1 | 1.1 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 708.6 | 7.5 | x | | 1.16 | 10.0 |
| 4 | 1.0 | 0.9 | 0.9 | 1.0 | 1.0 | 1.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 719.1 | 14.5 | x | | 1.18 | |
| 5 | 0.9 | 0.7 | 0.9 | 0.9 | 0.9 | 0.9 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 730.6 | 10.4 | x | | 1.18 | |
| 6 | 1.1 | 1.0 | 0.9 | 0.9 | 0.9 | 0.9 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 741.0 | 9.4 | x | | 1.20 | |
| 7 | 1.0 | 1.1 | 0.7 | 1.3 | 1.3 | 1.3 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 750.4 | 13.3 | x | | 1.25 | |
| 8 | 1.6 | 1.0 | 1.1 | 0.9 | 0.9 | 0.9 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 763.7 | 8.7 | x | | 1.55 | |
| 9 | 1.5 | 1.3 | 0.9 | 1.2 | 1.2 | 1.2 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 772.4 | 10.3 | x | | 1.96 | |
| 10 | 1.9 | 1.4 | 1.2 | 1.3 | 1.3 | 1.3 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 782.7 | 13.5 | x | | 1.86 | 15.0 |
| 11 | 1.2 | 1.2 | 1.0 | 0.9 | 0.9 | 0.9 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 792.2 | 8.5 | | x | 1.72 | |
| 12 | 1.2 | 1.3 | 1.0 | 0.7 | 0.7 | 0.7 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 804.7 | 12.1 | | x | 1.03 | |
| 13 | 2.5 | 1.2 | 2.3 | 2.0 | 2.0 | 2.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 816.8 | 11.0 | | x | 1.30 | |
| 14 | 1.1 | 0.6 | 1.0 | 1.0 | 1.0 | 1.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 827.8 | 6.8 | | x | 1.50 | |
| 15 | 2.2 | 1.8 | 1.7 | 2.1 | 2.1 | 2.1 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 834.6 | 7.2 | | x | 1.47 | |
| 16 | 2.1 | 1.7 | 2.0 | 2.0 | 2.0 | 2.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 841.8 | 8.3 | | x | 1.39 | |
| 17 | 0.8 | 0.6 | 0.8 | 0.9 | 0.9 | 0.9 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 850.1 | 11.9 | | x | 1.04 | 20.0 |
| 18 | 0.9 | 0.7 | 0.6 | 0.9 | 0.9 | 0.9 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 862.0 | 11.0 | | x | 1.31 | |
| 19 | 0.4 | 0.6 | 1.1 | 1.3 | 1.3 | 1.3 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 873.0 | 8.9 | | x | 1.24 | |
| 20 | 0.9 | 0.6 | 0.7 | 0.8 | 0.8 | 0.8 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 881.9 | 11.3 | | x | 1.30 | |
| 21 | 0.9 | 0.6 | 0.6 | 0.8 | 0.8 | 0.8 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 893.2 | 9.4 | | x | 1.31 | |
| 22 | 2.2 | 1.7 | 1.4 | 1.6 | 1.6 | 1.6 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 902.6 | 8.8 | | x | 1.37 | |
| 23 | 1.5 | 1.7 | 1.3 | 1.5 | 1.5 | 1.5 | 7.1 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 911.4 | 8.5 | | x | 1.29 | |
| 24 | 0.9 | 0.9 | 0.6 | 0.7 | 0.7 | 0.7 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 919.9 | 12.7 | | x | 1.14 | 25.0 |
| 25 | 1.0 | 0.8 | 0.6 | 0.6 | 0.6 | 0.6 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 932.6 | 10.4 | | x | 1.29 | |
| 26 | 0.9 | 0.6 | 0.6 | 0.6 | 0.6 | 0.6 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 943.0 | 10.0 | | x | 1.26 | |
| 27 | 0.9 | 0.6 | 0.4 | 0.6 | 0.6 | 0.6 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 953.0 | 10.6 | | x | 1.19 | |
| 28 | 1.6 | 1.6 | 1.4 | 1.3 | 1.3 | 1.3 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 963.6 | 12.4 | | x | 1.30 | |
| 29 | 1.1 | 1.4 | 1.3 | 1.0 | 1.0 | 1.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 976.0 | 10.1 | | x | 1.33 | |
| 30 | 2.1 | 1.6 | 1.2 | 0.9 | 0.9 | 0.9 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 986.1 | 18.8 | | x | 1.35 | |

Sample Points _____

Final Water Tap _____

MGRES _____

Sewage Plant _____

314.4

16,087 Million Gallons

n/a Pounds

n/a Pounds

n/a Pounds

100 Pounds

2,936 Million Pounds

9.8

Daily Fluoride, Production & Chlorination Report

Water System: City of Coquille

Number of Services: 1,806 Population Served: 3866

Chlorine Product Used: NaOCL Strength: 0.80%

Make & Type of Chlorinator: W & T OSC

Month / Year : Jun-24

Source of Water: Rink Creek/ Coquille River

Free Chlorine Residual Tests
 Test Method: DPD
 2. Knowlton Heights
 3. WWTP, Sink Tap
 4. Steel Tank
 5. Random Point - Oerding Hts

| Day of Month | Reading Gallons | Daily Water Production | Finished Water Fluoride MG/L | SP #2 | SP #3 | SP #4 | SP #5 | Remarks |
|--------------|-----------------|------------------------|------------------------------|-------|-------|-------|-------|---------|
| | | | | PPM | PPM | PPM | PPM | |
| 1 | Calculated | 518 | 0.27 | 1.2 | 1.1 | 0.9 | 0.9 | |
| 2 | " " | 535 | 0.30 | 0.9 | 1.0 | 1.0 | 0.9 | |
| 3 | " " | 437 | 0.22 | 1.0 | 0.5 | 0.9 | 1.1 | |
| 4 | " " | 844 | 0.22 | 1.0 | 0.9 | 0.9 | 1.0 | |
| 5 | " " | 624 | 0.34 | 0.9 | 0.7 | 0.9 | 0.9 | |
| 6 | " " | 564 | 0.33 | 1.1 | 1.0 | 0.9 | 0.9 | |
| 7 | " " | 782 | 0.42 | 1.0 | 1.1 | 0.7 | 1.3 | |
| 8 | " " | 506 | 0.66 | 1.6 | 1.0 | 1.1 | 0.9 | |
| 9 | " " | 612 | 0.35 | 1.5 | 1.3 | 0.9 | 1.2 | |
| 10 | " " | 826 | 0.38 | 1.9 | 1.4 | 1.2 | 1.3 | |
| 11 | " " | 561 | 0.38 | 1.2 | 1.2 | 1.0 | 0.9 | |
| 12 | " " | 799 | 0.42 | 1.2 | 1.3 | 1.0 | 0.7 | |
| 13 | " " | 726 | 0.32 | 2.5 | 1.2 | 2.3 | 2.0 | |
| 14 | " " | 445 | 0.39 | 1.1 | 0.6 | 1.0 | 1.0 | |
| 15 | " " | 471 | 0.29 | 2.2 | 1.8 | 1.7 | 2.1 | |
| 16 | " " | 543 | 0.22 | 2.1 | 1.7 | 2.0 | 2.0 | |
| 17 | " " | 785 | 0.25 | 0.8 | 0.6 | 0.8 | 0.9 | |
| 18 | " " | 719 | 0.21 | 0.9 | 0.7 | 0.6 | 0.9 | |
| 19 | " " | 582 | 0.16 | 0.4 | 0.6 | 1.1 | 1.3 | |
| 20 | " " | 739 | 0.17 | 0.9 | 0.6 | 0.7 | 0.8 | |
| 21 | " " | 65 | 0.23 | 0.9 | 0.6 | 0.6 | 0.8 | |
| 22 | " " | 581 | 0.32 | 2.2 | 1.7 | 1.4 | 1.6 | |
| 23 | " " | 561 | 0.29 | 1.5 | 1.7 | 1.3 | 1.5 | |
| 24 | " " | 842 | 0.29 | 0.9 | 0.9 | 0.6 | 0.7 | |
| 25 | " " | 699 | 0.26 | 1.0 | 0.8 | 0.6 | 0.6 | |
| 26 | " " | 672 | 0.29 | 0.9 | 0.6 | 0.6 | 0.6 | |
| 27 | " " | 700 | 0.33 | 0.9 | 0.6 | 0.4 | 0.6 | |
| 28 | " " | 826 | 0.35 | 1.6 | 1.6 | 1.4 | 1.3 | |
| 29 | " " | 673 | 0.43 | 1.1 | 1.4 | 1.3 | 1.0 | |
| 30 | | 1269 | 0.42 | 2.1 | 1.6 | 1.2 | 0.9 | |

City of Coquille Water Plant Report

Jun-24

| RAW WATER | | | | PH | | TURBIDITY | | ISOPAC 835 | | FLOURIDE | | SODA ASH | | | | | |
|-----------|-----------|----------------|-------|------|-----|-----------|-----------|------------|-----------------|----------------|-----------|----------|-----------------|----------------|-------------------------|----------------------|------------------------------|
| Date | River MGD | Rink Creek MGD | Post | Salt | RAW | Final | Raw Water | mL / Min | Machine Setting | Speed / Stroke | Bags Used | mL / Min | Machine Setting | Temperature °C | Settled Water Turbidity | Soda Ash Tank Inches | Highest Turbidity of the Day |
| 1 | | 0.518 | 50/55 | 1 | 6.4 | 7.1 | 4.0 | 40 | SCM | 41/41 | 0 | 53 | 51/45 | 13.0 | 0.30 | 24 | 0.02 |
| 2 | | 0.535 | 50/55 | 1 | 6.6 | 7.0 | 4.8 | | SCM | 41/41 | 0 | | 51/45 | 14.0 | 0.10 | 19 1/2 | 0.02 |
| 3 | | 0.437 | 50/55 | 1 | 6.4 | 7.0 | 4.6 | | SCM | 41/41 | 0 | | 51/45 | 14.0 | 0.10 | 24 1/2 | 0.03 |
| 4 | | 0.844 | 50/55 | 1 | 6.4 | 7.0 | 5.0 | | SCM | 41/41 | 0 | | 51/45 | 14.0 | 0.20 | 28 | 0.02 |
| 5 | | 0.624 | 50/55 | 1 | 6.3 | 7.0 | 5.4 | | SCM | 41/41 | 0 | | 51/45 | 14.0 | 0.10 | 23 3/4 | 0.03 |
| 6 | | 0.564 | 50/55 | 1 | 6.3 | 7.0 | 7.5 | | SCM | 41/41 | 0 | | 51/45 | 14.0 | 0.10 | 21 1/2 | 0.02 |
| 7 | | 0.782 | 50/55 | 1 | 6.3 | 7.0 | 6.3 | | SCM | 41/41 | 0 | | 51/45 | 14.0 | 0.10 | 18 | 0.02 |
| 8 | | 0.506 | 50/55 | 1 | 6.0 | 7.0 | 6.0 | | SCM | 41/41 | 0 | | 51/45 | 14.0 | 0.10 | 22 1/2 | 0.02 |
| 9 | | 0.612 | 50/55 | 1 | 5.8 | 7.0 | 4.1 | | SCM | 41/41 | 0 | | 51/45 | 14.0 | 0.80 | 18 1/2 | 0.03 |
| 10 | | 0.826 | 50/55 | 0 | 6.0 | 7.0 | 4.2 | | SCM | 41/41 | 0 | | 51/45 | 14.0 | 0.80 | 22 3/4 | 0.04 |
| 11 | | 0.561 | 50/55 | 1 | 6.3 | 7.0 | 2.8 | | SCM | 41/41 | 0 | | 51/45 | 15.0 | 0.20 | 27 | 0.05 |
| 12 | | 0.799 | 50/55 | 1 | 6.8 | 7.0 | 2.9 | | SCM | 41/41 | 0 | | 51/45 | 21.0 | 0.20 | 24 1/2 | 0.05 |
| 13 | | 0.726 | 50/55 | 1 | 6.1 | 7.0 | 9.6 | | SCM | 41/41 | 0 | | 51/45 | 20.0 | 0.20 | 21 1/2 | 0.02 |
| 14 | | 0.445 | 50/55 | 1 | 6.3 | 7.0 | 6.1 | | SCM | 41/41 | 0 | | 51/45 | 20.0 | 0.30 | 18 1/2 | 0.02 |
| 15 | | 0.471 | 50/55 | 0 | 6.6 | 7.0 | 2.9 | | SCM | 41/41 | 0 | | 51/45 | 20.0 | 0.20 | 15 | 0.03 |
| 16 | | 0.543 | 50/55 | 1 | 6.5 | 7.0 | 2.1 | | SCM | 41/41 | 0 | | 51/45 | 20.0 | 0.30 | 20 3/4 | 0.02 |
| 17 | | 0.785 | 50/55 | 0 | 6.9 | 7.0 | 3.8 | | SCM | 41/41 | 1 | | 51/45 | 19.0 | 0.50 | 18 1/2 | 0.02 |
| 18 | | 0.719 | 50/55 | 1 | 6.9 | 7.0 | 3.6 | | SCM | 41/41 | 0 | | 51/45 | 18.0 | 0.70 | 24 | 0.03 |
| 19 | | 0.582 | 50/55 | 1 | 6.8 | 7.0 | 4.4 | | SCM | 41/41 | 0 | | 51/45 | 18.0 | 0.40 | 22 | 0.02 |
| 20 | | 0.739 | 50/55 | 1 | 6.8 | 7.0 | 3.1 | | SCM | 41/41 | 0 | | 51/45 | 19.0 | 0.80 | 19 1/2 | 0.02 |
| 21 | | 0.615 | 50/55 | 1 | 6.8 | 7.0 | 4.0 | | SCM | 41/41 | 0 | | 51/45 | 20.0 | 0.70 | 16 1/2 | 0.02 |
| 22 | | 0.581 | 50/55 | 1 | 6.4 | 7.0 | 4.6 | | SCM | 41/41 | 0 | | 51/45 | 20.0 | 0.60 | 22 | 0.02 |
| 23 | | 0.561 | 50/55 | 1 | 6.5 | 7.1 | 5.4 | | SCM | 41/41 | 0 | | 51/45 | 21.0 | 0.40 | 18 1/2 | 0.02 |
| 24 | | 0.842 | 50/55 | 0 | 6.8 | 7.0 | 2.7 | | SCM | 41/41 | 0 | | 51/45 | 19.0 | 0.20 | 16 1/2 | 0.02 |
| 25 | | 0.699 | 50/55 | 0 | 6.8 | 7.0 | 3.6 | | SCM | 41/41 | 0 | | 51/45 | 21.0 | 0.50 | 31 | 0.02 |
| 26 | | 0.672 | 50/55 | 1 | 6.8 | 7.0 | 4.6 | | SCM | 41/41 | 0 | | 51/45 | 22.0 | 0.40 | 28 1/2 | 0.02 |
| 27 | | 0.700 | 50/55 | 0 | 6.8 | 7.0 | 4.5 | | SCM | 41/41 | 0 | | 51/45 | 21.0 | 0.30 | 25 1/4 | 0.02 |
| 28 | | 0.826 | 50/55 | 1 | 6.5 | 7.0 | 4.5 | | SCM | 41/41 | 0 | | 51/45 | 21.0 | 0.40 | 24 | 0.02 |
| 29 | | 0.673 | 50/55 | 1 | 6.4 | 7.0 | 5.3 | | SCM | 41/41 | 0 | | 51/45 | 22.0 | 0.50 | 23 | 0.02 |
| 30 | | 1.269 | 50/55 | 1 | 6.5 | 7.0 | 5.1 | | SCM | 41/41 | 0 | | 51/45 | 22.0 | 0.40 | 21 | 0.02 |