

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS
Conventional or Direct Filtration**

System Name: COQUILLE, CITY OF ID:OR4100213 WTP:-WTP-A Month/Year: Jan-25

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	NR	NR	NR	NR	NR	NR	
2	NR	NR	0.02	0.02	0.02	NR	0.02
3	NR	NR	0.02	0.02	NR	NR	0.02
4	NR	NR	0.02	0.02	NR	NR	0.02
5	NR	NR	0.02	0.02	0.02	NR	0.02
6	NR	NR	0.02	0.02	NR	NR	0.02
7	NR	NR	0.02	0.02	0.02	NR	0.03
8	NR	NR	0.03	0.03	NR	NR	0.02
9	NR	NR	0.02	0.02	NR	NR	0.02
10	NR	NR	0.02	0.02	NR	NR	0.02
11	NR	NR	0.02	0.02	0.02	NR	0.02
12	NR	0.02	0.02	0.02	NR	NR	0.02
13	NR	NR	0.02	0.02	0.02	NR	0.02
14	NR	NR	0.02	0.02	0.02	NR	0.02
15	NR	NR	0.02	0.02	0.02	NR	0.03
16	NR	0.03	NR	NR	NR	NR	0.02
17	NR	NR	0.02	0.02	0.03	NR	0.02
18	NR	NR	0.02	0.02	0.06	NR	0.02
19	NR	NR	0.02	0.02	0.05	NR	0.02
20	NR	NR	0.02	0.02	NR	NR	0.02
21	NR	NR	0.02	0.02	0.02	NR	0.02
22	NR	NR	0.02	0.02	NR	NR	0.02
23	NR	NR	0.02	0.02	NR	NR	0.02
24	NR	NR	0.02	0.02	0.02	NR	0.02
25	NR	NR	0.02	0.02	NR	NR	0.02
26	NR	NR	0.02	0.02	0.02	NR	0.02
27	NR	NR	0.03	0.02	0.03	NR	0.02
28	NR	NR	0.02	0.03	0.02	NR	0.02
29	NR	NR	0.02	0.02	0.02	NR	0.02
30	NR	NR	0.02	0.02	0.02	NR	0.02
31	NR	NR	0.02	0.02	0.02	NR	0.02

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All the 4 hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No		
All turbidity readings ≤ IFE ² triggers? <input checked="" type="radio"/> Yes / No ²		
	<i>Gary Dagit</i>	
	<i>Gary Dagit</i>	
	PHONE #: (541) 396-4614	DATE: 2/4/25
		CERT #: 09435

OHA - Drinking Water Program - Surface Water Quality Data Form

COQUILLE, CITY OF ID #: OR4100213 WTP-: WTP-A

Month/Year: Jan-25

Required Log Inactivation: 0.5

Date / Time	Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1/ NR								
2/ 8:20	2.1	48	101	11.0	7.1	21	Yes	1010
3/ 8:30	1.1	48	53	11.0	7.1	19	Yes	1015
4/ 9:30	1.3	48	62	12.0	7.2	19	Yes	985
5/ 9:15	1.2	48	58	11.0	7.1	19	Yes	1015
6/ 8:30	1.1	48	53	11.0	7.1	19	Yes	1000
7/ 8:20	1.7	48	82	11.0	7.0	20	Yes	1010
8/ 8:15	1.5	48	72	11.0	7.1	20	Yes	1015
9/ 8:30	1.9	48	91	11.0	7.0	20	Yes	1020
10/ 8:15	1.5	48	72	10.0	7.0	20	Yes	1015
11/ 9:15	1.3	48	62	11.0	7.1	19	Yes	1020
12/ 8:50	1.0	48	48	10.0	7.0	19	Yes	1020
13/ 8:20	1.1	48	53	11.0	7.1	19	Yes	1025
14/ 8:00	1.1	48	53	10.0	7.1	20	Yes	1025
15/ 8:20	1.3	48	62	10.0	7.1	21	Yes	1020
16/ 8:30	1.1	48	53	10.0	7.1	20	Yes	1025
17/ 8:30	1.2	48	58	9.0	7.1	22	Yes	1015
18/ 9:00	1.2	48	58	10.0	7.1	20	Yes	1030
19/ 9:15	1.4	48	67	10.0	7.1	21	Yes	1030
20/ 9:15	1.1	48	53	10.0	7.1	20	Yes	1030
21/ 8:30	1.1	48	53	10.0	7.0	20	Yes	1030
22/ 8:30	1.2	48	58	9.0	7.1	22	Yes	1035
23/ 8:30	1.3	48	62	9.0	7.1	22	Yes	1030
24/ 8:15	1.5	48	72	9.0	7.1	23	Yes	1025
25/ 9:15	1.4	48	67	9.0	7.1	22	Yes	1030
26/ 10:00	1.4	48	67	10.0	7.1	21	Yes	1030
27/ 8:30	1.3	48	62	9.0	7.1	22	Yes	1035
28/ 8:15	1.3	48	62	8.0	7.1	24	Yes	10354
29/ 8:15	1.2	48	58	8.0	7.1	23	Yes	1035
30/ 8:45	1.3	48	62	8.0	7.1	24	Yes	1025
31/ 8:30	1.1	48	53	9.0	7.1	22	Yes	1010

Daily Fluoride, Production & Chlorination Report

Water System: City of Coquille

Number of Services: 1,806 Population Served: 3866

Chlorine Product Used: NaOCL Strength: 0.80%

Make & Type of Chlorinator: W & T OSC

Month / Year : Jan-25	Free Chlorine Residual Tests Test Method: DPD 2. Knowlton Heights 3. WWTP, Sink Tap 4. Steel Tank 5. Random Point - Oerding Hts
Source of Water: <u>Rink Creek Res.</u>	

Day of Month	Reading Gallons	Daily Water Production	Finished Water Fluoride MG/L	Free Chlorine Residual Tests				Remarks
				SP #2	SP #3	SP #4	SP #5	
				PPM	PPM	PPM	PPM	
1	Calculated							
2	" "	509	0.60	2.1	1.3	1.3	1.9	
3	" "	505	0.58	1.1	1.2	1.0	1.7	
4	" "	573	0.52	1.3	1.2	1.1	1.1	
5	" "	445	0.41	1.2	1.2	1.1	1.2	
6	" "	402	0.40	1.1	1.0	0.9	1.4	
7	" "	467	0.84	1.7	1.0	0.9	1.5	
8	" "	713	0.65	1.5	1.1	0.6	1.3	
9	" "	532	0.63	1.9	1.4	1.0	2.2	
10	" "	451	1.00	1.5	1.2	1.0	1.2	
11	" "	869	0.75	1.3	1.0	0.9	1.4	
12	" "	318	0.63	1.0	1.0	0.9	1.2	
13	" "	394	0.55	1.1	1.0	0.9	1.1	
14	" "	541	0.54	1.1	0.7	1.0	1.5	
15	" "	630	0.63	1.3	1.0	1.0	1.4	
16	" "	326	0.59	1.1	1.0	0.5	1.3	
17	" "	481	0.56	1.2	1.0	0.9	1.4	
18	" "	550	0.58	1.2	1.1	0.9	1.8	
19	" "	544	0.76	1.4	1.3	1.1	1.7	
20	" "	365	0.75	1.1	1.3	0.8	1.6	
21	" "	735	0.82	1.1	1.3	1.0	1.7	
22	" "	379	0.62	1.2	1.4	1.1	1.7	
23	" "	383	0.65	1.3	1.3	0.6	1.5	
24	" "	621	0.53	1.5	1.2	1.0	1.3	
25	" "	519	0.74	1.5	1.6	1.1	1.6	
26	" "	476	0.65	1.4	1.5	1.1	1.7	
27	" "	428	0.51	1.3	1.2	1.1	1.6	
28	" "	509	0.57	1.3	1.2	1.1	1.5	
29	" "	615	0.51	1.2	1.2	1.1	1.6	
30	" "	283	0.52	1.3	1.2	1.1	1.7	
31		490	0.58	1.1	1.2	1.1	1.6	

Month / Year : Jan-25

City of Coquille Daily Chlorine and pH Report

Day	CL ₂					pH					Hours of Operation			River	CL17 Analyzer Reading	Alkalinity	
	2	3	4	5		2	3	4	5		Reading	Plant Hrs	R.C.				
1																	
2	2.1	1.3	1.3	1.4		7.1	7.2	7.3			858.4	8.4	x			1.72	
3	1.1	1.2	1.0	0.6		7.1	7.2	7.3			866.8	8.3	x			1.86	
4	1.3	1.2	1.1	0.7		7.2	7.2	7.3			875.1	9.7	x			1.18	
5	1.2	1.2	1.1	0.6		7.1	7.2	7.3			884.8	7.3	x			1.25	
6	1.1	1.0	0.9	0.5		7.1	7.2	7.3			892.1	6.7	x			1.48	
7	1.7	1.0	0.9	0.6		7.0	7.1	7.2			898.8	7.7	x			1.52	
8	1.5	1.1	0.6	0.6		7.1	7.2	7.3			906.5	11.7	x			1.41	
9	1.9	1.5	1.0	0.9		7.0	7.1	7.2			918.2	8.7	x			2.15	
10	1.5	1.2	1.0	0.6		7.0	7.1	7.2			926.9	7.4	x			1.19	
11	1.3	1.0	0.9	0.7		7.1	7.2	7.3			934.3	14.2	x			1.40	
12	1.0	1.0	0.9	0.7		7.0	7.2	7.3			948.5	5.2	x			1.43	
13	1.1	1.0	0.9	0.5		7.1	7.2	7.3			953.7	6.4	x			1.12	
14	1.1	0.7	1.0	0.8		7.1	7.2	7.3			960.1	8.8	x			1.51	
15	1.3	1.0	1.0	0.7		7.1	7.2	7.3			968.9	10.3	x			1.31	
16	1.1	1.0	0.5	0.7		7.1	7.2	7.2			979.2	5.3	x			1.41	
17	1.2	1.0	0.9	0.7		7.1	7.2	7.3			984.5	7.9	x			1.32	
18	1.2	1.1	0.9	0.7		7.1	7.2	7.3			992.4	8.9	x			1.76	
19	1.4	1.3	1.1	0.7		7.1	7.2	7.2			1.3	8.8	x			1.75	
20	1.1	1.3	0.8	0.7		7.1	7.2	7.3			10.1	5.9	x			1.63	
21	1.1	1.3	1.0	0.7		7.0	7.1	7.2			16.0	11.9	x			1.77	
22	1.2	1.4	1.1	0.8		7.1	7.2	7.3			27.9	6.1	x			1.78	
23	1.3	1.3	0.6	0.3		7.1	7.2	7.3			34.0	6.2	x			1.76	
24	1.5	1.2	1.0	0.8		7.1	7.2	7.2			40.2	10.1	x			1.32	
25	1.4	1.6	1.1	0.7		7.1	7.2	7.3			50.3	8.4	x			1.55	
26	1.4	1.5	1.1	0.7		7.1	7.2	7.2			58.7	7.7	x			1.61	
	1.3	1.2	1.1	0.7		7.1	7.0	7.2			66.4	6.9	x			1.57	
28	1.3	1.2	1.1	0.7		7.1	7.2	7.2			73.3	8.2	x			1.49	
29	1.2	1.2	1.1	0.7		7.1	7.2	7.2			81.5	9.9	x			1.55	
30	1.3	1.2	1.1	0.9		7.1	7.2	7.2			91.4	4.6	x			1.60	
31	1.1	1.2	1.1	0.7		7.1	7.2	7.3			96.0	8.1	x			1.41	

Sample Points	245.7
Final Water Tap	16,087 Million Gallons
MGRES	n/a Pounds
Sewage Plant	n/a Pounds
	n/a Pounds
	100 Pounds
	2,936 Million Pounds
	9.8

City of Coquille Water Plant Report

RAW WATER		PH			TURBIDITY	ISOPAC 835	FLOURIDE			SODA ASH			Temperature °C	Settled Water Turbidity	Soda Ash Tank Inches	Highest Turbidity of the Day											
		RAW	Final	Raw Water			ml / Min	Machine Setting	Speed / Stroke	Bags Used	ml / Min	Machine Setting															
Date	River MGD	Rink Creek MGD	Scale Reading	Feed Rate ml / Min	Salt	Post	Scale Reading	Feed Rate ml / Min	Bags Used	Post	Scale Reading	Feed Rate ml / Min	Salt	RAW	Final	Turbidity	ISOPAC 835	Machine Setting	Speed / Stroke	Bags Used	ml / Min	Machine Setting	Temperature °C	Settled Water Turbidity	Soda Ash Tank Inches	Highest Turbidity of the Day	
1			50/55		0		50/55		0	40	SCM	41/41	0	53	51/45												
2		0.509	50/55		2		50/55		2	6.8	7.1	4.7														23	0.02
3		0.505	50/55		1		50/55		1	6.9	7.1	5.0														20 1/2	0.02
4		0.573	50/55		1		50/55		1	6.8	7.2	4.6														26 1/2	0.02
5		0.445	50/55		0		50/55		0	6.7	7.1	5.7														23 1/2	0.02
6		0.402	50/55		0		50/55		0	6.8	7.1	4.7														2	0.02
7		0.467	50/55		30		50/55		30	6.7	7.0	4.2														20	0.02
8		0.713	50/55		0		50/55		0	6.8	7.1	4.3														18	0.03
9		0.532	50/55		3		50/55		3	6.7	7.0	3.9														14 1/2	0.02
10		0.451	50/55		2		50/55		2	6.8	7.0	3.5														20	0.02
11		0.869	50/55		1		50/55		1	6.6	7.1	4.2														25 1/2	0.02
12		0.318	50/55		0		50/55		0	6.7	7.0	3.0														21 1/2	0.02
13		0.394	50/55		1		50/55		1	6.7	7.1	5.0														20	0.02
14		0.541	50/55		1		50/55		1	6.8	7.1	2.7														17	0.02
15		0.630	50/55		1		50/55		1	6.8	7.1	3.5														15 1/2	0.02
16		0.326	50/55		0		50/55		0	6.8	7.1	2.9														20	0.03
17		0.481	50/55		0		50/55		0	6.9	7.1	2.8														26 1/2	0.02
18		0.550	50/55		1		50/55		1	6.7	7.1	3.3														24	0.02
19		0.544	50/55		1		50/55		1	6.7	7.1	4.0														21	0.02
20		0.365	50/55		2		50/55		2	6.7	7.0	3.8														18 1/2	0.02
21		0.735	50/55		0		50/55		0	6.8	7.1	3.2														23 1/4	0.02
22		0.379	50/55		1		50/55		1	6.8	7.1	3.2														20	.2
23		0.383	50/55		1		50/55		1	6.8	7.1	3.1														18	0.02
24		0.621	50/55		1		50/55		1	6.9	7.1	3.5														16 1/4	0.02
25		0.519	50/55		0		50/55		0	6.7	7.1	4.3														21	0.02
26		0.476	50/55		1		50/55		1	6.7	7.1	5.2														19	0.02
27		0.428	50/55		1		50/55		1	6.8	7.1	6.6														17	0.02
28		0.509	50/55		1		50/55		1	6.8	7.1	2.1														15	0.02
29		0.615	50/55		0		50/55		0	6.8	7.1	2.4														20 1/2	0.02
30		0.283	50/55		1		50/55		1	6.8	7.1	2.0														26	.02
31		0.490	50/55		1		50/55		1	6.9	7.1	2.3														24 1/2	0.02