

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS
Conventional or Direct Filtration**

System Name: COQUILLE, CITY OF ID:OR4100213 WTP-:WTP-A Month/Year: Feb-25

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	NR	NR	0.02	0.02	NR	NR	0.02
2	NR	NR	0.02	0.02	0.02	NR	0.02
3	NR	NR	0.02	0.02	0.03	NR	0.03
4	NR	NR	0.02	0.02	NR	NR	0.02
5	NR	NR	0.02	0.02	NR	NR	0.02
6	NR	NR	0.02	0.02	0.02	NR	0.02
7	NR	NR	0.02	0.02	NR	NR	0.02
8	NR	NR	0.02	0.02	NR	NR	0.02
9	NR	NR	0.02	0.02	NR	NR	0.02
10	NR	NR	0.02	0.03	NR	NR	0.03
11	NR	NR	0.03	NR	NR	NR	0.03
12	NR	0.02	0.03	0.03	NR	NR	0.03
13	NR	NR	0.03	0.03	NR	NR	0.03
14	NR	NR	NR	0.02	0.02	NR	0.02
15	NR	NR	0.02	0.02	NR	NR	0.02
16	NR	0.03	0.02	0.02	NR	NR	0.02
17	NR	NR	0.02	0.04	0.04	NR	0.04
18	NR	NR	0.04	NR	NR	NR	0.04
19	NR	NR	0.03	0.03	NR	NR	0.03
20	NR	NR	0.03	0.03	NR	NR	0.03
21	NR	NR	0.04	0.02	NR	NR	0.04
22	NR	NR	0.02	0.02	NR	NR	0.02
23	NR	NR	0.02	0.03	0.02	NR	0.03
24	NR	NR	0.02	NR	NR	NR	0.03
25	NR	NR	0.02	0.02	0.02	NR	0.02
26	NR	NR	0.02	0.02	NR	NR	0.02
27	NR	NR	0.02	0.02	NR	NR	0.02
28	NR	NR	0.02	0.03	NR	NR	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / No	
All the 4 hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / No	Gary DeG. A DATE: 3/3/25 PHONE #: (541) 396-4614 CERT #: 9435		
All turbidity readings ≤ IFE ² triggers? <input checked="" type="radio"/> Yes / No ²			

City of Coquille Water Plant Report

RAW WATER		PH		TURBIDITY		ISOPAC 835		FLOURIDE		SODA ASH		Temperature °C	Settled Water Turbidity	Soda Ash Tank Inches	Highest Turbidity of the Day		
		RAW	Final	Raw Water	ml / Min	Machine Setting	Speed / Stroke	Bags Used	ml / Min	Machine Setting							
Date	River MGD	Rink Creek MGD	Post		Scale Reading	Feed Rate ml / Min	Bags Used	Salt	FLOURIDE		SODA ASH		Temperature °C	Settled Water Turbidity	Soda Ash Tank Inches	Highest Turbidity of the Day	
			RAW	Final					Machine Setting	Speed / Stroke	Bags Used	ml / Min					Machine Setting
1		0.514	50/55	0	6.7	7.1	2.7	40	SCM	41/41	0	53	51/45	9.0	0.01	22	0.02
2		0.588	50/55	2	6.7	7.1	2.5		SCM	41/41	0		51/45	8.0	0.01	19 1/2	0.02
3		0.519	50/55	1	6.9	7.2	2.8		SCM	41/41	1		51/45	7.0	0.01	17	0.03
4		0.447	50/55	1	6.8	7.2	2.4		SCM	41/41	0		51/45	7.0	0.01	15	0.02
5		0.538	50/55	1	6.9	7.2	2.4		SCM	41/41	0		51/45	8.0	0.01	21	0.02
6		0.658	50/55	1	6.9	7.2	2.3		SCM	41/41	0		51/45	7.0	0.01	19	0.02
7		0.519	50/55	1	6.9	7.1	2.6		SCM	41/41	0		51/45	7.0	0.01	25	0.02
8		0.466	50/55	1	6.9	7.1	3.4		SCM	41/41	0		51/45	8.0	0.01	23	0.02
9		0.404	50/55	1	6.8	7.1	3.3		SCM	41/41	0		51/45	7.0	0.01	21	0.02
10		0.447	50/55	0	6.8	7.2	3.7		SCM	41/41	0		51/45	7.0	0.01	19 1/2	0.03
11		0.371	50/55	1	6.9	7.2	1.7		SCM	41/41	0		51/45	7.0	0.01	17 1/2	0.03
12		0.418	50/55	1	6.8	7.0	2.0		SCM	41/41	0		51/45	8.0	0.01	24 1/2	0.03
13		0.357	50/55	0	6.9	7.1	2.4		SCM	41/41	1		51/45	7.0	0.01	23 1/2	0.03
14		0.697	50/55	1	6.6	7.0	2.2		SCM	41/41	0		51/45	8.0	0.01	22 1/2	0.02
15		0.320	50/55	1	6.6	7.0	3.3		SCM	41/41	0		51/45	7.0	0.01	27 1/2	0.02
16		0.367	50/55	0	6.8	7.2	3.7		SCM	41/41	0		51/45	7.0	0.01	26	0.02
17		0.363	50/55	1	6.8	7.0	4.1		SCM	41/41	0		51/45	8.0	0.01	24	0.04
18		0.330	50/55	1	6.8	7.0	1.7		SCM	41/41	0		51/45	8.0	0.01	21 1/2	0.04
19		0.541	50/55	1	6.7	7.0	23.8		SCM	41/41	0		51/45	8.0	0.01	20	0.03
20		0.453	50/55	1	6.8	7.0	1.6		SCM	41/41	0		51/45	7.0	0.01	17 1/2	0.03
21		0.361	50/55	0	6.7	7.0	2.2		SCM	41/41	0		51/45	8.0	0.01	23 1/2	0.04
22		0.428	50/55	0	7.1	7.2	2.0		SCM	41/41	0		51/45	8.0	0.01	21 1/2	0.02
23		0.727	50/55	2	6.7	7.1	2.0		SCM	41/41	0		51/45	9.0	0.01	19 1/2	0.03
24		0.311	50/55	1	6.7	7.0	2.5		SCM	41/41	0		51/45	8.0	0.01	18	0.03
25		0.615	50/55	0	6.8	7.0	2.8		SCM	41/41	0		51/45	8.0	0.01	22 1/2	0.02
26		0.402	50/55	1	6.6	7.0	2.9		SCM	41/41	1		51/45	9.0	0.01	19	0.02
27		0.430	50/55	1	6.7	7.0	2.9		SCM	41/41	0		51/45	8.0	0.01	16 1/2	0.02
28		0.521	50/55	1	6.6	7.0	2.9		SCM	41/41	0		51/45	8.0	0.01	21	0.03

Feb-25

