

JAN 11 2023

OHA - Drinking Water Services -Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: Coos  
Month/Year: Dec.2022

Certification  
Drinking Water Services

System Name: Garden Valley Water Dist. ID#: 41 00214 WTP: TP -

Table with 8 columns: Day, 12 AM [NTU], 4 AM [NTU], 8 AM [NTU], NOON [NTU], 4 PM [NTU], 8 PM [NTU], Highest Reading of the Day 1 [NTU]. Rows 1-31.

Conventional or Direct Filtration  
95% of 4-hour turbidity readings ≤ 0.3 NTU? Yes/No  
All 4-hour turbidity readings ≤ 1 NTU? Yes/No  
All turbidity readings < IFE<sup>2</sup> triggers Yes/No

Monthly Summary (Answer Yes or No)  
CT's met everyday? (see back) Yes/No  
All Cl<sub>2</sub> residual at entry point ≥ 0.2 mg/l? Yes/No

Boil water notice was handed out to all 28 members on the 24th and then on the 31st notice was given, that it safe to drink the water. We could not meet our turbidity standard because the BOPAC was not delivered. Safe water was determine by turbidity at end location. No

PRINTED NAME: Ryan H. Sherman  
SIGNATURE: [Signature]  
PHONE #: (541) 260-2936  
DATE: 1/6/23  
CERT #: 9189

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

RECEIVED  
JAN 11 2023

WTP - :

System Name: Garden Valley Water Dist.	ID#: 41	00214	Month/Year: Dec. 2022	Disinfection Log Inactive: <i>Giardia</i>	1
--	---------	-------	-----------------------	---	---

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Certification Drinking Water Services formula	CT Met? <sup>3</sup>	Peak Hourly Demand Flow [GPM]
	[ppm or mg/L]	[minutes]	C X T	[° C]			Yes / No	
1	1.1	45	49.5	8.0	7.20	47.7	YES	50
2	1.1	45	49.5	8.0	7.20	47.7	YES	50
3	1.3	45	58.5	10.0	7.20	42.8	YES	50
4	1.3	45	58.5	9.0	7.20	45.7	YES	50
5	1.2	45	54.0	9.0	7.30	46.8	YES	50
6	1	45	45.0	10.0	7.20	41.4	YES	50
7	1	45	45.0	10.0	7.20	41.4	YES	50
8	1.1	45	49.5	9.0	7.20	44.7	YES	50
9	1.1	45	49.5	9.0	7.20	44.7	YES	50
10	1.2	45	54.0	9.0	7.20	45.2	YES	50
11	1.2	45	54.0	8.0	7.30	50.0	YES	50
12	1.3	45	58.5	7.0	7.30	54.1	YES	50
13	1.3	45	58.5	9.0	7.30	47.4	YES	50
14	1.2	45	54.0	9.0	7.30	46.8	YES	50
15	1.3	45	58.5	10.0	7.20	42.8	YES	50
16	1.2	45	54.0	10.0	7.20	42.3	YES	50
17	1	45	45.0	9.0	7.20	44.2	YES	50
18	1.1	45	49.5	9.0	7.20	44.7	YES	50
19	1	45	45.0	9.0	7.20	44.2	YES	50
20	1.3	45	58.5	11.0	7.20	40.1	YES	50
21	1.3	45	58.5	12.0	7.20	37.6	YES	50
22	1.2	45	54.0	10.0	7.20	42.3	YES	50
23	1.3	45	58.5	13.0	7.20	34.7	YES	50
24	1	45	45.0	13.0	7.20	33.5	YES	50
25	1	45	45.0	13.0	7.20	33.5	YES	50
26	1.3	45	58.5	14.0	7.20	32.5	YES	50
27	1.3	45	58.5	13.0	7.20	34.7	YES	50
28	1.2	45	54.0	13.0	7.20	34.3	YES	50
29	1	45	45.0	13.0	7.20	33.5	YES	50
30	1.3	45	58.5	13.0	7.20	34.7	YES	50
31	1.2	45	54.0	13.0	7.20	34.3	YES	50

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:  
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350