

Garden Valley Water Dist.

ID#: 41

00214

WTP : TP -

12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
0.20	0.20	0.20	0.28	0.20	0.20	0.28
0.20	0.20	0.20	0.27	0.20	0.20	0.27
0.20	0.20	0.20	0.20	0.20	0.20	0.20
0.10	0.10	0.10	0.12	0.10	0.10	0.12
0.20	0.20	0.20	0.23	0.20	0.20	0.23
0.10	0.10	0.10	0.15	0.10	0.10	0.15
0.20	0.20	0.20	0.25	0.20	0.20	0.25
0.20	0.20	0.21	0.20	0.20	0.20	0.21
0.20	0.20	0.22	0.20	0.20	0.20	0.22
0.40	0.40	0.40	0.45	0.40	0.40	0.45
0.40	0.40	0.40	0.45	0.40	0.40	0.45
0.40	0.40	0.40	0.48	0.40	0.40	0.48
0.40	0.40	0.40	0.42	0.40	0.40	0.42
0.40	0.40	0.40	0.22	0.20	0.20	0.22
0.20	0.20	0.20	0.22	0.20	0.20	0.24
0.20	0.20	0.20	0.24	0.20	0.20	0.21
0.20	0.20	0.20	0.21	0.20	0.20	0.20
0.20	0.20	0.20	0.19	0.20	0.20	0.20
0.20	0.20	0.20	0.22	0.20	0.20	0.22
0.20	0.20	0.20	0.21	0.20	0.20	0.21
0.20	0.20	0.20	0.21	0.20	0.20	0.20
0.20	0.20	0.20	0.19	0.20	0.20	0.20
0.20	0.20	0.20	0.23	0.20	0.20	0.23
0.20	0.20	0.20	0.35	0.40	0.40	0.40
0.40	0.40	0.40	0.45	0.40	0.40	0.45
0.40	0.40	0.40	0.42	0.40	0.40	0.42
0.40	0.40	0.40	0.18	0.20	0.20	0.20
0.20	0.20	0.20	0.17	0.20	0.20	0.20
0.20	0.20	0.20	0.15	0.20	0.60	0.60
0.10	0.10	0.10	0.12	0.10	0.10	0.12
0.10	0.10	0.10	0.16	0.20	0.20	0.20
0.20	0.20	0.20	0.14	0.10	0.10	0.14
0.10	0.10	0.10	0.14	0.10	0.10	0.13
0.10	0.10	0.10	0.13	0.10	0.10	0.13

Conventional or Direct Filtration

of 4-hour turbidity readings ≤ 0.3 NTU? Yes / No

4-hour turbidity readings ≤ 1 NTU? Yes / No

All turbidity readings $< IFE^2$ triggers Yes / No

... was handed out to all 28 members on the 24th and then ...
 ... was given, that it safe to drink the water. We could not
 ... standard because the ISOPAC was not delivered. Safe water
 ... by turbidity at end location.

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) Yes / No

All Cl2 residual at entry point ≥ 0.2 mg/l? Yes / No

PRINTED NAME: _____

SIGNATURE: _____

PHONE #: () _____

DATE: _____

CERT # _____

Compliance values in columns 12 AM through 8 PM may not

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Garden Valley Water Dist. ID#: 41 00214 Month/Year: Mar-23 WTP - :
 Disinfection Giardia Log Inactive: 1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³ [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	i formula	CT Met? ³ Yes / No	Peak Hourly Demand Flow [GPM]
1	1.2	45	54.0	9.0	7.20	45.2	YES	50
2	1.2	45	54.0	10.0	7.20	42.3	YES	50
3	1.3	45	58.5	10.0	7.20	42.8	YES	50
4	1.3	45	58.5	8.0	7.30	42.8	YES	50
5	1.3	45	54.0	10.0	7.20	50.6	YES	50
6	1.2	45	54.0	10.0	7.20	42.3	YES	50
7	1.2	45	76.5	10.0	7.20	42.3	YES	50
8	1.7	45	76.5	10.0	7.20	44.8	YES	50
9	1.7	45	76.5	10.0	7.20	44.8	YES	50
10	1.7	45	72.0	10.0	7.20	44.3	YES	50
11	1.6	45	63.0	10.0	7.20	43.3	YES	50
12	1.4	45	67.5	10.0	7.20	43.8	YES	50
13	1.5	45	63.0	10.0	7.30	44.8	YES	50
14	1.4	45	54.0	10.0	7.20	42.3	YES	50
15	1.2	45	54.0	10.0	7.20	42.3	YES	50
16	1.2	45	54.0	10.0	7.20	42.3	YES	50
17	1.2	45	54.0	10.0	7.20	42.3	YES	50
18	1.2	45	54.0	10.0	7.20	42.3	YES	50
19	1.2	45	54.0	10.0	7.20	42.3	YES	50
20	1.1	45	49.5	10.0	7.20	41.8	YES	50
21	1.1	45	49.5	10.0	7.20	41.8	YES	50
22	1.1	45	49.5	10.0	7.20	41.8	YES	50
23	1.1	45	49.5	10.0	7.20	41.8	YES	50
24	1.1	45	49.5	9.0	7.20	44.7	YES	50
25	1.2	45	54.0	9.0	7.20	45.2	YES	50
26	1.3	45	58.5	9.0	7.20	45.7	YES	50
27	1.3	45	58.5	9.0	7.20	45.7	YES	50
28	1.3	45	58.5	9.0	7.20	45.7	YES	50
29	1.3	45	58.5	9.0	7.20	45.7	YES	50
30	1.3	45	58.5	9.0	7.20	45.7	YES	50
31	1.3	45	58.5	9.0	7.20	45.7	YES	50

Revised July 2018

If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350