

OHA - Drinking Water Services - Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: Coos  
 Month/Year: Jan. 2024

System Name:	Garden Valley Water Dist.			ID#: 41	00214	WTP: TP -	
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1		0.20	0.20	0.20	0.29	0.20	0.29
2	0.20	0.20	0.20	0.20	0.19	0.20	0.19
3	0.20	0.20	0.20	0.20	0.25	0.20	0.25
4	0.20	0.20	0.20	0.20	0.16	0.20	0.20
5	0.20	0.20	0.20	0.20	0.17	0.20	0.20
6	0.20	0.20	0.20	0.20	0.14	0.20	0.20
7	0.20	0.20	0.20	0.20	0.16	0.20	0.20
8	0.20	0.20	0.20	0.20	0.21	0.20	0.21
9	0.20	0.20	0.20	0.20	0.18	0.20	0.20
10	0.20	0.20	0.20	0.20	0.14	0.20	0.20
11	0.20	0.20	0.20	0.20	0.14	0.20	0.20
12	0.20	0.20	0.20	0.20	0.16	0.20	0.20
13	0.20	0.20	0.20	0.20	0.26	0.20	0.26
14	0.20	0.20	0.20	0.20	0.20	0.20	0.20
15	0.20	0.20	0.20	0.20	0.37	0.30	0.37
16	0.20	0.20	0.20	0.20	0.30	0.20	0.30
17	0.20	0.20	0.20	0.20	0.24	0.20	0.24
18	0.20	0.20	0.20	0.20	0.29	0.20	0.29
19	0.20	0.20	0.20	0.20	0.37	0.20	0.37
20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
21	0.20	0.20	0.20	0.20	0.25	0.20	0.25
22	0.20	0.20	0.20	0.20	0.30	0.20	0.30
23	0.20	0.20	0.20	0.20	0.24	0.20	0.24
24	0.20	0.20	0.20	0.20	0.15	0.20	0.20
25	0.20	0.20	0.20	0.20	0.27	0.20	0.27
26	0.20	0.20	0.20	0.20	0.19	0.20	0.20
27	0.20	0.20	0.20	0.20	0.24	0.20	0.24
28	0.20	0.20	0.20	0.20	0.20	0.20	0.20
29	0.20	0.20	0.20	0.20	0.18	0.20	0.20
30							
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE <sup>2</sup> triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		

PRINTED NAME: RYAN A. SHERMAN  
 SIGNATURE: [Signature] Feb. 2024  
 PHONE #: (541) 260-2436 CERT #: 9184

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Eff. (393-081-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name: Garden Valley Water Dist. ID#: 41 00214 Month/Year: FEB.2024 Disinfection Giardia Log Inactive: 1

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [ C ]	pH	i formula	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1	1.1	45	49.5	12.0	7.20	36.7	YES	50
2	1.4	45	63.0	12.0	7.20	38.0	YES	50
3	1.1	45	49.5	12.0	7.20	36.7	YES	50
4	1.2	45	54.0	12.0	7.20	37.1	YES	50
5	1.3	45	58.5	12.0	7.20	37.6	YES	50
6	1.2	45	54.0	11.0	7.20	39.6	YES	50
7	1.3	45	58.5	11.0	7.20	40.1	YES	50
8	1.2	45	54.0	11.0	7.20	39.6	YES	50
9	1.1	45	49.5	11.0	7.20	39.2	YES	50
10	1.1	45	49.5	12.0	7.20	36.7	YES	50
11	1.5	45	67.5	12.0	7.30	39.8	YES	50
12	1.4	45	63.0	13.0	7.30	36.4	YES	50
13	1.3	45	58.5	11.0	7.30	41.5	YES	50
14	1.2	45	54.0	11.0	7.30	41.0	YES	50
15	1.4	45	63.0	13.0	7.30	36.4	YES	50
16	1.3	45	58.5	13.0	7.30	36.0	YES	50
17	1.2	45	54.0	13.0	7.30	35.6	YES	50
18	1.2	45	54.0	13.0	7.20	34.3	YES	50
19	1.2	45	54.0	15.0	7.20	30.0	YES	50
20	1.3	45	58.5	15.0	7.20	30.4	YES	50
21	1.3	45	58.5	15.0	7.20	30.4	YES	50
22	1.2	45	54.0	15.0	7.20	30.0	YES	50
23	1.2	45	54.0	9.0	7.20	45.2	YES	50
24	1.1	45	49.5	9.0	7.20	44.7	YES	50
25	1.2	45	54.0	13.0	7.20	34.3	YES	50
26	1.1	45	49.5	15.0	7.20	29.7	YES	50
27	1	45	45.0	15.0	7.20	29.3	YES	50
28	1.1	45	49.5	12.0	7.20	36.7	YES	50
29	1.2	45	54.0	12.0	7.20	37.1	YES	50
30								
31								

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018