

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: Garden Valley Water Assn. F ID: OR4100214 WTP-: WTP-A Month/Year: March 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	----	0.03	0.01	0.01	----	0.01	0.03
2	----	----	0.01	0.01	0.03	0.03	0.03
3	----	----	----	0.01	0.01	0.01	0.01
4	----	0.01	0.01	0.01	0.01	----	0.01
5	----	----	0.01	0.01	0.02	----	0.02
6	----	----	0.01	0.02	0.02	----	0.02
7	----	0.02	----	0.03	0.01	----	0.03
8	----	----	----	----	0.01	----	0.01
9	----	0.01	----	----	----	0.01	0.01
10	----	0.01	----	----	0.01	0.01	0.01
11	----	0.01	0.01	----	----	0.01	0.01
12	----	0.01	0.02	0.01	0.01	----	0.02
13	----	0.01	----	0.01	----	0.01	0.01
14	----	0.02	0.01	0.01	0.02	----	0.02
15	----	----	----	0.03	----	0.02	0.03
16	----	----	0.03	----	----	----	0.03
17	----	----	----	----	----	----	----
18	----	----	0.04	----	----	----	0.04
19	----	----	0.04	----	----	----	0.04
20	----	----	0.06	----	0.06	----	0.06
21	----	----	0.05	0.05	----	----	0.05
22	----	0.01	0.01	----	----	----	0.01
23	----	----	----	----	----	----	----
24	----	----	----	----	----	----	----
25	----	----	----	----	----	0.02	0.02
26	----	----	0.02	0.05	----	0.02	0.05
27	----	----	0.02	0.02	0.02	0.02	0.02
28	----	----	----	0.01	----	----	0.01
29	0.01	----	----	0.01	----	----	0.01
30	0.01	----	0.01	----	----	----	0.01
31	----	----	----	0.01	0.02	0.01	0.02

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? Yes/No	CT's met everyday? (see back) Yes/No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes/No
All the 4 hour turbidity readings ≤ 1 NTU? Yes/No		
All turbidity readings < IFE ² triggers? Yes/No²		
Notes:	PRINTED NAME: <i>Ryan A. Sherman</i>	
	SIGNATURE: <i>Ryan A. Sherman</i>	DATE: April 8, 2025
	PHONE #: (541) 260-2436	CERT #: 9184

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Garden Valley Water Assn ID #: OR4100214 WTP-: WTP-A Month/Year: March 2025 Required Log Inactivation: 1

Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.4	45	63	13.0	7.1	34	Yes	50
2 / 11 AM	1.4	45	63	12.0	7.2	38	Yes	50
3 / 11 AM	1.4	45	63	11.0	7.3	42	Yes	50
4 / 11 AM	1.4	45	63	16.0	7.2	29	Yes	50
5 / 11 AM	1.4	45	63	11.0	7.3	42	Yes	50
6 / 11 AM	1.4	45	63	13.0	7.3	36	Yes	50
7 / 11 AM	1.4	45	63	13.0	7.4	38	Yes	50
8 / 11 AM	1.3	45	59	14.0	7.2	32	Yes	50
9 / 11 AM	1.3	45	59	13.0	7.3	36	Yes	50
10 / 11 AM	1.1	45	50	12.0	7.1	35	Yes	50
11 / 11 AM	1.0	45	45	11.0	7.3	40	Yes	50
12 / 11 AM	1.3	45	59	10.0	7.2	43	Yes	50
13 / 11 AM	1.1	45	50	9.0	7.3	46	Yes	50
14 / 11 AM	1.2	45	54	10.0	7.3	44	Yes	50
15 / 11 AM	1.1	45	50	10.0	7.4	45	Yes	50
16 / 11 AM	1.0	45	45	10.0	7.3	43	Yes	50
17 / 11 AM	1.3	45	59	12.0	7.2	38	Yes	50
18 / 11 AM	1.1	45	50	12.0	7.3	38	Yes	50
19 / 11 AM	1.0	45	45	9.0	7.3	46	No	50
20 / 11 AM	1.4	45	63	10.0	7.4	46	Yes	50
21 / 11 AM	1.3	45	59	11.0	7.2	40	Yes	50
22 / 11 AM	1.3	45	59	11.0	7.3	41	Yes	50
23 / 11 AM	1.1	45	50	14.0	7.1	31	Yes	50
24 / 11 AM	1.0	45	45	15.0	7.3	30	Yes	50
25 / 11 AM	1.3	45	59	17.0	7.3	28	Yes	50
26 / 11 AM	1.1	45	50	16.0	7.4	30	Yes	50
27 / 11 AM	1.2	45	54	12.0	7.2	37	Yes	50
28 / 11 AM	1.4	45	63	12.0	7.3	39	Yes	50
29 / 11 AM	1.3	45	59	12.0	7.1	36	Yes	50
30 / 11 AM	1.5	45	68	11.0	7.1	40	Yes	50
31 / 11 AM	1.6	45	72	11.0	7.1	40	Yes	50

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012