

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: Garden Valley Water Assn. F ID: OR4100214 WTP: WTP-A Month/Year: August 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]	
1	-----	0.20	0.28	0.26	0.20	0.20	0.28	5
2	0.20	0.22	0.20	0.20	0.20	0.20	0.22	6
3	-----	-----	0.24	0.20	0.10	0.20	0.24	4
4	0.27	0.20	0.20	0.18	-----	-----	0.27	4
5	-----	0.18	-----	-----	-----	-----	0.18	1
6	-----	0.30	-----	-----	-----	-----	0.30	1
7	-----	-----	-----	-----	-----	-----	-----	0
8	0.17	0.18	-----	-----	0.26	0.32	0.32	4
9	0.30	-----	0.12	0.14	-----	-----	0.30	3
10	-----	-----	-----	-----	0.22	-----	0.22	1
11	-----	-----	-----	0.20	0.20	0.30	0.30	3
12	-----	-----	-----	-----	0.18	0.05	0.18	2
13	-----	-----	0.25	0.21	0.20	-----	0.25	3
14	0.25	-----	0.22	0.25	0.30	0.17	0.30	5
15	-----	-----	0.28	0.16	0.18	-----	0.28	3
16	-----	0.24	0.30	0.30	0.16	-----	0.30	4
17	-----	-----	-----	-----	0.20	-----	0.20	1
18	-----	-----	-----	-----	0.20	0.15	0.20	2
19	-----	0.20	0.25	-----	-----	0.25	0.25	3
20	0.20	0.22	-----	0.25	-----	-----	0.25	3
21	0.20	0.25	0.25	0.30	-----	0.26	0.30	4
22	-----	-----	-----	0.18	0.16	-----	0.18	2
23	-----	0.28	-----	-----	0.30	-----	0.30	2
24	-----	-----	0.25	-----	-----	-----	0.25	1
25	0.28	0.20	-----	-----	-----	0.20	0.28	3
26	-----	-----	-----	0.24	0.30	0.30	0.30	3
27	0.30	-----	-----	0.30	0.30	0.20	0.30	4
28	0.20	0.20	-----	-----	-----	0.25	0.25	3
29	0.22	0.30	0.30	-----	-----	-----	0.30	3
30	-----	-----	-----	0.22	0.20	0.28	0.28	3
31	-----	-----	0.42	0.34	0.25	0.26	0.42	4

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? Yes / No All the 4 hour turbidity readings ≤ 1 NTU? Yes / No All turbidity readings < IFE ² triggers? Yes / No ²	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No	
Notes: 3/91 0.0329		PRINTED NAME: Ryan Sherman SIGNATURE: Ryan A.S. PHONE #: (541) 260-2436	
		DATE: September 8, 2025 CERT #: 9184	

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Garden Valley Water Assn ID #: OR4100214 WTP-: WTP-A Month/Year: August 2025

**Required Log
Inactivation: 1**

Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.1	45	50	16.0	8.0	37	Yes	50
2 / 11 AM	1.3	45	59	15.0	8.0	41	Yes	50
3 / 11 AM	1.4	45	63	18.0	7.8	31	Yes	50
4 / 11 AM	1.1	45	50	20.0	7.9	28	Yes	50
5 / 11 AM	1.4	45	63	17.0	7.8	34	Yes	50
6 / 11 AM	1.6	45	72	20.0	7.9	29	Yes	50
7 / 11 AM	1.6	45	72	18.0	7.9	33	Yes	50
8 / 11 AM	1.7	45	77	19.0	7.9	32	Yes	50
9 / 11 AM	1.5	45	68	20.0	8.0	30	Yes	50
10 / 11 AM	1.8	45	81	20.0	7.9	30	Yes	50
11 / 11 AM	1.3	45	59	19.0	7.8	29	Yes	50
12 / 11 AM	1.2	45	54	18.0	8.0	33	Yes	50
13 / 11 AM	1.9	45	86	19.0	8.1	35	Yes	50
14 / 11 AM	1.7	45	77	19.0	7.8	30	Yes	50
15 / 11 AM	1.5	45	68	20.0	8.1	31	Yes	50
16 / 11 AM	1.4	45	63	19.0	8.1	33	Yes	50
17 / 11 AM	1.1	45	50	18.0	7.5	27	Yes	50
18 / 11 AM	1.4	45	63	19.0	8.2	34	Yes	50
19 / 11 AM	1.4	45	63	20.0	8.1	31	Yes	50
20 / 11 AM	1.3	45	59	20.0	8.1	30	Yes	50
21 / 11 AM	1.4	45	63	20.0	8.1	31	Yes	50
22 / 11 AM	1.3	45	59	18.0	8.0	33	Yes	50
23 / 11 AM	1.7	45	77	18.0	8.0	35	Yes	50
24 / 11 AM	1.4	45	63	19.0	8.0	32	Yes	50
25 / 11 AM	1.5	45	68	18.0	7.9	33	Yes	50
26 / 11 AM	1.4	45	63	18.0	7.8	31	Yes	50
27 / 11 AM	1.3	45	59	20.0	7.3	23	Yes	50
28 / 11 AM	1.5	45	68	19.0	8.0	32	Yes	50
29 / 11 AM	1.3	45	59	18.0	8.1	35	Yes	50
30 / 11 AM	1.2	45	54	18.0	7.9	32	Yes	50
31 / 11 AM	1.3	45	59	18.0	7.9	32	Yes	50

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012