

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name:Garden Valley Water Assn. **F ID:**OR4100214 **WTP-:**WTP-A **Month/Year:** September 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.31	0.31	0.31	0.31	0.31	0.31	0.31
2	0.31	0.31	0.31	0.31	0.31	0.31	0.31
3	0.31	0.31	0.31	0.31	0.31	0.31	0.31
4	0.31	0.31	0.31	0.31	0.31	0.31	0.31
5	0.31	0.31	0.31	0.31	0.31	0.31	0.31
6	0.31	0.31	0.31	0.31	0.31	0.31	0.31
7	0.31	0.31	0.31	0.31	0.31	0.31	0.31
8	0.31	0.31	0.31	0.31	0.31	0.31	0.31
9	0.31	0.31	0.31	0.31	0.31	0.31	0.31
10	0.31	0.31	0.31	0.31	0.31	0.31	0.31
11	0.31	0.31	0.31	0.31	0.31	0.30	0.31
12	0.31	0.31	0.31	0.31	0.31	0.31	0.31
13	0.31	0.31	0.31	0.31	0.31	0.31	0.31
14	0.31	0.31	0.31	0.31	0.31	0.31	0.31
15	0.31	0.31	0.31	0.31	0.31	0.31	0.31
16	0.31	0.31	0.31	0.31	0.31	0.31	0.31
17	0.31	0.31	0.31	0.31	0.31	0.31	0.31
18	0.31	0.31	0.31	0.31	0.31	0.31	0.31
19	0.31	0.31	0.31	0.31	0.31	0.31	0.31
20	0.31	0.31	0.31	0.31	0.31	0.31	0.31
21	0.31	0.31	0.31	0.31	0.31	0.31	0.31
22	0.31	0.31	0.31	0.31	0.31	0.31	0.31
23	0.31	0.31	0.31	0.31	0.31	0.31	0.31
24	0.31	0.31	0.31	0.31	0.31	0.31	0.31
25	0.31	0.31	0.31	0.31	0.31	0.31	0.31
26	0.31	0.31	0.31	0.31	0.31	0.31	0.31
27	0.31	0.31	0.31	0.31	0.31	0.31	0.31
28	0.31	0.31	0.31	0.31	0.31	0.31	0.31
29	0.31	0.31	0.31	0.31	0.31	0.31	0.31
30	0.31	0.31	0.31	0.31	0.31	0.31	0.31
31	-----	-----	-----	-----	-----	-----	-----

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? Yes / No No	CT's met everyday? (see back) Yes / No No	
All the 4 hour turbidity readings ≤ 1 NTU? Yes / No No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No No	
All turbidity readings < IFE ² triggers? Yes / No No		
Notes:	PRINTED NAME: Bryan A. Sherman	
	SIGNATURE: Bryan A. Sherman	DATE: October 9, 2025
	PHONE # : (541) 260-2436	CERT # : 9184

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Garden Valley Water Assn ID #: OR4100214 WTP-: WTP-A Month/Year: September 2025								Required Log Inactivation: 1
Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.8	45	81	17.0	7.8	35	Yes	50
2 / 11 AM	1.6	45	72	15.0	8.2	45	Yes	50
3 / 11 AM	1.2	45	54	17.0	8.7	46	Yes	50
4 / 11 AM	1.4	45	63	17.0	8.2	39	Yes	50
5 / 11 AM	1.4	45	63	16.0	8.5	46	Yes	50
6 / 11 AM	0.6	45	28	16.0	8.0	35	No	50
7 / 11 AM	1.7	45	77	21.0	8.2	31	Yes	50
8 / 11 AM	1.7	45	77	15.0	8.5	51	Yes	50
9 / 11 AM	0.8	45	35	17.0	8.4	39	No	50
10 / 11 AM	1.2	45	54	22.0	8.4	29	Yes	50
11 / 11 AM	0.3	45	14	17.0	8.8	43	No	50
12 / 11 AM	1.9	45	86	16.0	7.5	34	Yes	50
13 / 11 AM	2.0	45	90	15.0	8.4	51	Yes	50
14 / 11 AM	1.6	45	72	18.0	8.5	42	Yes	50
15 / 11 AM	0.8	45	35	12.0	7.8	44	No	50
16 / 11 AM	0.8	45	35	12.0	8.5	56	No	50
17 / 11 AM	1.8	45	81	17.0	8.5	45	Yes	50
18 / 11 AM	1.9	45	86	16.0	8.4	47	Yes	50
19 / 11 AM	1.8	45	81	20.0	8.4	36	Yes	50
20 / 11 AM	1.5	45	68	17.0	8.8	49	Yes	50
21 / 11 AM	1.1	45	50	15.0	8.4	46	Yes	50
22 / 11 AM	1.3	45	59	13.0	8.5	56	Yes	50
23 / 11 AM	1.1	45	50	12.0	8.5	58	No	50
24 / 11 AM	1.5	45	68	13.0	8.4	55	Yes	50
25 / 11 AM	1.0	45	45	13.0	8.5	54	No	50
26 / 11 AM	1.0	45	45	14.0	8.6	53	No	50
27 / 11 AM	1.7	45	77	12.0	8.6	65	Yes	50
28 / 11 AM	1.6	45	72	15.0	8.5	51	Yes	50
29 / 11 AM	1.3	45	59	16.0	8.5	46	Yes	50
30 / 11 AM	1.3	45	60	13.0	8.5	56	Yes	50
31 / 11 AM	-----	45	-----	-----	-----	-----	-----	50

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012