

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: Garden Valley Water Assn. F ID: OR4100214 WTP: WTP-A Month/Year: October 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.30	0.30	0.30	0.30	0.30	0.30	0.30
2	0.30	0.30	0.30	0.30	0.30	0.30	0.30
3	0.30	0.30	0.30	0.30	0.30	0.30	0.30
4	0.30	0.30	0.30	0.30	0.30	0.30	0.30
5	0.30	0.30	0.30	0.30	0.30	0.30	0.30
6	0.30	0.30	0.30	0.30	0.30	0.30	0.30
7	0.30	0.30	0.30	0.30	0.30	0.30	0.30
8	0.30	0.30	0.30	0.30	0.30	0.30	0.30
9	0.30	0.30	0.30	0.30	0.30	0.30	0.30
10	0.30	0.30	0.30	0.30	0.30	0.30	0.30
11	0.30	0.30	0.30	0.30	0.30	0.30	0.30
12	0.30	0.30	0.30	0.30	0.30	0.30	0.30
13	0.30	0.30	0.30	0.30	0.30	0.30	0.30
14	0.30	0.30	0.30	0.30	0.30	0.30	0.30
15	0.30	0.30	0.30	0.30	0.30	0.30	0.30
16	0.30	0.30	0.30	0.30	0.30	0.30	0.30
17	0.30	0.30	0.30	0.30	0.30	0.30	0.30
18	0.30	0.30	0.30	0.30	0.30	0.30	0.30
19	0.30	0.30	0.30	0.30	0.30	0.30	0.30
20	0.30	0.30	0.30	0.30	0.30	0.30	0.30
21	0.30	0.30	0.30	0.30	0.30	0.30	0.30
22	0.30	0.30	0.30	0.30	0.30	0.30	0.30
23	0.30	0.30	0.30	0.30	0.30	0.30	0.30
24	0.30	0.30	0.30	0.30	0.30	0.30	0.30
25	0.30	0.30	0.30	0.30	0.30	0.30	0.30
26	0.30	0.30	0.30	0.30	0.30	0.30	0.30
27	0.30	0.30	0.30	0.30	0.30	0.30	0.30
28	0.30	0.30	0.30	0.30	0.30	0.30	0.30
29	0.30	0.30	0.30	0.30	0.30	0.30	0.30
30	0.30	0.30	0.30	0.30	0.30	0.30	0.30
31	0.30	0.30	0.30	0.30	0.30	0.30	0.30

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <u>Yes</u> / No All the 4 hour turbidity readings ≤ 1 NTU? <u>Yes</u> / No All turbidity readings < IFE ² triggers? <u>Yes</u> / No ²	CT's met everyday? (see back) <u>Yes</u> / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <u>Yes</u> / No	
Notes: 		PRINTED NAME: <u>Ryan A. Sherman</u> SIGNATURE: <u>[Signature]</u> PHONE #: (541) 260-2436	
		DATE: November 10, 2025 CERT #: <u>9189</u>	

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Garden Valley Water Assn ID #: OR4100214 WTP-: WTP-A Month/Year: October 2025								Required Log Inactivation: 1
Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	0.7	45	32	15.0	8.1	40	No	50
2 / 11 AM	1.3	45	59	14.0	7.9	42	Yes	50
3 / 11 AM	1.2	45	54	16.0	8.3	42	Yes	50
4 / 11 AM	0.5	45	23	15.0	8.2	40	No	50
5 / 11 AM	0.7	45	32	15.0	8.2	41	No	50
6 / 11 AM	1.0	45	45	18.0	7.5	27	Yes	50
7 / 11 AM	0.4	45	17	19.0	8.2	30	No	50
8 / 11 AM	0.4	45	18	15.0	8.2	40	No	50
9 / 11 AM	0.6	45	27	15.0	8.3	42	No	50
10 / 11 AM	0.6	45	27	15.0	8.3	42	No	50
11 / 11 AM	0.4	45	18	15.0	8.5	44	No	50
12 / 11 AM	0.4	45	18	14.0	8.4	46	No	50
13 / 11 AM	0.4	45	18	14.0	8.0	39	No	50
14 / 11 AM	0.5	45	23	14.0	8.4	46	No	50
15 / 11 AM	2.0	45	90	16.0	7.7	37	Yes	50
16 / 11 AM	1.8	45	81	14.0	8.2	50	Yes	50
17 / 11 AM	1.6	45	72	14.0	8.2	49	Yes	50
18 / 11 AM	1.1	45	50	16.0	8.2	40	Yes	50
19 / 11 AM	1.3	45	59	15.0	8.2	44	Yes	50
20 / 11 AM	1.1	45	50	15.0	8.2	43	Yes	50
21 / 11 AM	1.2	45	54	17.0	7.9	34	Yes	50
22 / 11 AM	1.3	45	59	15.0	8.3	46	Yes	50
23 / 11 AM	1.1	45	50	14.0	8.3	48	Yes	50
24 / 11 AM	1.2	45	54	12.0	8.3	55	No	50
25 / 11 AM	1.1	45	50	11.0	8.3	58	No	50
26 / 11 AM	1.2	45	54	14.0	8.2	46	Yes	50
27 / 11 AM	1.4	45	63	12.0	8.3	56	Yes	50
28 / 11 AM	1.2	45	54	13.0	8.1	48	Yes	50
29 / 11 AM	0.6	45	27	12.0	8.2	49	No	50
30 / 11 AM	0.5	45	23	13.0	8.3	48	No	50
31 / 11 AM	1.5	45	68	11.0	8.6	68	No	50

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012