

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS
Conventional or Direct Filtration**

System Name:Garden Valley Water Assn. **F ID:**OR4100214 **WTP:-**WTP-A **Month/Year:** November 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	----	0.52	----	0.42	----	0.56	0.56
2	----	-----	0.60	----	----	----	0.60
3	0.26	0.14	0.28	0.28	-----	0.56	0.56
4	0.60	0.80	0.80	0.80	0.80	0.80	0.80
5	0.28	0.26	0.26	0.25	-----	-----	0.28
6	0.26	0.22	0.68	0.25	-----	-----	0.68
7	0.26	-----	0.24	0.30	-----	-----	0.30
8	0.25	0.28	0.30	0.24	-----	0.14	0.30
9	-----	-----	0.20	0.12	0.18	-----	0.20
10	-----	0.16	0.25	-----	0.18	0.19	0.25
11	0.30	0.18	0.19	0.30	-----	0.30	0.30
12	0.17	0.37	-----	0.22	0.27	-----	0.37
13	0.26	0.36	-----	-----	0.25	0.32	0.36
14	0.24	0.33	-----	0.26	0.28	-----	0.33
15	-----	-----	-----	-----	-----	-----	-----
16	0.43	-----	-----	-----	-----	-----	0.43
17	0.42	-----	-----	-----	-----	-----	0.42
18	-----	-----	0.26	0.30	0.30	-----	0.30
19	-----	0.25	0.32	0.24	0.33	-----	0.33
20	0.27	-----	0.38	0.27	-----	-----	0.38
21	-----	-----	-----	0.43	-----	-----	0.43
22	0.44	-----	-----	0.34	0.35	-----	0.44
23	0.18	0.19	0.20	0.30	-----	-----	0.30
24	0.20	0.36	0.21	-----	-----	-----	0.36
25	0.35	0.35	0.35	0.35	0.35	0.35	0.35
26	0.35	0.35	0.35	0.35	0.35	0.35	0.35
27	0.35	0.35	0.35	0.35	0.35	0.35	0.35
28	0.35	0.35	0.35	0.35	0.35	0.35	0.35
29	0.35	0.35	0.35	0.35	0.35	0.35	0.35
30	0.35	0.35	0.35	0.35	0.35	0.35	0.35
31	0.35	0.35	0.35	0.35	0.35	0.35	0.35

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? <u>Yes / No</u> All the 4 hour turbidity readings ≤ 1 NTU? <u>Yes / No</u> All turbidity readings < IFE ² triggers? <u>Yes / No</u> ²		CT's met everyday? (see back) Yes <u>No</u>	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <u>Yes / No</u>
Notes: 		PRINTED NAME: <u>Ryan A. Sherman</u> SIGNATURE: <u>[Signature]</u> DATE: December 4, 2025 PHONE # : (541) 260-2436 CERT # : <u>9184</u>	

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Garden Valley Water Assn ID #: OR4100214 WTP-: WTP-A Month/Year: November 2025								Required Log Inactivation: 1
Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.2	45	54	12.0	7.8	46	Yes	50
2 / 11 AM	1.7	45	77	13.0	7.8	45	Yes	50
3 / 11 AM	1.7	45	76	13.0	7.8	45	Yes	50
4 / 11 AM	1.5	45	68	13.0	8.2	51	Yes	50
5 / 11 AM	1.5	45	68	14.0	7.8	41	Yes	50
6 / 11 AM	1.5	45	65	15.0	8.4	48	Yes	50
7 / 11 AM	1.5	45	68	14.0	7.7	40	Yes	50
8 / 11 AM	1.2	45	54	15.0	7.7	36	Yes	50
9 / 11 AM	1.2	45	54	15.0	7.7	36	Yes	50
10 / 11 AM	1.2	45	54	14.0	7.6	37	Yes	50
11 / 11 AM	1.9	45	86	14.0	7.8	43	Yes	50
12 / 11 AM	1.3	45	59	15.0	7.8	38	Yes	50
13 / 11 AM	1.3	45	59	14.0	7.8	40	Yes	50
14 / 11 AM	1.3	45	59	14.0	7.8	40	Yes	50
15 / 11 AM	1.5	45	68	15.0	7.8	39	Yes	50
16 / 11 AM	1.0	45	45	15.0	7.8	37	Yes	50
17 / 11 AM	1.0	45	45	15.0	7.8	37	Yes	50
18 / 11 AM	1.1	45	50	14.0	8.4	49	Yes	50
19 / 11 AM	1.7	45	77	13.0	8.5	59	Yes	50
20 / 11 AM	1.5	45	68	12.0	8.5	61	Yes	50
21 / 11 AM	1.4	45	63	10.0	8.3	64	No	50
22 / 11 AM	1.3	45	59	11.0	8.6	66	No	50
23 / 11 AM	1.2	45	54	11.0	8.4	61	No	50
24 / 11 AM	11.0	45	495	11.0	8.6	212	Yes	50
25 / 11 AM	1.4	45	63	11.0	8.0	54	Yes	50
26 / 11 AM	1.3	45	59	10.0	8.7	73	No	50
27 / 11 AM	1.2	45	54	11.0	8.6	65	No	50
28 / 11 AM	1.2	45	54	12.0	8.6	61	No	50
29 / 11 AM	1.3	45	59	12.0	7.7	45	Yes	50
30 / 11 AM	1.2	45	54	11.0	7.6	46	Yes	50
31 / 11 AM	----	45	----	----	----	----	----	50

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012