



**OHA - Drinking Water Program - Surface Water Quality Data Form**

Garden Valley Water Assn ID #: OR4100214 WTP-: WTP-A Month/Year: December 2025

Date / Time	Min. Cl <sub>2</sub> Residual At 1 <sup>st</sup> User (C) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Required Log Inactivation: 1
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	Peak Hourly Demand Flow [GPM]
1/ 11 AM	1.3	45	59	10.0	8.0	57	Yes	50
2/ 11 AM	1.5	45	68	10.0	8.3	65	Yes	50
3/ 11 AM	1.7	45	77	11.0	8.3	62	Yes	50
4/ 11 AM	1.8	45	81	11.0	8.3	63	Yes	50
5/ 11 AM	1.8	45	81	12.0	8.3	59	Yes	50
6/ 11 AM	1.3	45	59	12.0	8.2	53	Yes	50
7/ 11 AM	1.9	45	86	12.0	8.0	53	Yes	50
8/ 11 AM	1.8	45	81	15.0	7.7	39	Yes	50
9/ 11 AM	1.8	45	81	15.0	8.2	46	Yes	50
10/ 11 AM	1.7	45	77	15.0	8.2	46	Yes	50
11/ 11 AM	1.4	45	63	14.0	8.3	49	Yes	50
12/ 11 AM	1.6	45	72	12.0	8.2	55	Yes	50
13/ 11 AM	1.4	45	63	12.0	8.5	60	Yes	50
14/ 11 AM	1.3	45	59	12.0	8.4	57	Yes	50
15/ 11 AM	1.4	45	63	11.0	8.4	62	Yes	50
16/ 11 AM	1.5	45	68	14.0	8.3	50	Yes	50
17/ 11 AM	1.7	45	75	11.0	8.3	62	Yes	50
18/ 11 AM	1.3	45	59	14.0	8.2	47	Yes	50
19/ 11 AM	1.8	45	81	11.0	8.3	63	Yes	50
20/ 11 AM	1.9	45	86	11.0	8.1	59	Yes	50
21/ 11 AM	1.8	45	81	11.0	8.1	58	Yes	50
22/ 11 AM	1.7	45	77	11.0	8.1	58	Yes	50
23/ 11 AM	1.7	45	77	10.0	8.1	62	Yes	50
24/ 11 AM	2.1	45	95	12.0	8.2	59	Yes	50
25/ 11 AM	1.9	45	86	11.0	8.1	59	Yes	50
26/ 11 AM	1.7	45	77	10.0	8.1	62	Yes	50
27/ 11 AM	2.2	45	99	10.0	8.0	63	Yes	50
28/ 11 AM	2.1	45	95	8.0	8.2	77	Yes	50
29/ 11 AM	1.5	45	68	9.0	8.2	67	Yes	50
30/ 11 AM	1.7	45	77	9.0	8.1	66	Yes	50
31/ 11 AM	1.7	45	77	8.0	8.1	71	Yes	50

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012