

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS
Conventional or Direct Filtration**

System Name:Garden Valley Water Assn. **F ID:**OR4100214 **WTP-:**WTP-A **Month/Year:** January 2026

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	0.53	0.72	----	0.30	----	----	0.72
2	0.68	----	----	0.65	----	----	0.68
3	0.50	----	----	----	----	0.41	0.50
4	----	----	----	----	0.70	----	0.70
5	0.68	----	----	0.30	----	----	0.68
6	0.90	----	----	----	----	0.72	0.90
7	----	----	----	----	0.90	----	0.90
8	0.99	----	0.99	0.92	----	----	0.99 ?
9	0.99	----	----	----	0.48	0.49	0.99 ?
10	0.74	----	----	----	0.70	----	0.74
11	0.66	----	0.70	----	----	0.31	0.70
12	0.72	0.65	0.58	----	0.36	0.62	0.72
13	0.58	0.70	----	0.63	----	0.44	0.70
14	0.48	0.58	----	----	----	0.22	0.58
15	0.68	----	0.32	----	----	----	0.68
16	----	0.38	----	----	----	0.33	0.38
17	0.37	----	----	----	----	----	0.37
18	----	----	0.30	----	----	0.32	0.32
19	----	----	----	----	----	0.40	0.40
20	----	0.37	0.38	----	----	----	0.38
21	0.36	----	0.46	----	----	----	0.46
22	----	0.62	----	----	0.30	0.46	0.62
23	0.38	0.43	----	----	----	0.42	0.43
24	----	0.44	----	----	0.33	----	0.44
25	----	----	----	----	----	0.48	0.48
26	0.56	----	----	----	----	----	0.56
27	0.99	----	----	----	----	0.22	0.99 ?
28	----	----	----	----	----	----	----
29	----	0.28	0.23	----	----	0.34	0.34
30	----	----	----	----	----	0.25	0.25
31	0.30	----	----	0.40	----	----	0.40

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? Yes / <u>No</u>	CT's met everyday? (see back) Yes / <u>No</u>	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / <u>No</u>
All the 4 hour turbidity readings ≤ 1 NTU? Yes / <u>No</u> ?		
All turbidity readings < IFE ² triggers? <u>Yes</u> / <u>No</u> ²		
Notes:	PRINTED NAME: <u>Ryan A. Sherman</u>	
	SIGNATURE: <u>Ryan A. S.</u>	DATE: February 9, 2026
	PHONE #: (541) 260-2436	CERT #: <u>9184</u>

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Garden Valley Water Assn ID #: OR4100214 WTP-: WTP-A Month/Year: January 2026 Required Log Inactivation: 1

Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.9	45	86	11.0	7.9	55	Yes	50
2 / 11 AM	1.5	45	68	12.0	7.9	49	Yes	50
3 / 11 AM	1.7	45	77	12.0	8.1	54	Yes	50
4 / 11 AM	1.5	45	68	10.0	7.9	56	Yes	50
5 / 11 AM	1.5	45	68	12.0	8.2	55	Yes	50
6 / 11 AM	1.5	45	68	10.0	8.1	60	Yes	50
7 / 11 AM	1.2	45	54	10.0	7.8	52	Yes	50
8 / 11 AM	1.2	45	54	10.0	7.8	52	Yes	50
9 / 11 AM	1.3	45	59	8.0	7.7	58	Yes	50
10 / 11 AM	1.3	45	59	8.0	7.7	58	Yes	50
11 / 11 AM	1.5	45	68	9.0	8.2	67	Yes	50
12 / 11 AM	1.4	45	63	10.0	8.2	62	Yes	50
13 / 11 AM	1.4	45	63	10.0	8.0	58	Yes	50
14 / 11 AM	1.3	45	59	10.0	8.0	57	Yes	50
15 / 11 AM	1.1	45	50	10.0	7.6	48	Yes	50
16 / 11 AM	1.4	45	63	9.0	7.7	55	Yes	50
17 / 11 AM	1.6	45	72	8.0	8.0	67	Yes	50
18 / 11 AM	1.8	45	81	8.0	8.0	69	Yes	50
19 / 11 AM	1.8	45	81	10.0	7.7	54	Yes	50
20 / 11 AM	1.4	45	63	10.0	8.1	60	Yes	50
21 / 11 AM	1.3	45	59	10.0	8.0	57	Yes	50
22 / 11 AM	1.3	45	59	9.0	7.8	57	Yes	50
23 / 11 AM	1.5	45	68	11.0	8.0	54	Yes	50
24 / 11 AM	1.8	45	81	6.0	8.0	79	Yes	50
25 / 11 AM	1.9	45	86	5.0	7.8	80	Yes	50
26 / 11 AM	1.6	45	72	9.0	8.0	63	Yes	50
27 / 11 AM	1.6	45	72	9.0	7.9	61	Yes	50
28 / 11 AM	1.6	45	72	10.0	8.0	59	Yes	50
29 / 11 AM	1.6	45	72	10.0	7.7	53	Yes	50
30 / 11 AM	1.7	45	77	9.0	7.9	61	Yes	50
31 / 11 AM	1.7	45	77	7.0	8.0	73	Yes	50

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012