

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:COOS Conventional or Direct Filtration

System Name: Garden Valley Water Assn. F ID: OR4100214 WTP-: WTP-A Month/Year: February 2026

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	----	----	0.18	----	----	----	0.18
2	0.12	0.46	----	----	----	----	0.46
3	----	----	----	----	----	----	----
4	----	0.26	----	----	----	----	0.26
5	----	0.28	----	----	----	----	0.28
6	----	0.36	----	----	----	----	0.36
7	0.28	----	----	----	----	----	0.28
8	----	0.32	0.27	----	----	----	0.32
9	----	----	----	----	----	0.27	0.27
10	----	----	----	----	0.27	----	0.27
11	----	----	0.34	----	0.47	----	0.47
12	0.60	----	0.34	----	----	0.44	0.60
13	----	----	----	0.40	----	0.37	0.40
14	----	----	----	----	----	----	----
15	----	----	0.21	0.46	----	----	0.46
16	----	0.46	----	----	----	0.52	0.52
17	----	----	----	----	----	0.18	0.18
18	----	----	0.57	----	----	----	0.57
19	----	----	----	----	----	0.35	0.35
20	----	----	----	0.22	----	----	0.22
21	----	----	0.33	----	----	----	0.33
22	0.29	0.30	----	----	----	----	0.30
23	----	----	----	----	----	----	----
24	----	----	----	----	----	----	----
25	----	----	----	----	----	----	----
26	----	----	----	----	----	----	----
27	----	----	----	----	----	----	----
28	----	----	----	----	----	----	----
29	----	----	----	----	----	----	----
30	----	----	----	----	----	----	----
31	----	----	----	----	----	----	----

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4 hour turbidity readings ≤ 0.3 NTU? Yes/No	CT's met everyday? (see back) Yes/No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes/No
All the 4 hour turbidity readings ≤ 1 NTU? Yes/No		
All turbidity readings < IFE ² triggers? Yes/No ²		
Notes:	PRINTED NAME: Ryan A. Sherman	
	SIGNATURE: <i>Ryan A. Sherman</i>	DATE: March 9, 2026
	PHONE #: (541) 260-2436	CERT #: 9184

¹ Including continuous data, if applicable, for optimizing recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

² IFE=Individual Filter Effluent (OAR 333-061-0040(1)(e)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Garden Valley Water Assn ID #: OR4100214 WTP-: WTP-A Month/Year: February 2026

Required Log Inactivation: 1

Date / Time	Min. Cl ₂ Residual At 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/l]	[minutes]	C x T	[° C]	S.U.	Formula	Yes / No	[GPM]
1 / 11 AM	1.0	45	45	11.0	8.3	57	No	50
2 / 11 AM	1.0	45	45	10.0	8.4	63	No	50
3 / 11 AM	1.0	45	45	12.0	8.4	55	No	50
4 / 11 AM	1.0	45	45	13.0	8.3	50	No	50
5 / 11 AM	1.0	45	45	13.0	8.3	50	No	50
6 / 11 AM	1.0	45	45	11.0	8.4	59	No	50
7 / 11 AM	1.0	45	45	8.0	8.5	75	No	50
8 / 11 AM	1.0	45	45	10.0	8.4	63	No	50
9 / 11 AM	0.9	45	41	11.0	8.3	57	No	50
10 / 11 AM	0.7	45	32	10.0	8.4	61	No	50
11 / 11 AM	1.0	45	45	12.0	8.3	53	No	50
12 / 11 AM	1.0	45	45	12.0	8.4	55	No	50
13 / 11 AM	1.0	45	45	11.0	8.4	59	No	50
14 / 11 AM	1.0	45	45	11.0	8.3	57	No	50
15 / 11 AM	1.0	45	45	10.0	8.2	59	No	50
16 / 11 AM	1.0	45	45	9.0	8.1	61	No	50
17 / 11 AM	0.9	45	41	7.0	7.9	64	No	50
18 / 11 AM	1.0	45	45	6.0	8.4	84	No	50
19 / 11 AM	1.0	45	45	6.0	8.1	75	No	50
20 / 11 AM	1.0	45	45	5.0	8.4	90	No	50
21 / 11 AM	1.0	45	45	11.0	8.4	59	No	50
22 / 11 AM	1.0	45	45	10.0	8.1	57	No	50
23 / 11 AM	1.0	45	45	12.0	8.3	53	No	50
24 / 11 AM	1.0	45	45	12.0	8.3	53	No	50
25 / 11 AM	1.0	45	45	12.0	8.3	53	No	50
26 / 11 AM	1.0	45	45	12.0	8.3	53	No	50
27 / 11 AM	1.0	45	45	14.0	8.2	45	No	50
28 / 11 AM	1.0	45	45	11.0	8.3	57	No	50
29 / 11 AM	----	45	----	----	----	----	----	50
30 / 11 AM	----	45	----	----	----	----	----	50
31 / 11 AM	----	45	----	----	----	----	----	50

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012