


**OHA - Drinking Water Program - Turbidity Monitoring Report Form    County: Benton**  
**Conventional or Direct Filtration**

**System Name: Corvallis, City of    ID#: OR4100225 WTP--:WTP-A    Month/Year: Feb / 2022**

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ' (NTU)
1	Off	Off	0.03	0.03	0.03	Off	0.03
2	Off	Off	0.03	0.03	0.03	Off	0.03
3	Off	Off	0.03	0.03	0.03	Off	0.03
4	Off	Off	0.03	0.03	0.03	Off	0.03
5	Off	Off	0.03	0.03	0.03	Off	0.03
6	Off	Off	Off	0.03	0.03	Off	0.03
7	Off	Off	0.03	0.03	0.03	Off	0.03
8	Off	Off	0.03	0.03	0.03	Off	0.03
9	Off	Off	0.03	0.02	0.03	Off	0.03
10	Off	Off	0.03	0.02	0.03	Off	0.03
11	Off	Off	0.03	0.03	0.03	Off	0.03
12	Off	Off	0.03	0.02	0.03	Off	0.03
13	Off	Off	0.03	0.03	0.02	Off	0.03
14	Off	Off	Off	0.03	0.03	Off	0.03
15	Off	Off	0.03	0.02	0.02	Off	0.03
16	Off	Off	0.03	0.02	0.02	Off	0.03
17	Off	Off	0.02	0.02	0.02	Off	0.03
18	Off	Off	0.02	0.02	0.02	Off	0.02
19	Off	Off	Off	0.02	0.02	Off	0.03
20	Off	Off	0.02	0.02	0.02	Off	0.03
21	Off	Off	0.02	0.02	0.02	Off	0.03
22	Off	Off	0.03	0.02	0.02	Off	0.03
23	Off	Off	0.03	0.02	0.02	Off	0.03
24	Off	Off	0.02	0.03	0.02	Off	0.03
25	Off	Off	0.03	0.03	Off	Off	0.03
26	Off	Off	0.03	0.02	0.03	Off	0.03
27	Off	Off	0.02	0.02	Off	Off	0.03
28	Off	Off	0.02	0.03	0.03	Off	0.03

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No		<b>Notes:</b>	
		PRINTED NAME: Chad Marshall	
		SIGNATURE: 	DATE: 3/4/2022
		PHONE #: (541) 754-1758	CERT #: T-08843

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.  
<sup>2</sup> IFE = Individual Filter Effluent (OAR 333-061-0040 (1) (e) (B&C))

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**Corvallis, City of**    **ID#: 41 00225 WTP-: WTP - A**    **Month/Year: Feb / 2022**    Required Log Inactivation: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	ppm or mg/L	minutes	C X T	° C		Use tables	Yes / No	[GPM]
01 / 0714	1.28	69.0	88	6	7.1	31	Yes	8300
02 / 1053	1.23	83.0	102	6	7.0	25	Yes	6900
03 / 0935	1.13	76.0	86	6	7.0	25	Yes	7600
04 / 1243	1.16	83.0	96	7	7.1	31	Yes	6900
05 / 0925	1.16	88.0	102	7	7.0	25	Yes	6600
06 / 1501	1.22	69.0	84	7	7.1	31	Yes	8200
07 / 1204	1.27	72.0	91	7	7.0	26	Yes	7800
08 / 0930	1.25	72.0	90	7	7.0	26	Yes	7800
09 / 1519	1.22	92.0	112	7	7.0	25	Yes	6200
10 / 1518	1.22	80.0	98	7	7.0	25	Yes	7200
11 / 1020	1.22	68.0	83	7	7.0	25	Yes	8700
12 / 0730	1.18	64.0	76	7	7.1	31	Yes	8800
13 / 1157	1.19	72.0	86	7	7.0	25	Yes	7800
14 / 0852	1.13	92.0	104	7	7.1	31	Yes	6300
15 / 0731	1.16	83.0	96	7	7.0	25	Yes	6700
16 / 1214	1.23	83.0	102	7	6.9	25	Yes	6900
17 / 0928	1.20	80.0	96	8	6.9	25	Yes	7200
18 / 0849	1.83	49.0	90	8	6.9	27	Yes	11500
19 / 1149	1.19	83.0	99	7	7.0	25	Yes	6800
20 / 1524	1.22	80.0	98	7	7.0	25	Yes	7000
21 / 1240	1.19	80.0	95	7	7.0	25	Yes	7000
22 / 1027	1.28	80.0	102	7	7.0	26	Yes	7000
23 / 1435	1.11	72.0	80	5	7.1	31	Yes	7800
24 / 1138	1.05	80.0	84	5	6.9	25	Yes	7000
25 / 1446	1.21	72.0	87	4	7.0	36	Yes	7800
26 / 0738	1.27	64.0	81	5	7.0	26	Yes	8900
27 / 1207	1.25	72.0	90	6	7.0	26	Yes	7800
28 / 1047	1.30	72.0	94	7	7.0	26	Yes	7900

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by next business day.

Download form at: [www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf](http://www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf)