

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Benton
Conventional or Direct Filtration**

System Name: Corvallis, City of ID#: OR4100225 WTP-: WTP - A Month/Year: Nov / 2025

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day 1 (NTU)
1	Off	Off	0.03	0.03	0.03	Off	0.04
2	Off	Off	0.03	0.03	0.03	Off	0.04
3	Off	Off	0.03	0.03	0.03	Off	0.04
4	Off	Off	0.03	0.03	0.03	Off	0.04
5	Off	Off	0.03	0.03	0.03	Off	0.04
6	Off	Off	0.03	0.03	0.03	Off	0.04
7	Off	Off	0.03	0.03	0.03	Off	0.04
8	Off	Off	0.03	0.03	0.03	Off	0.04
9	Off	Off	0.03	0.03	0.03	Off	0.04
10	Off	Off	0.03	0.03	0.03	Off	0.03
11	Off	Off	0.03	0.03	0.03	Off	0.04
12	Off	Off	0.03	0.03	Off	Off	0.04
13	Off	Off	0.03	0.03	0.03	Off	0.04
14	Off	Off	0.03	0.03	0.03	Off	0.04
15	Off	Off	0.03	0.03	0.03	Off	0.04
16	Off	Off	0.03	0.03	0.03	Off	0.04
17	Off	Off	0.03	0.03	0.03	Off	0.04
18	Off	Off	0.03	0.03	0.03	Off	0.04
19	Off	Off	0.03	0.03	0.03	Off	0.04
20	Off	Off	0.03	0.03	0.03	Off	0.03
21	Off	Off	0.03	0.03	0.03	Off	0.03
22	Off	Off	0.03	0.03	0.03	Off	0.04
23	Off	Off	0.03	0.03	0.03	Off	0.03
24	Off	Off	0.03	0.03	0.03	Off	0.03
25	Off	Off	0.03	0.03	0.03	Off	0.03
26	Off	Off	0.03	0.03	0.02	Off	0.03
27	Off	Off	Off	Off	Off	Off	OFF
28	Off	Off	Off	0.03	0.03	Off	0.03
29	Off	Off	0.03	0.03	0.03	Off	0.04
30	Off	Off	0.03	0.03	0.03	Off	0.04

Conventional or Direct Filtration

Monthly Summary (Answer Yes or No)

95% of the 4-hour turbidity readings ≤ 0.3 NTU? Yes No
 All the 4-hour turbidity readings ≤ 1 NTU? Yes No
 All turbidity readings < IFE² triggers? Yes No

CT's met everyday? Yes No
 (see back)
 All Cl2 residuals at entry point >= 0.2 mg/l? Yes No

Notes:

PRINTED NAME: Chad Marshall
 SIGNATURE: 
 PHONE #: (541) 754-1758

Date: 12/04/2025
 Cert #: T-08843

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through

"8 PM" may not correspond to continuous readings' maximum.

² IFE = Individual Filter Effluent (OAR 333-061-0040 (1) (e) (B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

Corvallis, City of

ID#: 41 00225 WTP-: WTP - A

Month/Year: Nov / 2025

Required Log Inactivation: 0.5

Date / Time	Minimum Cl ₂ Residual at 1st User (C) [ppm or mg/L]	Contact Time [minutes]	Actual CT C X T	Temp [°C]	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow [GPM]
01 / 1137	1.30	58.0	75	13	6.8	19	Yes	9,931
02 / 0843	1.32	64.0	84	13	6.7	19	Yes	8,819
03 / 1306	1.28	63.0	81	12	6.8	19	Yes	9,097
04 / 1335	1.29	63.0	81	12	6.9	19	Yes	9,306
05 / 1104	1.33	59.0	78	13	6.8	19	Yes	9,444
06 / 1129	1.30	72.0	94	13	6.8	19	Yes	7,777
07 / 1220	1.28	58.0	74	13	6.8	19	Yes	10,069
08 / 0936	1.28	63.0	81	13	6.8	19	Yes	9,375
09 / 1431	1.32	64.0	84	11	6.9	19	Yes	8,750
10 / 1207	1.25	68.0	85	11	6.9	19	Yes	8,611
11 / 0921	1.25	69.0	86	12	6.8	19	Yes	8,263
12 / 0802	1.30	72.0	94	12	6.9	19	Yes	7,986
13 / 1500	1.23	58.0	71	13	6.9	19	Yes	9,931
14 / 1106	1.30	76.0	99	13	6.9	19	Yes	7,431
15 / 1546	1.26	76.0	96	13	6.9	19	Yes	7,431
16 / 1307	1.23	98.0	121	13	6.9	19	Yes	5,625
17 / 1447	1.20	63.0	76	12	6.9	19	Yes	9,167
18 / 1022	1.23	59.0	73	12	7.0	19	Yes	9,653
19 / 1505	1.24	63.0	78	10	7.0	19	Yes	9,306
20 / 1427	1.26	59.0	74	10	7.0	19	Yes	9,583
21 / 1027	1.29	72.0	93	10	7.0	19	Yes	7,986
22 / 0920	1.26	76.0	96	10	7.0	19	Yes	7,638
23 / 0740	1.24	88.0	109	10	7.1	23	Yes	6,319
24 / 1357	1.27	80.0	102	9	7.0	26	Yes	7,291
25 / 1244	1.30	63.0	82	9	7.0	26	Yes	9,375
26 / 1033	1.29	63.0	81	9	7.0	26	Yes	9,236
27 /								OFF
28 / 1006	1.30	59.0	77	10	6.9	19	Yes	9,583
29 / 0820	1.33	88.0	117	10	7.0	19	Yes	6,597
30 / 0800	1.35	92.0	124	10	7.0	19	Yes	6,181

" 3 If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by next business day.