

OHA - Drinking Water Program - Surface Water Quality Data Form

| Corvallis, City of | | ID#: 41 00225 WTP-: WTP - A | | Month/Year: Dec / 2025 | | | Required Log Inactivation: 0.5 | |
|--------------------|--------------------------------------|-----------------------------|-----------|------------------------|-----|-------------|--------------------------------|-------------------------|
| Date / Time | Minimum Cl2 Residual at 1st User (C) | Contact Time | Actual CT | Temp | pH | Required CT | CT Met? | Peak Hourly Demand Flow |
| | [ppm or mg/L] | [minutes] | C X T | [°C] | | Use Tables | Yes / No | [GPM] |
| 01 / 1310 | 1.26 | 76.0 | 96 | 9 | 7.0 | 26 | Yes | 7,500 |
| 02 / 1431 | 1.29 | 59.0 | 76 | 9 | 7.0 | 26 | Yes | 9,514 |
| 03 / 0951 | 1.25 | 64.0 | 80 | 9 | 7.0 | 26 | Yes | 9,027 |
| 04 / 1036 | 1.23 | 72.0 | 89 | 8 | 6.9 | 26 | Yes | 7,986 |
| 05 / 0818 | 1.17 | 83.0 | 97 | 8 | 7.0 | 25 | Yes | 6,875 |
| 06 / 1549 | 1.25 | 69.0 | 86 | 9 | 6.9 | 26 | Yes | 8,264 |
| 07 / 1413 | 1.29 | 58.0 | 75 | 10 | 6.9 | 19 | Yes | 9,861 |
| 08 / 1127 | 1.31 | 63.0 | 83 | 10 | 7.0 | 19 | Yes | 9,097 |
| 09 / 1002 | 1.35 | 54.0 | 73 | 10 | 7.0 | 19 | Yes | 10,763 |
| 10 / 1300 | 1.20 | 59.0 | 71 | 10 | 7.1 | 23 | Yes | 9,444 |
| 11 / 1428 | 1.30 | 59.0 | 77 | 11 | 7.1 | 23 | Yes | 9,444 |
| 12 / 0734 | 1.16 | 68.0 | 79 | 11 | 7.1 | 23 | Yes | 8,611 |
| 13 / 1344 | 1.23 | 92.0 | 113 | 10 | 7.0 | 19 | Yes | 6,250 |
| 14 / 0934 | 1.29 | 76.0 | 98 | 9 | 7.0 | 26 | Yes | 7,361 |
| 15 / 0825 | 1.37 | 76.0 | 104 | 9 | 7.0 | 26 | Yes | 7,639 |
| 16 / 0753 | 1.34 | 63.0 | 84 | 9 | 7.1 | 31 | Yes | 9,097 |
| 17 / 1051 | 1.22 | 63.0 | 77 | 10 | 7.1 | 23 | Yes | 9,167 |
| 18 / 0951 | 1.30 | 63.0 | 82 | 10 | 7.0 | 19 | Yes | 9,306 |
| 19 / 0936 | 1.34 | 104.0 | 139 | 10 | 7.0 | 19 | Yes | 5,486 |
| 20 / 1842 | 1.29 | 83.0 | 107 | 10 | 7.1 | 23 | Yes | 6,736 |
| 21 / 1210 | 1.39 | 88.0 | 122 | 9 | 7.1 | 31 | Yes | 6,597 |
| 22 / 1947 | 1.37 | 76.0 | 104 | 9 | 7.1 | 31 | Yes | 7,431 |
| 23 / 1718 | 1.48 | 54.0 | 80 | 9 | 7.1 | 32 | Yes | 10,625 |
| 24 / 1156 | 1.30 | 69.0 | 90 | 9 | 7.1 | 31 | Yes | 8,264 |
| 25 / | | | | | | | | OFF |
| 26 / 1227 | 1.32 | 72.0 | 95 | 9 | 7.0 | 26 | Yes | 7,917 |
| 27 / 0729 | 1.32 | 76.0 | 100 | 9 | 7.0 | 26 | Yes | 7,361 |
| 28 / 0714 | 1.41 | 104.0 | 147 | 8 | 7.1 | 32 | Yes | 5,555 |
| 29 / 1342 | 1.32 | 98.0 | 129 | 8 | 7.1 | 31 | Yes | 5,694 |
| 30 / 0742 | 1.28 | 68.0 | 87 | 7 | 7.1 | 31 | Yes | 8,402 |
| 31 / 0727 | 1.29 | 55.0 | 71 | 7 | 7.2 | 31 | Yes | 10,208 |

³ If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by next business day.

Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf