



## OHA - Drinking Water Program - Surface Water Quality Data Form

Corvallis, City of ID#: 41 00225 WTP-: WTP - B							Month/Year: Jul / 2024		Required Log Inactivation: 0.5	
Date	Time	Minimum Cl <sub>2</sub> Residual at 1st User (C)	Contact Time	Actual CT	Temp	pH	Required CT	CT Met?	Peak Hourly Demand Flow	
		[ppm or mg/L]	[minutes]	<b>C X T</b>	[°C]	7.3	Use Tables	Yes / No	[GPM]	
01	1700	1.21	36	44	16	7.3	16	Yes	1,875	
02	0100	1.29	36	46	16	7.4	16	Yes	1,875	
03	0600	1.28	36	46	16	7.4	16	Yes	1,597	
04	0000	1.31	36	47	16	7.3	16	Yes	1,597	
05	1800	1.15	36	41	16	7.3	15	Yes	1,528	
06	2300	1.32	36	48	17	7.3	16	Yes	1,597	
07	1700	1.13	36	41	17	7.3	15	Yes	1,597	
08	1100	1.20	36	43	18	7.3	15	Yes	1,597	
09	0200	1.31	36	47	18	7.3	16	Yes	1,806	
10	2200	1.28	36	46	19	7.3	16	Yes	1,806	
11	1700	1.10	36	40	19	7.3	15	Yes	1,806	
12	0100	1.35	36	49	18	7.3	16	Yes	1,806	
13	0900	1.29	36	46	18	7.3	16	Yes	1,806	
14	0900	1.23	36	44	18	7.2	16	Yes	1,736	
15	0800	1.25	36	45	18	7.2	16	Yes	1,736	
16	2300	1.31	36	47	18	7.2	16	Yes	1,736	
17	1600	1.13	36	41	18	7.2	15	Yes	1,736	
18	0900	1.27	36	46	18	7.2	16	Yes	1,806	
19	1000	1.19	36	43	18	7.2	15	Yes	1,736	
20	0000	1.30	36	47	18	7.2	16	Yes	1,736	
21	0800	1.24	36	45	18	7.2	16	Yes	1,806	
22	1000	1.17	36	42	18	7.2	15	Yes	1,736	
23	0100	1.26	36	45	18	7.2	16	Yes	1,736	
24	0000	1.22	36	44	17	7.2	16	Yes	1,736	
25	0800	1.23	36	44	17	7.2	16	Yes	1,736	
26	0000	1.29	36	46	18	7.2	16	Yes	1,736	
27	1700	1.13	36	41	18	7.2	15	Yes	1,736	
28	1100	1.18	36	42	18	7.2	15	Yes	1,736	
29	1700	1.15	36	41	18	7.2	15	Yes	1,806	
30	1100	1.14	36	41	17	7.2	15	Yes	1,806	
31	1400	1.13	36	41	18	7.1	15	Yes	1,806	

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by next business day.