


**OHA - Drinking Water Program - Turbidity Monitoring Report Form    County: Benton**  
**Conventional or Direct Filtration**

**System Name: Corvallis, City of    ID#: OR4100225 WTP--:WTP-A    Month/Year:    May / 2021**

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day <sup>1</sup> (NTU)
1	Off	Off	0.03	0.02	0.03	Off	0.04
2	Off	Off	0.03	0.03	0.03	Off	0.04
3	Off	Off	0.03	0.03	0.03	Off	0.03
4	Off	Off	0.03	0.02	0.03	Off	0.04
5	Off	Off	0.03	0.02	0.03	Off	0.04
6	Off	Off	0.03	0.03	0.03	Off	0.03
7	Off	Off	0.03	0.02	0.03	Off	0.04
8	Off	Off	0.03	0.02	0.02	Off	0.05
9	Off	Off	0.03	0.02	0.02	Off	0.04
10	Off	Off	0.02	0.02	0.03	Off	0.04
11	Off	Off	0.03	0.03	0.02	Off	0.04
12	Off	Off	0.03	0.03	0.03	Off	0.04
13	Off	Off	0.03	0.03	0.03	Off	0.04
14	Off	Off	0.03	0.02	0.03	Off	0.03
15	Off	Off	0.03	0.02	0.03	Off	0.03
16	Off	Off	0.02	0.02	0.03	Off	0.04
17	Off	Off	0.02	0.03	0.03	Off	0.04
18	Off	Off	0.02	0.02	0.03	Off	0.04
19	Off	Off	0.02	0.02	0.02	Off	0.04
20	Off	Off	0.02	0.02	0.02	Off	0.03
21	Off	Off	0.02	0.02	0.02	Off	0.03
22	Off	Off	0.02	0.02	0.02	Off	0.03
23	Off	Off	0.02	0.02	0.02	Off	0.04
24	Off	Off	0.02	0.02	0.02	Off	0.03
25	Off	Off	0.02	0.02	0.02	Off	0.04
26	Off	Off	0.02	0.02	0.03	Off	0.03
27	Off	Off	0.03	0.02	0.02	Off	0.04
28	Off	Off	0.03	0.02	0.03	Off	0.03
29	Off	Off	0.03	0.02	0.03	Off	0.04
30	Off	Off	0.03	0.03	0.03	Off	0.04
31	Off	Off	0.03	0.02	0.03	Off	0.03

<b>Conventional or Direct Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? <b>Yes/No</b>	CT's met everyday? <b>Yes/No</b>	All Cl <sub>2</sub> residuals at entry point $\geq$ 0.2 mg/l? <b>Yes/No</b>	
All the 4-hour turbidity readings $\leq$ 1 NTU? <b>Yes/No</b>	(see back) <b>Yes/No</b>	<b>Yes/No</b>	
All turbidity readings < IFE <sup>2</sup> triggers? <b>Yes/No</b>	<b>Yes/No</b>		
<b>Notes:</b>	<b>PRINTED NAME: Tom Hubbard</b>		
	<b>SIGNATURE: </b>		<b>DATE: 6-3-2021</b>
	<b>PHONE #: (541) 754-1758</b>		<b>CERT #: 08804</b>

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.

<sup>2</sup> IFE = Individual Filter Effluent (OAR 333-061-0040 (1) (e) (B&C))

**OHA - Drinking Water Program - Surface Water Quality Data Form**

**Corvallis, City of**    **ID#: 41 00225 WTP:- WTP - A**    **Month/Year: May / 2021**    Required Log Inactivation: 0.5

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	ppm or mg/L	minutes	C X T	° C		Use tables	Yes / No	[GPM]
01 / 0654	1.13	55.0	62	15	6.9	13	Yes	10300
02 / 1003	1.19	54.0	64	15	6.7	13	Yes	10600
03 / 1356	1.16	58.0	67	14	6.7	19	Yes	10100
04 / 1413	1.12	55.0	62	15	6.8	13	Yes	10400
05 / 0943	1.06	55.0	58	15	6.8	13	Yes	10400
06 / 1100	1.16	55.0	64	15	6.7	13	Yes	10400
07 / 0754	1.05	54.0	57	15	6.8	13	Yes	10500
08 / 1012	1.12	59.0	66	14	6.6	19	Yes	9500
09 / 0730	1.04	55.0	57	14	6.8	19	Yes	10200
10 / 1521	1.21	44.0	53	14	6.9	19	Yes	13000
11 / 1448	1.16	45.0	52	15	6.8	13	Yes	12700
12 / 1018	1.24	41.0	51	15	6.8	13	Yes	14000
13 / 0950	1.21	45.0	54	16	6.7	13	Yes	12700
14 / 0931	1.16	55.0	64	16	6.7	13	Yes	10400
15 / 1309	1.16	55.0	64	17	6.7	13	Yes	10400
16 / 0857	1.13	59.0	67	17	6.7	13	Yes	9400
17 / 1204	1.12	59.0	66	17	6.6	13	Yes	9400
18 / 0932	1.14	59.0	67	17	6.6	13	Yes	9600
19 / 1330	1.10	68.0	75	13	6.6	19	Yes	8500
20 / 1030	1.14	59.0	67	14	6.6	19	Yes	9400
21 / 0725	1.16	59.0	68	14	6.6	19	Yes	9400
22 / 0605	1.19	58.0	69	14	6.7	19	Yes	9900
23 / 1113	1.10	59.0	65	14	6.7	19	Yes	9400
24 / 1038	1.16	63.0	73	14	6.7	19	Yes	9200
25 / 1600	1.13	63.0	71	15	6.7	13	Yes	9200
26 / 1521	1.15	59.0	68	15	6.8	13	Yes	9500
27 / 1402	1.13	55.0	62	15	6.7	13	Yes	10200
28 / 1350	1.21	54.0	65	15	6.7	13	Yes	10600
29 / 1249	1.13	52.0	59	15	6.7	13	Yes	11000
30 / 1012	1.19	54.0	64	16	6.7	13	Yes	10700
31 / 1441	1.11	52.0	58	18	6.7	13	Yes	11100

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by next business day.