

OHA - DWS

Membrane Filter Monthly Operating Report

County: LANE

System Name: ROW RIVER WTP

Month/Year: Feb-2025

PWS ID#: 41 - 00236

Minimum test pressure applied || req'd: 27.190 psi || 27.0 ps

Plant ID: WTP - B (e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇌

PDR = Pressure Decay Rate

LRC = Log Removal Credit

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 min duration)	PDR _{Max} [^{psi} / _{min}]	LRC [log removal]	DIT Daily
				0.170	4.00	
1	0.014		0.014	0.04	5.07	Y
2	0.012		0.012	0.04	5.07	Y
3	0.015		0.015	0.04	5.06	Y
4	0.013		0.013	0.04	5.06	Y
5	0.012		0.012	0.04	5.14	Y
6	0.012		0.012	0.04	5.05	Y
7	0.013		0.013	0.04	5.01	Y
8	0.014		0.014	0.04	5.06	Y
9	0.013		0.013	0.04	5.05	Y
10	0.012		0.012	0.04	5.03	Y
11	0.014		0.014	0.04	5.02	Y
12	0.013		0.013	0.05	4.95	Y
13	0.013		0.013	0.05	4.99	Y
14	0.015		0.015	0.05	4.98	Y
15	0.013		0.013	0.03	5.04	Y
16	0.014		0.014	0.03	5.08	Y
17	0.015		0.015	0.03	5.04	Y
18	0.014		0.014	0.04	4.98	Y
19	0.013		0.013	0.03	5.03	Y
20	0.014		0.014	0.03	5.11	Y
21	0.015		0.015	0.03	5.05	Y
22	0.013		0.013	0.03	5.07	Y
23	0.016		0.016	0.03	5.14	Y
24	0.013		0.013	0.04	4.92	Y
25	0.014		0.014	0.04	4.98	Y
26	0.013		0.013	0.03	5.04	Y
27	0.014		0.014	0.04	5.00	Y
28	0.015		0.015	0.03	5.15	Y
29						Y
30						Y
31						Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Yes	Yes	Yes	Yes	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
Yes	Yes	Yes	Yes	

PRINTED NAME: Ryan Kimball

SIGNATURE: 

Notes:

DATE: 3/3/2025

WT CERT #: T-882889

PHONE #: 541-942-7094

Disinfection Monthly Operating ReportSystem Name: **ROW RIVER WTP**PWS ID#: 41 - **00236**Plant ID : WTP - **B****0.5**

Log
Inactivation
Required via
Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	0.790	140	110.6	5.2	7.97	36.8	YES	996	
2	0.770	140	107.8	5.6	7.99	36.0	YES	992	
3	0.770	140	107.8	5.5	8.04	36.8	YES	1,033	
4	0.830	140	116.2	5.8	8.06	36.8	YES	960	
5	0.820	140	114.8	5.8	8.08	36.9	YES	870	
6	0.810	140	113.4	6.2	8.09	35.9	YES	897	
7	0.800	140	112.0	6.3	8.11	36.0	YES	957	
8	0.800	140	112.0	6.2	8.11	36.1	YES	988	
9	0.800	140	112.0	5.9	8.11	36.9	YES	1,011	
10	0.780	140	109.2	6.4	7.96	33.7	YES	1,000	
11	0.780	140	109.2	6.2	7.98	34.4	YES	947	
12	0.780	140	109.2	6.2	7.98	34.4	YES	947	
13	0.780	140	109.2	6.0	7.99	35.1	YES	1,070	
14	0.740	140	103.6	6.0	7.89	33.6	YES	1,061	
15	0.780	140	109.2	6.2	7.95	34.1	YES	1,077	
16	0.790	140	110.6	6.6	7.93	32.9	YES	1,054	
17	0.790	140	110.6	7.0	7.89	31.5	YES	1,000	
18	0.780	140	109.2	7.4	7.86	30.4	YES	960	
19	0.760	140	106.4	7.8	7.81	28.9	YES	903	
20	0.770	140	107.8	8.0	7.79	28.3	YES	882	
21	0.770	140	107.8	8.2	7.81	28.3	YES	937	
22	0.760	140	106.4	8.4	7.85	28.2	YES	943	
23	0.760	140	106.4	8.4	8.05	30.3	YES	943	
24	0.740	140	103.6	8.9	7.82	26.9	YES	852	
25	0.720	140	100.8	9.0	7.77	26.1	YES	814	
26	0.730	140	102.2	9.2	7.75	25.7	YES	817	
27	0.760	140	106.4	9.3	7.79	25.9	YES	825	
28	0.700	140	98.0	9.6	7.87	26.0	YES	878	
29		140							
30		140							
31		140							

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350
email: dwp.dmce@odhsoha.oregon.gov
fax: 971-673-0458

p. 2 of 2