

Oregon DHS - Drinking Water Services – Turbidity Monitoring Report Form

System Name: London Water Co-Op	ID# 41 00239	Month/Year: Mar	2022
--	---------------------	------------------------	-------------

	(NTU)	(NTU)	(NTU)	(NTU)	(NTU)	(NTU)	(NTU)	Flow (GPM)
3/4/2022					0.233	0.122	0.233	2.1
3/5/2022	0.074	0.054	0.054				0.074	2.2
3/10/2022					0.139	0.061	0.139	2.2
3/11/2022	0.058	0.06	0.069				0.069	2.1
3/17/2022				0.212	0.145	0.144	0.212	2
3/18/2022	0.16	0.179	0.206				0.206	2.2
3/22/2022						0.196	0.196	2.1
3/23/2022	0.243	0.29	0.217	0.241			0.29	2.1
3/28/2022					0.239	0.052	0.239	2.2
3/29/2022	0.048	0.045	0.046				0.048	2.1

- OR -	PRINTED NAME: <u>T. FINN KADOMAS</u>
Slow Sand/Cartridge/Membrane/DE Filtration	SIGNATURE: _____ DATE: <u>4-10-22</u>
95% of turbidity readings ≤ 1 NTU? All turbidity readings < 5 NTU?	PHONE #: <u>541 942-8563</u> CERT #:
Is there 4-log virus inactivation provided with <input checked="" type="checkbox"/> Chlorine; <input type="checkbox"/> Other _____ <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT _{viral} : Required = _____ Achieved = _____

¹ Including continuous NTU data, if applicable, for optimization recording purposes

² IFE = Individual Filter Effluent

RECEIVED

APR 14 2022

Data Mgmt & Compliance
Drinking Water Program

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: London Water Co-Op ID# 41 00239 Month/Year: Mar / 2022

Minimum UVT [%] during month: _____ Duty sensor variation from reference sensor %: _____ 0

Minimum Validated UVT : {Insert Req'd Value}

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1						0
2						
3						
#####	15	213	Y		0	
5	15	215	Y	16282	0	
6						
7						
8						
9						
10	15	214	Y	15863	0	
11						
12						
13						
14						
15						
16						
17	15	213	Y		0	
18	15	212	Y	17504	0	
19						
20						
21						
22	15	212	Y		0	
23	15	213	Y	18479	0	
24						
25						
26						
27						
28	15	214	Y		0	
29	15	214	Y	17365	0	
30						
31						
Monthly Cumulative % Off-Spec Water Produced						

rev 1/11 I:\MC\forms\Turbidity Report Form – UV and opt mod.doc

Signature: T. FINN KADRUBS Op Cert #: _____

Date: 4-10-22
RECEIVED
APR 14 2022

Data Mgmt & Compliance
Drinking Water Program