

WTP: _____ County: LANE**ces – Turbidity Monitoring Report Form**System Name: **London Water Co-Op**ID# **41 00239**Month/Year: **Apr****2022**

	(NTU)	(NTU)	(NTU)	(NTU)	(NTU)	(NTU)	U)	Flow (GPM)
4/3/2022					0.13	0.07	0.1	2.2
4/4/2022	0.064	0.063	0.047	0.046				2.1
4/9/2022					0.116	0.068	0.1	2.1
4/10/22/	0.065	0.067	0.069	0.054			0.1	2.1
4/15/2022						0.148	0.1	2
4/16/2022	0.231	0.103	0.076	0.119			0.2	2.2
4/21/2022						0.275	0.3	2.1
4/22/2022	0.052	0.049	0.049	0.06			0.1	2
4/27/2022					0.254	0.204	0.3	2.1
4/28/2022	0.287	0.228	0.276	0.248			0.3	2

- OR -

Slow
Sand95%
of
total
sandPRI
NTE
SIG
NAT
PRO
MEYes / No
Yes / NoNOT
here

Yes / No

4/9/2022

CERT #:

CT_{virat}: Required =
Achieved =¹ Including continuous NTU data, if applicable, for optimization recording purposes² IFE = Individual Filter Effluent

E:\Water_Reports\Apr2022\Apr

Received Time May. 10. 2022 3:05PM No. 8603

WTP: _____ County: LANE**Oregon DHS - Drinking Water Services – Surface Water Quality Data**System Name: London Water Co-OpID# 41 00239Month/Year: Apr / 2022

Minimum UVT [%] during month: _____

Duty sensor variation from reference sensor %: _____

0

Minimum Validated UVT : {Insert Req'd Value}

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced (Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
	[gpm/unit]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	
1						
2						
3	15	215	Y	16278	0	
4	15	212	Y			
5						
6						
7						
8						
9	15	213	Y	16103	0	
10	15	215	Y			
11						
12						
13						
14						
15	15	212	Y	14904	0	
16	15	213	Y			
17						
18						
19						
20						
21	15	214	Y	15875	0	
22	15	213	Y			
23						
24						
25						
26						
27	15	213	Y	16149	0	
28	15	212	Y			
29						
30						
31						
Monthly Cumulative % Off-Spec Water Produced						

rev 1/11 I:\MC\forms\Turbidity Report Form – UV and opt mod.doc

Signature: _____

Op Cert #: _____

Date: 4-9-22