

RECEIVED

MAR 10 2023

Certification

WTP: County: LANE

Oregon DHS - Drinking Water Services Turbidity Monitoring Report Form

System Name: London Water Co-Op ID# 41 00239 Month/Year: Feb / 2023

Table with 9 columns: DAY, 12:00 AM (NTU), 4:00 AM (NTU), 8:00 AM (NTU), NOON (NTU), 4:00 PM (NTU), 8:00 PM (NTU), Highest Reading of the Day (NTU), Peak Hourly Demand Flow (GPM). Rows 1-31 contain turbidity data.

Summary section with four main boxes: Conventional or Direct Filtration Monthly Summary, Monthly UV Summary (Circle Yes or No), Slow Sand/Cartridge/Membrane/DE Filtration, and Is there 4-log virus inactivation provided with X Chlorine; Other Yes/No. Includes handwritten signatures and dates.

1 Including continuous NTU data, if applicable, for optimization recording purposes

2 IFE = Individual Filter Effluent

WTP: ___ County: ___

Oregon DHS - Drinking Water Services – Surface Water Quality Data

System Name: London Water Co-Op ID# 41 00239 Month/Year: Feb / 2023
 Minimum UVT [%] during month: _____ Duty sensor variation from reference sensor %: _____ 0
 Minimum Validated UVT : {Insert Req'd Value}

Date	Peak Hourly Demand Flow	Minimum Intensity	All Lamps On?	Daily Water Produced {A}	Water outside Validated Conditions {B}	Cumulative % Off-Spec Water Produced
	[gpm/unit]	[^{mW} /cm ²]	[Y or N]	[gal]	[gal]	(Mo. Sum {B}) ÷ (Mo. Sum {A}) * 100 [%]
1						0
2						
3						
4	13.1	214	Y	11029	0	
5	11.9	211	Y	8628	0	
6						
7						
8						
9						
10						
11	12.1	214	Y	9498	0	
12	8.48	214	Y	6615	0	
13						
14						
15						
16	13.1	212	Y	5522	0	
17	10.2	210	Y	11712	0	
18						
19						
20						
21						
22	8.9	211	Y	8017	0	
23	8.72	216	Y	8377	0	
24						
25						
26						
27	13.2	216	Y	11166	0	
28	11.9	212	Y	7154	0	
29						
30						
31						
Monthly Cumulative % Off-Spec Water Produced						

rev 1/11 E:\MC\forms\Turbidity Report Form – UV and opt mod.doc

Signature: 

Op Cert #: 

Date: 2/6/23