

OHA - DWS

Membrane Filter Monthly Operating Report

System Name: City of Creswell

County: Lane

PWS ID#: 41 - 00246

Month/Year: May-2025

Minimum test pressure applied || req'd: 22.0 psi // 17.5 psi

Plant ID: WTP - B (e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇌

PDR = Pressure Decay Rate

LRC = Log Removal Credit

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 min duration)	PDR _{Max} [^{psi} /min]	LRC [log removal]	DIT Daily
				0.030	4.00	
1	0.023	0.03	0.045	0.02		Y
2	0.020	0.021	0.050	0.02		Y
3	0.021	0.022	0.057	0.02		Y
4	0.021	0.022	0.028	0.02		Y
5	0.022	0.027	0.020	0.02		Y
6	0.022	0.023	0.034	0.02		Y
7	0.021	0.021	0.032	0.02		Y
8	0.022	0.022	0.050	0.02		Y
9	0.021	0.024	0.037	0.02		Y
10	0.022	0.023	0.050	0.02		Y
11	0.021	0.022	0.024	0.02		Y
12	0.020	0.022	0.033	0.02		Y
13	0.020	0.02	0.041	0.02		Y
14	0.021	0.026	0.026	0.02		Y
15	0.023	0.024	0.059	0.02		Y
16	0.023	0.068	0.071	0.02		Y
17	0.021	0.054	0.057	0.02		Y
18	0.021	0.041	0.023	0.02		Y
19	0.021	0.05	0.044	0.02		Y
20	0.021	0.024	0.017	0.02		Y
21	0.021	0.026	0.019	0.02		Y
22	0.022	0.022	0.017	0.01		Y
23	0.022	0.033	0.019	0.02		Y
24	0.022	0.035	0.048	0.01		Y
25	0.023	0.042	0.024	0.01		Y
26	0.020	0.029	0.027	0.01		Y
27	0.021	0.039	0.025	0.02		Y
28	0.020	0.04	0.022	0.02		Y
29	0.022	0.035	0.045	0.02		Y
30	0.021	0.044	0.060	0.02		Y
31	0.019	0.034	0.036	0.02		Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Yes	Yes	Yes	Yes	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
Yes	Yes	Yes		

PRINTED NAME: Mike Howard DATE: 6/1/2025
 SIGNATURE: Mike Howard WT CERT #: T-5028
 Notes: Computer not set u PHONE #: 541-895-4044

Disinfection Monthly Operating Report

May-2025

System Name: **City of Creswell**PWS ID#: 41 - **0.0246**Plant ID : WTP - **B****0.5**Log
Inactivation
Required via
Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	0.700	47	32.9	15.0	8.10	19.8	YES	1,524	
2	0.680	47	32.0	15.0	7.80	17.7	YES	1,222	
3	0.660	47	31.0	14.0	7.80	18.8	YES	1,587	
4	0.710	47	33.4	14.0	8.00	20.4	YES	1,515	
5	0.680	47	32.0	15.0	8.00	19.0	YES	1,500	
6	0.660	47	31.0	13.0	8.00	21.7	YES	1,534	
7	0.660	47	31.0	14.0	8.00	20.3	YES	1,518	
8	0.710	47	33.4	16.0	8.00	17.9	YES	1,601	Highest
9	0.720	47	33.8	16.0	7.70	16.0	YES	1,564	
10	0.730	47	34.3	16.0	7.80	16.6	YES	1,384	
11	0.750	47	35.3	16.0	7.90	17.3	YES	1,556	
12	0.690	47	32.4	15.0	7.80	17.7	YES	1,562	
13	0.730	47	34.3	15.0	7.90	18.4	YES	1,526	
14	0.660	47	31.0	14.0	8.00	20.3	YES	1,541	
15	0.680	47	32.0	15.0	7.90	18.3	YES	1,371	
16	0.640	47	30.1	15.0	7.90	18.2	YES	1,567	
17	0.630	47	29.6	15.0	7.80	17.6	YES	1,601	Highest
18	0.730	47	34.3	15.0	7.70	17.1	YES	1,559	
19	0.750	47	35.3	15.0	7.80	17.8	YES	721	
20	0.750	47	35.3	14.0	8.00	20.5	YES	1,560	
21	0.770	47	36.2	14.0	8.10	21.3	YES	1,522	
22	0.690	47	32.4	15.0	8.10	19.8	YES	1,283	
23	0.720	47	33.8	15.0	7.80	17.7	YES	1,183	
24	0.740	47	34.8	15.0	8.00	19.1	YES	1,252	
25	0.710	47	33.4	15.0	8.10	19.8	YES	1,112	
26	0.780	47	36.7	15.0	8.00	19.2	YES	731	
27	0.710	47	33.4	15.0	8.00	19.1	YES	832	
28	0.720	47	33.8	16.0	8.30	20.0	YES	1,173	
29	0.670	47	31.5	17.0	8.20	17.9	YES	1,330	
30	0.740	47	34.8	17.0	7.80	15.6	YES	1,420	
31	0.710	47	33.4	18.0	7.90	15.1	YES	1,385	

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350

email: dwp.dmce@odhsoha.oregon.gov

fax: 971-673-0458

p. 2 of 2