

OHA - Drinking Water Services – Turbidity Monitoring Report
Conventional or Direct Filtration

County: Poll

Name: City of Dallas

ID #41: 00248

WTP: Dallas

Month/Year: May 2025

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.077	.079	.064	.073	.060	.061	.079
2	.061	.067	.068	.086	.061	.061	.086
3	.061	.066	.064	.067	.073	.067	.073
4	.061	.061	.061	.065	.071	.066	.071
5	.073	.148	.061	.060	.061	.061	.148
6	.061	.061	.067	.059	.060	.061	.067
7	.061	.062	.071	.061	.060	.061	.071
8	.061	.061	.061	.067	.067	.079	.079
9	.061	.061	.061	.061	.065	.061	.065
10	.059	.061	.061	.060	.067	.065	.067
11	.061	.067	.060	.061	.061	.061	.067
12	.065	.071	.065	.059	.061	.061	.071
13	.061	.065	.061	.084	.067	.073	.084
14	.061	.060	.060	.067	.090	.061	.090
15	.067	.061	.063	.061	.065	.065	.067
16	.067	.079	.061	.061	.061	.065	.079
17	.065	.060	.067	.061	.061	.066	.067
18	.061	.065	.077	.073	.061	.061	.067
19	.061	.071	.065	.060	.066	.073	.073
20	.061	.060	.065	.077	.071	.073	.077
21	.111	.060	.060	.065	.065	.071	.111
22	.067	.073	.060	.060	.065	.067	.073
23	.071	.067	.073	.061	.060	.061	.073
24	.060	.065	.067	.079	.060	.061	.079
25	.061	.067	.067	.070	.073	.067	.073
26	.061	.060	.061	.067	.067	.067	.067
27	.060	.061	.061	.065	.066	.067	.067
28	.067	.073	.061	.061	.061	.065	.073
29	.066	.109	.059	.061	.061	.061	.109
30	.061	.061	.061	.061	.061	.061	.061
31	.061	.060	.060	.061	.061	.060	.061

Conventional or Direct Filtration Monthly Summary 95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? <u>Yes</u> / No All the 4-hour turbidity readings $\leq$ 1 NTU? <u>Yes</u> / No All turbidity readings < IFE ² triggers? <u>Yes</u> / No ²		Monthly Summary (Answer Yes or No) CT's met everyday? (see back) <u>Yes</u> / No All Cl ₂ residuals at entry point $\geq$ 0.2 mg/l? <u>Yes</u> / No	
Notes:		PRINTED NAME: <u>Jason Anderson</u> SIGNATURE: <u>Jason Anderson</u> DATE: <u>6/3/2025</u> PHONE #: <u>(503) 623-2125</u> CERT #: <u>7030</u>	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.
² IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form - Giardia Inactivation

Name: City of Dallas

ID #41:

00248

WTP-:

Dallas

Month/Year:

May 2025

Log Requirement

(Circle One): 0.5 (1.0)

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/0800	1.21	112	136	12.5	7.35	46	Y	2195.7
2/0830	1.10	112	123	14.0	7.09	45	Y	2157.6
3/0940	1.20	112	134	14.0	7.16	46	Y	2111.5
4/0945	1.19	112	133	13.3	7.25	46	Y	2016.1
5/0915	1.06	112	118	12.5	7.30	45	Y	2364.2
6/0750	1.12	112	125	13.3	7.25	46	Y	2442.0
7/0936	1.11	112	124	14.1	7.15	46	Y	2385.4
8/0805	1.26	112	141	13.3	7.17	47	Y	2152.7
9/0815	1.19	112	133	13.1	7.21	46	Y	2370.8
10/1035	.97	112	108	13.8	7.26	45	Y	2374.6
11/1045	1.10	112	123	13.5	7.31	46	Y	2349.6
12/0840	1.22	112	137	12.9	7.26	46	Y	2133.1
13/0800	1.10	112	123	12.2	7.36	45	Y	2090.8
14/0800	1.21	112	136	12.9	7.25	46	Y	2081.9
15/0800	1.24	112	139	13.2	7.33	47	Y	2023.7
16/0825	1.23	112	138	12.6	7.29	47	Y	1932.5
17/0900	1.12	112	125	13.0	7.23	46	Y	1954.1
18/0730	1.00	112	112	13.4	7.26	45	Y	1986.8
19/0740	1.07	112	119	13.4	7.27	45	Y	1958.4
20/0750	1.17	112	131	13.3	7.35	46	Y	1981.9
21/0830	1.12	112	125	13.1	7.36	45	Y	2088.7
22/0800	1.09	112	122	13.7	7.21	45	Y	2083.2
23/0900	1.10	112	123	13.5	7.63	46	Y	2158.7
24/0915	.99	112	110	14.4	7.29	45	Y	2408.0
25/0800	1.11	112	124	14.5	7.36	46	Y	2407.0
26/0830	1.11	112	124	14.4	7.36	46	Y	2444.6
27/0745	1.13	112	136	14.0	7.12	46	Y	2517.1
28/0815	1.17	112	131	15.8	7.21	31	Y	2600.9
29/0800	1.16	112	130	16.3	7.36	31	Y	2559.9
30/0815	1.24	112	139	15.5	7.07	31	Y	2509.2
31/0936	1.12	112	138	16.6	7.39	31	Y	2553.7

³ If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-conv-direct.pdf

Revised September 2016

Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350